

Torres Rojas, Genara

FOI#14241

**From:**  
**Sent:** Thursday, August 29, 2013 8:02 PM  
**To:** Duffy, Daniel  
**Cc:** Torres Rojas, Genara; Van Duyne, Sheree; Qureshi, Ann  
**Subject:** Freedom of Information Online Request Form

Information:

First Name: Jeffrey  
Last Name: Caubet  
Company: PATH  
Mailing Address 1:  
Mailing Address 2:  
City: 1  
State: 1  
Zip Code  
Email Address: \_  
Phon  
Required copies of the records: No

List of specific record(s):

I would like to request copies of the following records related to emergency preparedness at the PATH Harrison Car Maintenance Facility 1. The standard fire evacuation procedure. 2. The most recent fire alarm maintenance records. 3. The emergency services contingency plan in place during the blockage of fire lanes due to ongoing construction.

**THE PORT AUTHORITY OF NY & NJ**

*FOI Administrator*

October 18, 2013

Mr. Jeffrey Caubet

Re: Freedom of Information Reference No. 14241

Dear Mr. Caubet:

This is a response to your August 29, 2013 request, which has been processed under the Port Authority's Freedom of Information Code (the "Code"), for copies of the following records related to emergency preparedness at the PATH Harrison Car Maintenance Facility: 1. The standard fire evacuation procedure. 2. The most recent fire alarm maintenance records. 3. The emergency services contingency plan in place during the blockage of fire lanes due to ongoing construction.

Material responsive to the portion of your request as to the most recent fire alarm maintenance records and available under the Code can be found on the Port Authority's website at <http://www.panynj.gov/corporate-information/foi/14241-O.pdf>.

Certain material responsive to the portion of your request for the standard fire evacuation procedure is exempt from disclosure pursuant to exemption (4) of the Code.

Further, please be advised that we have searched our files and found no documents responsive to the remainder of your request.

Please refer to the above FOI reference number in any future correspondence relating to your request.

Very truly yours,



Ann L. Qureshi  
FOI Administrator

225 Park Avenue South, 17th Floor  
New York, NY 10003  
T: 212 435 3642  
F: 212 435 7555



AMERICAN PROTECTIVE SYSTEMS, INC.

Phone: (908) 725-2222

465 Union Avenue, Bridgewater, NJ 08807

Fax: (908) 725-2818

FIRE ALARM SYSTEM TEST / CERTIFICATION AND DESCRIPTION

Date: Time IN: Time OUT: Name: Manufacturer: Address: Listings: Local Remote station: Phone: Applicable NFIPA standards: Other standards: Jurisdiction: Jurisdiction phone:

Initiating Devices and Circuits

Manual stations coded noncoded single action dual action Addressable Y/N
Smoke detectors photo ion 2 wire 4 wire 110V interconnected Addressable Y/N
Heat detectors 135 fixed 135 ROR Addressable Y/N 194 fixed 194 ROR
Duct detectors photo ion 2 wire 4 wire Addressable Y/N
Beam detectors range Mfgr Model Addressable Y/N
Water flow switches 2" 4" 5" 6" 8" 10" other pressure rise
excess pressure (pressure drop) normal system pressure alarm pressure
other
initiating circuits - style initiating circuits - style

Indicating Appliances and Circuits

Horns with strobes Mfgr Model
Bells with strobes Mfgr Model Indicating Circuits Style
Strobes Mfgr Model
Other with strobes Mfgr Model

Supervisory Signal Initiating Devices and Circuits

Sprinkler control valve tamper switches OS&Y WIV Butterfly PIV Cord Type
Building temperature
A.C. power
other

System Power Supplies (If there is more than one aux power supply, complete the supplemental form)

Primary voltage location of over current device(s)
Standby voltage AH capacity calculated stand by time hours
Auxiliary power supply voltage AH capacity provides power for
Additional power supply information attached to this report (circle one) Yes / N/A

Service Data

Installation inspection cleaning testing date completed

Certification of System Operation

All operational features and functions of this system were tested by on and found to be operating properly in accordance with the standards referenced above.

Signature Witness (if any)

SYSTEM DEVIATIONS FROM REFERENCED STANDARDS ARE ARE NOT LISTED ON BACK OR ATTACHED.



AMERICAN PROTECTIVE SYSTEMS, INC.

Phone: (908) 725-2222

14 Culnen drive, Branchburg, NJ 08876

Fax: (908) 725-2818

8-13-13

Fire Alarm Inspection Zone List Page 2 of 6

Customer : PA HARRISON YARDS – AUGUST INSP

DATE: 8-13-2013

(list all supervisory functions, system components and action taken)

Zone/Pt.	Type	Location/Description	Remarks
ACCT. # 231-3000			
P3C2D6	PULL	Stockroom Exit (man door)	OK
P1C2D132	PULL	Wheel Turning Facility	OK
P3C5D8	SMOKE	1 <sup>st</sup> fl Freight Elev Lobby	OK
P3C5D7	SMOKE	Elev Mach Room	OK
P3C4D8	SMOKE	1 <sup>st</sup> fl Pass Elev Lobby	OK
P2C5D3	SMOKE	2 <sup>nd</sup> fl Pass Elev Lobby	OK
P2C5D8	SMOKE	3 <sup>rd</sup> fl Freight Elev Lobby	OK
P2C5D7	SMOKE	3 <sup>rd</sup> fl Pass Elev Lobby	OK
P5C2D4	SMOKE	Tower Elev Mach Room	OK
P5C2D1	SMOKE	Tower 1 <sup>st</sup> fl Elev Lobby	OK
P5C2D8	SMOKE	Tower 2 <sup>nd</sup> fl Elev Lobby	OK
P5C3D7	SMOKE	Tower 3 <sup>rd</sup> fl Elev Lobby	OK
P5C3D3	SMOKE	Tower 4 <sup>th</sup> fl Elev Lobby	OK
P2C3D2	DUCT	Upper Mezz, HV - 6	Verify shutdown OK
P2C3D3	DUCT	Upper Mezz, HV - 7	Verify shutdown OK
P4C4D3	WFLOW	Boiler Rm abv Ductwork	OK
P4C2D4	TAMPER	Boiler Rm abv Ductwork	Can't Test To High
P4C5D2	WFLOW	Pump Room Deluge Riser	OK
P4C2D3	TAMPER	Pump Room Deluge Valve	OK
P3C5D3	WFLOW	Truck Shop, West	OK
P3C3D2	TAMPER	Truck Shop, West	OK
P4C3D5	TAMPER	Main Pump Room	3 valves III OK
P4C3D6	TAMPER	Main Pump Room	5 valves III OK
P4C2D8	TAMPER	Boiler Room	6 valves III I OK
P4C3D8	TAMPER	Overhang by Brakeshop Ramp	OK
P4C4D2	TAMPER	Overhang by Brakeshop Ramp	OK
P4C4D1	TAMPER	Overhang by Brakeshop Ramp	OK
P4C3D4	TAMPER	Overhang by Brakeshop Ramp	OK
P1C2D127	WFLOW	Wheel Turning Facility	OK
P1C2D128	TAMPER	Wheel Turning Facility	OK
P1C2D129	SUPV	WHEEL TRUING FACILITY	PRESSURE SWITCH OK
P5C3D2	WFLOW	Tower Main WFlow	OK
P4C4D1	TAMPER	Tower Pump Room	Jockey pump, 3 valves III OK
P5C4D2	TAMPER	Tower Pump Room	Bypass 2 valves II OK
P5C4D3	TAMPER	Tower Pump Room	Main feeds 3 valves III OK
P3C12D3	SUPV	Main Pump Running	OK
P3C12D4	SUPV	Main Pump A/C Fail	OK
P5C4D4	SUPV	Tower Pump Running	OK
P5C5D1	SUPV	TOWER PUMP A/C FAIL	OK



AMERICAN PROTECTIVE SYSTEMS, Inc.

Phone: (908) 725-2222

14 Culnen drive, Branchburg, NJ 08876

Fax: (908) 725-2818

Standpipe Hose List Page 3 of 6

Customer : PA HARRISON YARDS - INSP

DATE: 8-13-2013

(list all supervisory functions, system components and action taken)

Number	Type	Location/Description	Remarks ACCT. # 231-3000
1	Standpipe	Main Bldg. 1 <sup>st</sup> Fl. M152 Hose 1969	Compressor Shop Hall OK
2	Standpipe	Main Bldg. 1 <sup>st</sup> Fl. by M143 Hose 2007	Hall 5 OK
3	Standpipe	Main Bldg. 1 <sup>st</sup> Fl. M149 Hose 2007	Store Room by Roll-up door at counter 5 OK
4	Standpipe	Main Bldg. 1 <sup>st</sup> Fl. M149 Hose (2007)	Store Room South West Corner OK
5	Standpipe	Main Bldg. 1 <sup>st</sup> Fl. M149 Hose (2007)	Store Room North West Corner OK
6	Standpipe	Main Bldg. Running Repair Hose 2007	Track 9 West Center OK
7	Standpipe	Main Bldg. Running Repair Hose 2007	Track 9 West by Ramp OK
8	Standpipe	Main Bldg. Running Repair Hose 2007	Track 7 West (Upper) OK
9	Standpipe	Main Bldg. Running Repair Hose 2007	Track 7 West Center (Upper) OK
10	Standpipe	Main Bldg. Running Repair Hose 2007	Track 7 West Center (Lower) OK
11	Standpipe	Main Bldg. Running Repair Hose 2007	Track 7 West (Lower) OK
12	Standpipe	Main Bldg. Running Repair Hose Hose 2007	Track 6 West (Upper) OK
13	Standpipe	Main Bldg. Running Repair Hose 2007	Track 6 West Center (Upper) OK
14	Standpipe	Main Bldg. Running Repair Hose 2007	Track 6 East Center (LOWER) OK
15	Standpipe	Main Bldg. Running Repair Hose 2007	Track 6 East (Upper) OK
16	Standpipe	Main Bldg. Running Repair Hose 2007	Track 6 East (Lower) OK
17	Standpipe	Main Bldg. Running Repair Hose 2007	Track 6 East Center (UPPER) OK
18	Standpipe	Main Bldg. Running Repair Hose 2007	Track 6 EAST (upper) OK
19	Standpipe	Main Bldg. Running Repair Hose 2007	Track 6 West (Lower) OK
20	Standpipe	Blowdown Bldg. West	(Upper) 3 (2011) OK
21	Standpipe	Blowdown Bldg. East Hose 2007	(Upper) Missing Hose OK
22	Standpipe	Blowdown Bldg. East Hose 2007	(Lower) OK
23	Standpipe	Blowdown Bldg West Hose 2007	(Lower) OK
24	Standpipe	Wheel Trving Facility Hose 2007	West OK
25	Standpipe	Wheel Trving Facility Hose 2007	East OK
26	Standpipe	Main Bldg. Running Repair Hose 2007	Track 9 East Center OK
27	Standpipe	Main Bldg. Heavy Repair Hose 2006	Motor Shop OK
28	Standpipe	Main Bldg. Heavy Repair Hose 2007	Track 10 East OK
29	Standpipe	Main Bldg. Heavy Repair Hose 2007	Track 13 East Wall OK
30	Standpipe	Main Bldg. Heavy Repair Hose 2007	Track 16 East OK
31	Standpipe	Main Bldg. Heavy Repair Hose 2007	Truck Washing Area East Center OK
32	Standpipe	Main Bldg. 2 <sup>nd</sup> Fl Stair B Hose 2007	M223 OK
33	Standpipe	Main Bldg. 2 <sup>nd</sup> Fl by M203 Hose 2007	OK
34	Standpipe	Main Bldg. 3 <sup>rd</sup> Fl Stair A Hose 2007	OK
35	Standpipe	Main Bldg 3 <sup>rd</sup> Fl Stair C Hose 2007	M302 OK
36	Standpipe	Main Bldg 3 <sup>rd</sup> Fl by M301 Hose 2007	OK
37	Standpipe	Main Bldg 3 <sup>rd</sup> Fl Stair B Hose 2007	M305 OK





AMERICAN PROTECTIVE SYSTEMS, INC.

Phone: (908) 725-2222

14 Culnen drive, Branchburg, NJ 08876

Fax: (908) 725-2818

Fire Alarm Inspection Zone List Page 5 of 6

Customer :HARRISON PATH FIRE DEPT. CONNECTIONS

DATE: 8-13-2012

(list all supervisory functions, system components and action taken)

Zone/Pt.	Type	Location/Description	Remarks ACCT. #231-3000
1	F.D. CONN.	SOUTH EAST BY HEAVING REPAIR	MAIN BUILDING ok
2	F.D. CONN.	SOUTH CENTER BY PUSSARELLE	MAIN BUILDING ok
3	F.D. CONN.	WEST BY STOCK RM.	MAIN BUILDING ok
4	F.D. CONN.	NORTH WEST BY BLOWDOWN	MAIN BUILDING ok
5	F.D. CONN.	NORTH CENTER BY TRACK 5	MAIN BUILDING ok
6	F.D. CONN.	NORTH EAST BY WHELL TURNING	MAIN BUILDING ok
7	F.D. CONN.	EAST BY TRACK 11 & 12	MAIN BUILDING ok
8	F.D. CONN.	NORTH EAST BY PUMP RM.	TOMLINSON TOWER ok
<b>NODE PANEL LOCATIONS</b>			
1	EST-3	WATCH ENGINEER OFFICE 24 con. Fig.	(2) 35 AMP. HR. BATTERY (dated 11-2012) ok
2	EST-3	CAFETERIA 3 <sup>RD</sup> FL. 24 con. Fig.	(2) 35 AMP. HR. BATTERY (dated 11-2012) ok
3	EST-3	LADIES RM. 1 <sup>ST</sup> FL. 24 con. Fig.	(2) 35 AMP. HR. BATTERY (dated 11-2012) ok
4	EST-3	TRACK 6 UPPER PLATFORM 24 con. Fig.	(2) 35 AMP. HR. BATTERY (dated 11-2012) ok
5	EST-3	TOWER 2 <sup>ND</sup> FL. MECH. RM. 24 con. Fig.	(2) 35 AMP. HR. BATTERY (dated 11-2012) ok
6	EST-3	SUB STATION 24 con. Fig.	(2) 7 AMP. HR. BATTERY (dated 11-2012) ok
<b>PRE ACTION PANELS</b>			
3		tower	ok
1		Sub station	ok
1		Main building pump rm.	ok



