

FOI # 15321

ROSENBAUM & ROSENBAUM, P.C.

ATTORNEYS AT LAW
100 WALL STREET
15TH FLOOR
NEW YORK, NEW YORK 10005
TEL (212) 514-5007
FAX (212) 514-9178

GEORGE D. ROSENBAUM
CRAIG D. ROSENBAUM

MATTHEW T. GAMMONS

JAMES Z. ROSS
JONATHAN E. GOLD

* ADMITTED N.Y. & MA.

www.rosenbaumnylaw.com
info@rosenbaumnylaw.com

September 15, 2014

Via Facsimile: 212-435-7555

Secretary of the Port Authority Of
New York and New Jersey
225 Park Avenue South, 17th Fl
New York, New York
Attn: FOI Administrator

Re: *Our Client : Herman Pasternack*
Our File No. : 14-001029
D/A : May 19, 2014

Dear Sir/Madam:


In accordance with the New York Freedom of Information Law, we hereby request records concerning prior notification and/or complaints of dangerous and defective conditions of the *automatic door number S14A3B bearing the bar code number 001411* at the Port Authority Bus Terminal located at the 8th Avenue entrance near 40th Street, New York, New York (attached hereto are photos of the subject premises and automatic door).

We hereby request all maintenance records, including but not limited to notices, correspondence, permits, work and repair orders to the door framework, saddle and motor that you received for 1 year prior to and including May 19, 2014.

Thank you for your prompt attention to this matter.

Very truly yours,

ROSENBAUM & ROSENBAUM, P.C.


Jonathan Gold

JG/kc
Enclosure

FOI Administrator

November 3, 2014

Mr. Jonathan Gold
Rosenbaum & Rosenbaum, P.C.
100 Wall Street, 15th Floor
New York, NY 10005

Re: Freedom of Information Reference No. 15321

Dear Mr. Gold:


This is in response to your September 15, 2014 request, which has been processed under the Port Authority's Freedom of Information Code (the "Code") for copies of "records concerning prior notification and/or complaints of dangerous and defective conditions of the" automatic door number S14A3B bearing the bar code number 001411 at the Port Authority Bus Terminal located at the 8th Avenue entrance near 40th Street, New York, NY. Copies of "all maintenance records, including but not limited to notices, correspondence, permits, work and repair orders to the door framework, saddle and motor one year prior to and including May 19, 2014."

Material responsive to your request for all maintenance records and available under the Code can be found on the Port Authority's website at <http://www.panynj.gov/corporate-information/foi/15321-O.pdf>. Paper copies of the available records are available upon request.

We have searched the Port Authority's files and found no records responsive to the remainder of your request.

Please refer to the above FOI reference number in any future correspondence relating to your request.

Very truly yours,



Daniel D. Duffy
FOI Administrator

DOOR AUTOMATION CORP

1800 ACCESS ROAD
 OCEANSIDE, NY 11572
 Phone (516) 678-4440 Fax (516) 887-7270

INVOICE

Date: 6/16/2014
 Invoice No: 13347

Bill to: PORT AUTHORITY BUS TERMINAL
 ATT: MAINTENANCE/BERNIE D'ALEO
 625 8TH AVE
 NEW YORK, NY 10018

Service at: PORT AUTHORITY BUS TERMINAL
 625 8TH AVENUNE
 NY NY 10018

Purchase Requisition #
~~4400 49-3686~~
 7/31/14-CR

Reference: Work Order 17575
 PO Number:
 Terms:

Work Date DAC Tag# Door Description Work Performed
 5/17/2014

329 PM PERFORMED

Item	Work Date	Description	Quantity	Unit Price	Amount
Labor	5/17/2014				
Labor Subtotal					0.00
Miscellaneous	2ND MAY PM		1.00	4,370.00	4,370.00
Miscellaneous Subtotal					4,370.00

OK
 BK
 7/25/14

[Signature]
 8/9/14

Subtotal:	4,370.00
Sales Tax:	0.00
Total Due:	4,370.00

DOOR AUTOMATION CORP.

DATE: 05/27/14

CUSTOMER: Quincy

PO: _____

LOCATION: _____

TN: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
346				South Wind	417 Stanley way
				OAC 041282	
346				Replaced Arm Track	
397				Replaced slider block	
315				Reset and ReProgram control	
316				Face Door is working OK	
331				Call completed	
270				North Wind	714 Stanley St
				OAC 041264	
270				Replaced Bottom Guide	
311				Reset and ReProgram control	
316				Face Door is working OK	

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 600

TRUCK #: 770

ARRIVED HERE: 9:00

NO. OF MEN: 1

LEFT THIS JOB: 1:00

JOB COMPLETED: YES NO

[Signature]
MECHANICS

[Signature]
CUSTOMER'S SIGNATURE

Re. L. Parker
PRINT NAME

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUN

DATE: 05/17/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	3	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	5	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	7	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	9	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	11	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	13	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	15	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	17	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	19	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	21	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	23	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	25	St old	✓	✓	✓	✓	✓	NO	control: 04280
LOWER LEVEL SOUTH	27	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	29	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	31	St old	✓	✓	✓	✓	✓	NO	

N OQBA



PA BUS TERMINAL DOOR MAINT CHECK LIST

J. Van

DATE: 05/17/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St aid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	34	St aid							R/H bottom Guide out of
LOWER LEVEL SOUTH	32	St aid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	30	St aid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	28	St aid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	26	St aid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	24	St aid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	22	St aid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	20	St aid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	18	St aid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	16	St aid	✓	✓	✓	✓	✓	NO	
REPAIRS									
LOWER LEVEL NORTH	60	St aid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	62	St aid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	62A	St aid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	63	St aid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	64	St aid	✓	✓	✓	✓	✓	NO	

03543

PA BUS TERMINAL DOOR MAINT CHECK LIST

Team

DATE: 11/23/13 05/17/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REPAIR	COMMENTS
LOWER LEVEL NORTH	65	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	66	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	67	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	68	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	69	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	70	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	71	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	71A	St old						NO	Bottom Bunch
LOWER LEVEL NORTH	72	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	73	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	74	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	75	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	75A	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	76	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	84A	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	85	St old	✓	✓	✓	✓	✓	NO	
L.L. NORTH	88	St old	✓	✓	✓	✓	✓	NO	

PA BUS TERMINAL DOOR MAINT CHECK LIST

Dick

DATE: 05/13/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PNOTS	REQUIRING REPAIR	COMMENTS
OVER LEVEL NORTH	61	SI 61d	✓	✓	✓	✓	✓		
OVER LEVEL NORTH	62	SI 61d	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	63	SI 61d	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	64	SI 61d	✓	✓	✓	✓	✓		

3rd FL NORTH	301	SI 61d	✓	✓	✓	✓	✓		
3rd FL NORTH	302	SI 61d	✓	✓	✓	✓	✓		
3rd FL NORTH	303	SI 61d	✓	✓	✓	✓	✓		
3rd FL NORTH	304	SI 61d	✓	✓	✓	✓	✓		
3rd FL NORTH	305	SI 61d	✓	✓	✓	✓	✓		
3rd FL NORTH	306	SI 61d	✓	✓	✓	✓	✓		
3rd FL NORTH	307	SI 61d	✓	✓	✓	✓	✓		
3rd FL NORTH	308	SI 61d	✓	✓	✓	✓	✓		
3rd FL NORTH	309	SI 61d	✓	✓	✓	✓	✓		
3rd FL NORTH	310	SI 61d	✓	✓	✓	✓	✓		

L/H 222222
S 222222

PA BUS TERMINAL DOOR MAINT CHECK LIST

JCA

DATE: *05/17/12*

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PNOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	St gw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	311	St gw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	312	St gw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	313	St gw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	314	St gw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	315	St gw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	316	St gw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	317	St gw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	318	St gw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	319	St gw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	320	St gw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	321	St gw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	322	St gw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	323	St gw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	324	St gw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	325	St gw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	326	St gw	✓	✓	✓	✓	✓	NO	

PA BUS TERMINAL DOOR MAINT CHECK LIST

3-11-14

DATE: 2/05/14/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St SW	✓	✓	✓	✓	✓	no	
4th FL SOUTH	402	St SW	✓	✓	✓	✓	✓	no	control overs
4th FL SOUTH	403	St SW	✓	✓	✓	✓	✓	no	
4th FL SOUTH	404	St SW	✓	✓	✓	✓	✓	no	slide block 0270
4th FL SOUTH	405	St SW	✓	✓	✓	✓	✓	no	
4th FL SOUTH	406	St SW	✓	✓	✓	✓	✓	no	
4th FL SOUTH	407	St SW	✓	✓	✓	✓	✓	no	
4th FL SOUTH	408	St SW	✓	✓	✓	✓	✓	no	
4th FL SOUTH	409	St SW	✓	✓	✓	✓	✓	no	
4th FL SOUTH	410	St SW	✓	✓	✓	✓	✓	no	
4th FL SOUTH	411	St SW	✓	✓	✓	✓	✓	no	
4th FL SOUTH	412	St SW	✓	✓	✓	✓	✓	no	press with switch
4th FL SOUTH	413	St SW	✓	✓	✓	✓	✓	no	0270
4th FL SOUTH	414	St SW	✓	✓	✓	✓	✓	no	
4th FL SOUTH	415	st SW	✓	✓	✓	✓	✓	no	
4th FL SOUTH	416	st SW	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE: 05/17/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
NORTH WING 8th AVE	SL1R1	In old	✓	✓	✓	✓	✓	NO	
NORTH WING 8th AVE	SL1R2	In old	✓	✓	✓	✓	✓	NO	
NORTH WING 8th AVE	SL1R3	In revolver	✓	✓	✓	✓	✓	NO	
NORTH WING 8th AVE	SL1R4	In revolver	✓	✓	✓	✓	✓	NO	
41st STREET	S13A1	St sw	✓	✓	✓	✓	✓	NO	
41st STREET	S13A2	St sw	✓	✓	✓	✓	✓	NO	
SOUTH WING 8TH AVE	S14A1A	Recess sw	✓	✓	✓	✓	✓	NO	
SOUTH WING 8TH AVE	S14A1B	Recess sw	✓	✓	✓	✓	✓	NO	
SOUTH WING 8TH AVE	S14A2A	Qt sw	✓	✓	✓	✓	✓	NO	
SOUTH WING 8TH AVE	S14A2B	Qt sw	✓	✓	✓	✓	✓	NO	
SOUTH WING 8TH AVE	S14A3A	Recess sw	✓	✓	✓	✓	✓	NO	
SOUTH WING 8TH AVE	S14A3B	Recess sw	✓	✓	✓	✓	✓	NO	
SOUTH WING 8TH AVE	S14A4A	Qt sw	✓	✓	✓	✓	✓	NO	
SOUTH WING 8TH AVE	S14A4B	Qt sw	✓	✓	✓	✓	✓	NO	

PA BUS TERMINAL DOOR MAINT CHECK LIST

5076

DATE: 05/21/19

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
DRTH WING 8TH AVE	N18A1A	DOOR SW	/	/	/	/	/		
DRTH WING 8TH AVE	N18A1B	DOOR SW	/	/	/	/	/		
DRTH WING 8TH AVE	N18A2A	DOOR SW	/	/	/	/	/		
DRTH WING 8TH AVE	N18A2B	DOOR SW	/	/	/	/	/		
DRTH WING 8TH AVE	N18A3A	DOOR SW	/	/	/	/	/		
DRTH WING 8TH AVE	N18A3B	DOOR SW	/	/	/	/	/		
DRTH WING 8TH AVE	N18A4A	DOOR SW	/	/	/	/	/		
DRTH WING 8TH AVE	N18A4B	DOOR SW	/	/	/	/	/		
[REDACTED SECTION]									
TAXI HD WAY	R17A05	DOOR SW	/	/	/	/	/		
TAXI HD WAY	R17A06	DOOR SW	/	/	/	/	/		

K. GREEN
 66085

DOOR AUTOMATION CORP

1800 ACCESS ROAD
 OCEANSIDE, NY 11572
 Phone (516) 678-4440 Fax (516) 887-7270

INVOICE

Date: 5/6/2014
 Invoice No: 13145

Bill to: PORT AUTHORITY BUS TERMINAL
 ATT: MAINTENANCE/BERNIE D'ALEO
 625 8TH AVE
 NEW YORK, NY 10018

Service at: PORT AUTHORITY BUS TERMINAL
 625 8TH AVENUE
 NY NY 10018

Reference: Work Order 17381
 PO Number:
 Terms:

Work Date DAC Tag# Door Description Work Performed
 4/21/2014

329 PM PERFORMED

Item	Work Date	Description	Quantity	Unit Price	Amount
------	-----------	-------------	----------	------------	--------

Labor

4/21/2014

Labor Subtotal 0.00

Miscellaneous

2ND APRIL PM

1.00 4,370.00 4,370.00

Miscellaneous Subtotal 4,370.00

Purchase Requisition #
~~4400 492319~~
 7/15/14-CK

OK by
 7/15/14

[Signature]
 7/20/14

Subtotal:	4,370.00
Sales Tax:	0.00

DOOR AUTOMATION CORP.

DATE: 1/14/14

CUSTOMER: Dus Terminal Pm

PO: _____

LOCATION: _____

TN: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
-------	------------	------	------	------	----------

J O B D E S C R I P T I O N

Dus Terminal Pm
work on door system as mentioned
3 times. 1 time and low level.

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative tot he Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: _____

TRUCK #: 210

ARRIVED HERE: _____

NO. OF MEN: 1

LEFT THIS JOB: _____

JOB COMPLETED: YES NO

MECHANICS

CUSTOMER'S SIGNATURE

PRINT NAME

DOOR AUTOMATION CORP.

DATE: 07/24/10

CUSTOMER: 800 ...

PO: _____

LOCATION: _____

TN: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
-------	------------	------	------	------	----------

J O B D E S C R I P T I O N

011 South wing ...

... door ...

... door ...

011 South wing 4103 ...

... door ...

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: _____ TRUCK #: 330

ARRIVED HERE: _____ NO. OF MEN: _____

LEFT THIS JOB: _____ JOB COMPLETED: YES NO

MECHANICS

CUSTOMER'S SIGNATURE

PRINT NAME

DOOR AUTOMATION CORP.

DATE: 2/1/80
 PO: _____
 TN: _____

CUSTOMER: RUS, Central Div
 LOCATION: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
03	North wing		311	slide	
310 must return with a new top track					
03	North wing		320	slide	
310 must return with a new top track					
03	North wing		326	slide	
310 must return with a new top track and slide block					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative tot he Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: _____ TRUCK #: _____

ARRIVED HERE: _____ NO. OF MEN: _____

LEFT THIS JOB: _____ JOB COMPLETED: YES NO

MECHANICS _____ CUSTOMER'S SIGNATURE _____ PRINT NAME _____

DOOR AUTOMATION CORP.

DATE: 04/08/14

PO: _____

TN: 17154

CUSTOMER: Bus terminal

LOCATION: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
tag # 04660					
LL	South wing			1 Stanley slider	
				#313 reprogram control	
				#370 replace both air guides	
tag # 04665	South wing				
LL				08 Stanley slider	
				#334 Replaced sensor (ext)	
				#336 TACO	
				#331 complete	
tag # 04647	South wing				
LL				11 Stanley slider	
				#330 Replaced sensor ext	
				#336 TACO	
				#331 complete	

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 0800
 ARRIVED HERE: 0800
 LEFT THIS JOB: 1200

TRUCK #: _____
 NO. OF MEN: 2
 JOB COMPLETED: YES NO

Charles
 MECHANICS

[Signature]
 CUSTOMER'S SIGNATURE

Jim Gunn
 PRINT NAME

DOOR AUTOMATION CORP.

DATE: 04/16/10

CUSTOMER: 330 must return

PO: _____

TN: _____

LOCATION: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
03	NORTH wing		311	Stanley	swing
DAC					
330 must return with a Arm Top Track and slide block					
03	NORTH wing		313	Stanley	swing
DAC					
330 must return with a Arm Top Track and slide block					
03	NORTH wing		320	Stanley	swing
DAC					
330 must return with a Arm Top Track and slide block					
03	NORTH wing		326	Stanley	swing
DAC					
330 must return with a Arm Top Track and slide block					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative tot he Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: _____ TRUCK #: _____

ARRIVED HERE: _____ NO. OF MEN: _____

LEFT THIS JOB: _____ JOB COMPLETED: YES NO

MECHANICS

CUSTOMER'S SIGNATURE

PRINT NAME

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE: 4/20/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	St old							
LOWER LEVEL SOUTH	3	St old							
LOWER LEVEL SOUTH	5	St old							
LOWER LEVEL SOUTH	7	St old							
LOWER LEVEL SOUTH	9	St old							
LOWER LEVEL SOUTH	11	St old							
LOWER LEVEL SOUTH	13	St old							
LOWER LEVEL SOUTH	15	St old							
LOWER LEVEL SOUTH	17	St old							
LOWER LEVEL SOUTH	19	St old							
LOWER LEVEL SOUTH	21	St old							
LOWER LEVEL SOUTH	23	St old							
LOWER LEVEL SOUTH	25	St old							
LOWER LEVEL SOUTH	27	St old							
LOWER LEVEL SOUTH	29	St old							
LOWER LEVEL SOUTH	31	St old							

PA BUS TERMINAL DOOR MAINT CHECK LIST

Juan

DATE: 4/28/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St sld							
LOWER LEVEL SOUTH	34	St sld							
LOWER LEVEL SOUTH	32	St sld							
LOWER LEVEL SOUTH	30	St sld							
LOWER LEVEL SOUTH	28	St sld							
LOWER LEVEL SOUTH	26	St sld							
LOWER LEVEL SOUTH	24	St sld							
LOWER LEVEL SOUTH	22	St sld							
LOWER LEVEL SOUTH	20	St sld							
LOWER LEVEL SOUTH	18	St sld							
LOWER LEVEL SOUTH	16	St sld							
LOWER LEVEL NORTH	60	St sld							
LOWER LEVEL NORTH	62	St sld							
LOWER LEVEL NORTH	62A	St sld							
LOWER LEVEL NORTH	63	St sld							
LOWER LEVEL NORTH	64	St sld							

03545

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE:

4/26/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	65	St sid							
LOWER LEVEL NORTH	66	St sid							
LOWER LEVEL NORTH	67	St sid							
LOWER LEVEL NORTH	68	St sid							
LOWER LEVEL NORTH	69	St sid							
LOWER LEVEL NORTH	70	St sid							
LOWER LEVEL NORTH	71	St sid							
LOWER LEVEL NORTH	71A	St sid							
LOWER LEVEL NORTH	72	St sid							
LOWER LEVEL NORTH	73	St sid							
LOWER LEVEL NORTH	74	St sid							
LOWER LEVEL NORTH	75	St sid							
LOWER LEVEL NORTH	75A	St sid							
LOWER LEVEL NORTH	76	St sid							
LOWER LEVEL NORTH	84A	St sid							
LOWER LEVEL NORTH	85	St sid							
<i>CL North</i>	<i>78</i>	<i>st sid</i>							

PA BUS TERMINAL DOOR MAINT CHECK LIST

Jeffer

DATE: 4/26/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	81	St sid							
LOWER LEVEL NORTH	82	St sid							
LOWER LEVEL NORTH	83	St sid							
LOWER LEVEL NORTH	84	St sid							
3rd FL NORTH	301	St sw							
3rd FL NORTH	302	St sw							<i>L/H Operator SUPERVISOR 04211</i>
3rd FL NORTH	303	St sw							
3rd FL NORTH	304	St sw							
3rd FL NORTH	305	St sw							
3rd FL NORTH	306	St sw							
3rd FL NORTH	307	St sw							
3rd FL NORTH	308	St sw							
3rd FL NORTH	309	St sw							

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE: 4/20/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	311	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	312	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	313	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	314	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	315	St sw	✓	✓	✓	✓	✓	TOP TRACK ^{yes} w/ block	04/20/14
3rd FL NORTH	316	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	317	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	318	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	319	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	320	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	321	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	322	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	323	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	324	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	325	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	326	St sw	✓	✓	✓	✓	✓		

PA BUS TERMINAL DOOR MAINT CHECK LIST

5 up

DATE: 7/14/2014

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	402	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	403	St sw	✓	✓	✓	✓	✓	no yes	03790
4th FL SOUTH	404	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	405	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	406	St sw	✓	✓	✓	✓	✓	yes	03216
4th FL SOUTH	407	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	408	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	409	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	410	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	411	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	412	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	413	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	414	St sw	✓	✓	✓	✓	✓	yes	03891
4th FL SOUTH	415	st sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	416	st sw	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUA

DATE: 4/26/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	417	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	418	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	419	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	420	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	421	St sw	✓	✓	✓	✓	✓	NO	
LOWER LEV SOUTH	14	ST SLD							
LOWER LEV SOUTH	12	ST SLD							
LOWER LEV SOUTH	10	ST SLD							
LOWER LEV SOUTH	8	ST SLD							
LOWER LEV SOUTH	6	ST SLD							
LOWER LEV SOUTH	4	ST SLD							
LOWER LEV SOUTH	2	ST SLD							
ROAD WAY EAST	SL1A1	BESAM SLD AMD 1							
ROAD WAY WEST	SL1A2	BESAM SLD AMD 1							

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE: *4/20/19*

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
OUTH WING 9th AVE	SL1R1	h sld							
OUTH WING 9th AVE	SL1R2	h sld							
OUTH WING 9th AVE	SL1R3	h revolver							
OUTH WING 9th AVE	SL1R4	h revolver							
41st STREET	S13A1	St sw							
41st STREET	S13A2	St sw							
OUTH WING 8TH AVE	S14A1A	Besam sw							
OUTH WING 8TH AVE	S14A1B	Besam sw							
OUTH WING 8TH AVE	S14A2A	Gt sw							
OUTH WING 8TH AVE	S14A2B	Gt sw							
OUTH WING 8TH AVE	S14A3A	Besam sw							
OUTH WING 8TH AVE	S14A3B	Besam sw							
OUTH WING 8TH AVE	S14A4A	Gt sw							
OUTH WING 8TH AVE	S14A4B	Gt sw							

DOOR AUTOMATION CORP

1800 ACCESS ROAD
 OCEANSIDE, NY 11572
 Phone (516) 678-4440 Fax (516) 887-7270

INVOICE

ate: 5/20/2014
 ervice No: 13247

Bill to: PORT AUTHORITY BUS TERMINAL
 ATT: MAINTENANCE/BERNIE D'ALEO
 625 8TH AVE
 NEW YORK, NY 10018

Service at: PORT AUTHORITY BUS TERMINAL
 625 8TH AVENUE
 NY NY 10018

Reference: Work Order 17382
 PO Number:
 Terms:

Work Date DAC Tag# Door Description Work Performed
 6/23/2014
 329 PM PERFORMED

item	work Date	Description	Quantity	Unit Price	Amount
------	-----------	-------------	----------	------------	--------

Labor

6/23/2014

Labor Subtotal 0.00

Miscellaneous

1ST MAY PM

1.00 4,370.00 4,370.00
 Miscellaneous Subtotal 4,370.00

Purchase Requisition #
 4400491306
 6/27/14 CR

OK Liz
 6/27/14
 u 7/2/14

Subtotal:	4,370.00
Sales Tax:	0.00
Total Due:	4,370.00

DOOR AUTOMATION CORP.

PM # 1

DATE: 5/1/82

PO: _____

TN: 17382

CUSTOMER: ABC Terminal
 LOCATION: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
Made PM on door at south wing					
Gate # 419 need roller top pivot					
416 11 11 11 Pivot					
413 need roller/switch					
410 need stanley arm track and slide block					
406 need stanley strut track and slide block					
Gate # 3 need inner out sensor (eagle)					
Gate # 22 11 set of optex safety beams					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative tot he Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 070
 ARRIVED HERE: 0900
 LEFT THIS JOB: 430
Charles
 MECHANICS

TRUCK #: _____
 NO. OF MEN: 1
 JOB COMPLETED: YES NO
 CUSTOMER'S SIGNATURE

PRINT NAME

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: 7/

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	402	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	403	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	404	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	405	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	406	St sw	✓	✓	✓	✓	✓	yes	need strut & slides
4th FL SOUTH	407	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	408	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	409	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	410	St sw	✓	✓	✓	✓	✓	yes	need travel block
4th FL SOUTH	411	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	412	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	413	St sw	✗	✓	✓	✓	✓	need p/wall switch	
4th FL SOUTH	414	St sw	✓	✓	✓	✓	✓		
4th FL SOUTH	415	st sw	✓	✓	✓	✓	✓		
4th FL SOUTH	416	st sw	✓	✓	✓	✓	✗	yes	need piston for pivot

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	417	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	418	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	419	St sw	✓	✓	✓	✓	X	need RIXSON for pivot ^{YES}	✓
4th FL SOUTH	420	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	421	St sw	✓	✓	✓	✓	✓	NO	
LOWER LEV SOUTH	14	ST SLD	✓	✓	✓	✓	✓	NO	
LOWER LEV SOUTH	12	ST SLD	✓	✓	✓	✓	✓	NO	
LOWER LEV SOUTH	10	ST SLD	✓	✓	✓	✓	✓	NO	
LOWER LEV SOUTH	8	ST SLD	✓	✓	✓	✓	✓	NO	
LOWER LEV SOUTH	6	ST SLD	✓	✓	✓	✓	✓	NO	
LOWER LEV SOUTH	4	ST SLD	✓	✓	✓	✓	✓	NO	
LOWER LEV SOUTH	2	ST SLD	✓	✓	✓	✓	✓	NO	
ROAD WAY EAST	SL1A1	BESAM SLD AMD 1	✓	✓	✓	✓	X	YES	need besam panic ^{atlc} ₂₁₇₆
ROAD WAY WEST	SL1A2	BESAM SLD AMD 1	✓	✓	✓	✓	✓		1

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	3	St sid	X	✓	✓	✓	✓	yes	need inner sensor
LOWER LEVEL SOUTH	5	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	7	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	9	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	11	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	13	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	15	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	17	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	19	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	21	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	23	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	25	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	27	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	29	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	31	St sid	✓	✓	✓	✓	✓	no	

5/4/14

PA BUS TERMINAL DOOR MAINT CHECK LIST

Charles

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	34	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	32	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	30	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	29	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	28	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	24	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	22	St ald	✓	✓	✓	✓	✓	YES	need to set after adjust
LOWER LEVEL SOUTH	20	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	18	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	16	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	60	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	62	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	62A	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	63	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	64	St ald	✓	✓	✓	✓	✓	NO	

03545

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE: 11/22/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	65	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	66	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	67	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	68	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	69	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	70	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	71	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	71A	St sid	✓	✓	✓	✓	X	yes	stouter need Park guide
LOWER LEVEL NORTH	72	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	73	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	74	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	75	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	75A	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	76	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	84A	St sid	⊙	⊙	⊙	⊙	⊙	yes	need to check counter
LOWER LEVEL NORTH	85	St sid	✓	✓	✓	✓	✓	no	
C-L North	88	St sid	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	81	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	82	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	83	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	84	St sid	✓	✓	✓	✓	✓	no	
3rd FL NORTH	301	St sw	✓	✓	✓	✓	✓	yes	need slide block
3rd FL NORTH	302	St sw	⊙	⊙	⊙	⊙	⊙	need to replace control	
3rd FL NORTH	303	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	304	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	305	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	306	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	307	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	308	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	309	St sw	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL, DOOR MAINT CHECK LIST

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	311	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	312	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	313	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	314	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	315	St sw	✓	✓	✓	✓	✓	yes	stanley need arm track
3rd FL NORTH	316	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	317	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	318	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	319	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	320	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	321	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	322	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	323	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	324	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	325	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	326	St sw	✓	✓	✓	✓	✓	yes	need slide block

PA BUS TERMINAL DOOR MAINT CHECK LIST

Charles

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
SOUTH WING 9th AVE	SL1R1	h sld	✓	✓	✓	✓	✓	NO	
SOUTH WING 9th AVE	SL1R2	h sld	✓	✓	✓	✓	✓	NO	
SOUTH WING 9th AVE	SL1R3	h revolver	✓	✓	✓	✓	✓	NO	
SOUTH WING 9th AVE	SL1R4	h revolver	✓	✓	✓	✓	✓	AC	
41st STREET	S13A1	St sw							
41st STREET	S13A2	St sw							
SOUTH WING 8TH AVE	S14A1A	Besam sw	✓	✓	✓	✓	✓		
SOUTH WING 8TH AVE	S14A1B	Besam sw	✓	✓	✓	✓	✓		
SOUTH WING 8TH AVE	S14A2A	Gt sw	✓	✓	✓	✓	✓		
SOUTH WING 8TH AVE	S14A2B	Gt sw <i>Record</i>	✓	✓	✓	✓	✓		
SOUTH WING 8TH AVE	S14A3A	Besam sw	✓	✓	✓	✓	✓		
SOUTH WING 8TH AVE	S14A3B	Besam sw <i>Gt</i>	✓	✓	✓	✓	✓		
SOUTH WING 8TH AVE	S14A4A	Gt sw	✓	✓	✓	✓	✓		
SOUTH WING 8TH AVE	S14A4B	Gt sw	✓	✓	✓	✓	✓		

DOOR AUTOMATION CORP

1800 ACCESS ROAD
 OCEANSIDE, NY 11572
 Phone (516) 678-4440 Fax (516) 887-7270

INVOICE

Date: 4/28/2014
 Invoice No: 13128

Bill to: PORT AUTHORITY BUS TERMINAL
 ATT: MAINTENANCE/BERNIE D'ALEO
 625 8TH AVE
 NEW YORK, NY 10018

Service at: PORT AUTHORITY BUS TERMINAL
 625 8TH AVENUE
 NY NY 10018

Reference: Work Order 17271
 PO Number:
 Terms:

Work Date DAC Tag# Door Description
 4/9/2014

Work Performed

329 PM PERFORMED

Item	Work Date	Description	Quantity	Unit Price	Amount
Labor	4/9/2014				
Labor Subtotal					0.00
Miscellaneous	1ST APRIL PM		1.00	4,370.00	4,370.00
Miscellaneous Subtotal					4,370.00

Purchase Requisition #
~~4400490580~~
 6/18/14 - CR
 6/23/14 - CR

OK
 B D
 4/18/14

Subtotal:	4,370.00
Sales Tax:	0.00
Total Due:	4,370.00

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	34	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	32	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	30	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	28	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	26	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	24	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	22	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	20	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	18	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	16	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	60	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	62	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	62A	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	63	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	64	St sld							TOP wheels 2

03545

04250

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE: 11/22/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	65	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	66	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	67	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	68	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	69	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	70	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	71	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	71A	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	72	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	73	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	74	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	75	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	75A	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	76	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	84A	St sid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	85	St sid	✓	✓	✓	✓	✓	no	
C.L North	88	St sid	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	81	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	82	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	83	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	84	St old	✓	✓	✓	✓	✓	no	
3rd FL NORTH	301	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	302	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	303	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	304	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	305	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	306	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	307	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	308	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	309	St sw	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	311	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	312	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	313	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	314	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	315	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	316	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	317	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	318	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	319	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	320	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	321	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	322	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	323	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	324	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	325	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	326	St sw	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: 7/

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	402	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	403	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	404	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	405	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	406	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	407	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	408	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	409	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	410	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	411	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	412	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	413	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	414	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	415	st sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	416	st sw	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	417	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	418	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	419	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	420	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	421	St sw	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	14	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	12	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	10	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	8	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	6	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	4	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	2	ST SLD	✓	✓	✓	✓	✓	no	
ROAD WAY EAST	SL1A1	BESAM SLD AMD 1	✓	✓	✓	✓	✓	no	
ROAD WAY WEST	SL1A2	BESAM SLD AMD 1	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
OUTH WING 9th AVE	SL1R1	h sld	✓	✓	✓	✓	✓	no	
OUTH WING 9th AVE	SL1R2	h sld	✓	✓	✓	✓	✓	no	
OUTH WING 9th AVE	SL1R3	h revolver	✓	✓	✓	✓	✓	no	
OUTH WING 9th AVE	SL1R4	h revolver	✓	✓	✓	✓	✓	no	
41st STREET	S13A1	St sw	✓	✓	✓	✓	✓	no	
41st STREET	S13A2	St sw	✓	✓	✓	✓	✓	no	
OUTH WING 8TH AVE	S14A1A	Besam sw	✓	✓	✓	✓	✓	no	
OUTH WING 8TH AVE	S14A1B	Besam sw	✓	✓	✓	✓	✓	no	
OUTH WING 8TH AVE	S14A2A	Gt sw	✓	✓	✓	✓	✓	no	
OUTH WING 8TH AVE	S14A2B	Gt sw	✓	✓	✓	✓	✓	no	
OUTH WING 8TH AVE	S14A3A	Besam sw	✓	✓	✓	✓	✓	no	
OUTH WING 8TH AVE	S14A3B	Besam sw	✓	✓	✓	✓	✓	no	
OUTH WING 8TH AVE	S14A4A	Gt sw	✓	✓	✓	✓	✓	no	
OUTH WING 8TH AVE	S14A4B	Gt sw	✓	✓	✓	✓	✓	no	

DOOR AUTOMATION CORP.

DATE: 04/08/14
 PO: _____
 TN: 17152

CUSTOMER: _____
 LOCATION: Bus terminal

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
tag # <u>03562</u> JOB DESCRIPTION					
<u>03</u>	<u>north wing</u>	<u>311</u>	<u>Stanley</u>		
<u>#315 reprogram control</u>					
<u>#246 secure wire harness</u>					
<u>#246 TACO</u>					

tag # _____					
<u>03</u>	<u>north wing</u>	<u>313</u>	<u>Stanley</u>		
<u># Temp. repair</u>					
<u>#499 must return with parts</u>					

tag # _____					
<u>03</u>	<u>north wing</u>	<u>321</u>	<u>Stanley</u>		
<u>#399 secure door arm</u>					
<u>#389 replace ext P/W/switch</u>					

tag # <u>04242</u>					
<u>03</u>	<u>north wing</u>	<u>326</u>	<u>Stanley</u>		
<u>#300 made temp. repair</u>					
<u>#499 must return with parts</u>					
<u>#306 TACO</u>					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: _____
 ARRIVED HERE: 100
 LEFT THIS JOB: 400

TRUCK #: _____
 NO. OF MEN: 1
 JOB COMPLETED: YES NO

Charles
 MECHANICS

[Signature]
 CUSTOMER'S SIGNATURE

PRINT NAME

DOOR AUTOMATION CORPORATION

DATE: _____

CUSTOMER: _____

PO: _____

LOCATION: _____

TN: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
03
		#		reprogram control	
		#		secure wire harness	
		#		TRAV	
03
		#		TRAV repair	
		#		Must return with parts	
03
		#		secure wire harness	
		#		replace P/S/valve	
03
		#		with truck repair	
		#		Must return with parts	
		#		32 Traps	

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: _____
 ARRIVED HERE: _____
 LEFT THIS JOB: _____

TRUCK #: _____
 NO. OF MEN: _____
 JOB COMPLETED: YES NO

MECHANICS

CUSTOMER'S SIGNATURE

PRINT NAME

DOOR AUTOMATION CORPORATION

DATE: 04/21/14

CUSTOMER: U.S. VETERANS

PO: _____

TN: 17771

LOCATION: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
01 main entrance 55 wing S14A36 besam swing DAC 01867					
395 Replaced L/H Arm with Track					
106 Resecure door OPERATOR					
315 RESET and Replenish control					
330 MUST RETURN TO Resecure Arm					
01 main exit swing S14A46 GET swing DAC 07733					
709 Resecure door PORT					
316 TACO door is working OK					
03 north wing 321 Stanley swing -DAC 04240					
394 Replaced OUTSIDE PICKS well switch					
311 TACO door is working OK					
04 south wing 414 Stanley swing DAC 03491					
Resecure Picks well switch					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 11:45

TRUCK #: 310

ARRIVED HERE: 12:45

NO. OF MEN: 1

LEFT THIS JOB: 5:00

JOB COMPLETED: YES NO

John

MECHANICS

[Signature]

CUSTOMER'S SIGNATURE

P. S. [Signature]

PRINT NAME

DOOR AUTOMATION CORP.

DATE: 04/23/11

CUSTOMER: Bus Terminal

PO: _____

LOCATION: _____

TN: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
					03 Stanley slider
					330 must return with a new sensor
					15 Stanley slider
					330 must return with a new Breakout way switch
					64 Stanley slider
					775 Replaced Top wheels
					715 reset and reprogram control
					786 TACO Door is working OK

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentation by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 11:30
 ARRIVED HERE: 17:30
 LEFT THIS JOB: 4:00

TRUCK #: 300
 NO. OF MEN: 1
 JOB COMPLETED: YES NO

[Signature]
 MECHANICS

[Signature]
 CUSTOMER'S SIGNATURE

[Signature] 4:0
 PRINT NAME

DOOR AUTOMATION CORP

1800 ACCESS ROAD
 OCEANSIDE, NY 11572
 Phone (516) 678-4440 Fax (516) 887-7270

INVOICE

Date: 4/1/2014
 Invoice No: 12886

Bill to: PORT AUTHORITY BUS TERMINAL
 ATT: MAINTENANCE/BERNIE D'ALEO
 625 8TH AVE
 NEW YORK, NY 10018

Service at: PORT AUTHORITY BUS TERMINAL
 625 8TH AVENUE
 NY NY 10018

Purchase Requisition #
~~4400488468~~
 5/22/14 - CR
 @ 5/23/14

Reference: Work Order 16712
 PO Number:
 Terms:

Work Date DAC Tag# Door Description Work Performed

Item	Work Date	Description	Quantity	Unit Price	Amount
Labor					
	3/5/2014				
Labor Subtotal					0.00
Miscellaneous					
	1ST MARCH PM		1.00	4,370.00	4,370.00
Miscellaneous Subtotal					4,370.00

OK
 BR
 5/19/14

Subtotal:	4,370.00
Sales Tax:	0.00
Total Due:	4,370.00

DOOR AUTOMATION CORP.

DATE: 03/05/14

CUSTOMER: Bus Terminal - m Repair

PO: _____

LOCATION: _____

TN: 16780

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
04	South wing	(401)	Stanley	swing	
DAC 03560					
344 Replaced outer press wall switch					
326 Taco Door is working OK					
03	North wing	(304)	Stanley	swing	
DAC 04243					
343 Replaced inner press wall switch					
316 Taco Door is working OK					
03	North wing	(306)	Stanley	swing	
DAC 01309					
344 Replaced outer press wall switch					
310 Taco Door is working OK					
03	North wing	(311)	Stanley	swing	
DAC 03562					
315 Replaced inner press wall switch					
315 Replaced and reprogram control					
310 Taco door is working OK					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 10:00

TRUCK #: 320

ARRIVED HERE: 11:00

NO. OF MEN: 1

LEFT THIS JOB: 7:00

JOB COMPLETED: YES NO

304
MECHANICS

[Signature]
CUSTOMER'S SIGNATURE

P. S. Allen
PRINT NAME

PROOF OF WORK PERFORMED

DATE: 03/01/04

CUSTOMER: B. J. ...

PO: _____

LOCATION: _____

TN: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
011	20th wing	101		STAIR	...
DAG 0-10					
This door is working ok					
011	20th wing	111		STAIR	...
DAG 0-10					
This door is working ok					
011	20th wing	121		STAIR	...
DAG 0-10					
This door is working ok					
011	20th wing	131		STAIR	...
DAG 0-10					
This door is working ok					
011	20th wing	141		STAIR	...
DAG 0-10					
This door is working ok					
011	20th wing	151		STAIR	...
DAG 0-10					
This door is working ok					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 10:00
 ARRIVED HERE: 11:00
 LEFT THIS JOB: 1:00

 MECHANICS

TRUCK #: 100
 NO. OF MEN: 1
 JOB COMPLETED: YES NO

 CUSTOMER'S SIGNATURE

_____ ...
 PRINT NAME

DOOR AUTOMATION CORP.

DATE: 03/08/14

CUSTOMER: Bus Terminal Pm (1)

PO: _____

LOCATION: _____

TN: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
LL	North wing		7A	Stanley slide	
DAC 04268					
330 must return with a two top wheels to complete					
O1	North wing			inner entrance	Revised swing
DAC 04485					
330 must return with a better flash bolt					
Performed Pm					
O1	North wing			N10A4B	GT swing
DAC 01326					
326 face measure and adjust bottom sweep					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative tot he Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 130

TRUCK #: 310

ARRIVED HERE: 7:30

NO. OF MEN: 1

LEFT THIS JOB: 6:00

JOB COMPLETED: YES NO

Sean
MECHANICS

Richard Oakes
CUSTOMER'S SIGNATURE

Richard Oakes
PRINT NAME

DOOR AUTOMATION CORPORATION

DATE: 12/22/11

CUSTOMER: Pro, ...

PO: _____

LOCATION: _____

TN: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
11	North Wing		71	Door	
3:00 must get door with two					
for who to see					
11	North Wing	8 th	101	Door	
3:00 must get door with two					
for who to see					
1	North Wing	4 th	110	Door	
3:00 must get door with two					
for who to see					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: _____

TRUCK #: _____

ARRIVED HERE: _____

NO. OF MEN: _____

LEFT THIS JOB: _____

JOB COMPLETED: YES NO

John
MECHANICS

[Signature]
CUSTOMER'S SIGNATURE

W. L. O. K. S.
PRINT NAME

DOOR AUTOMATION CORP.

DATE: 3-11-14

CUSTOMER: 305 Lexington

PO: _____

LOCATION: NY NY

TN: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
3	North wing	# 301	Stanley	Curly	01352
	No problem found.				
3	North wing	# 313	Stanley	Swiss	08350
	Must return with Stanley Button pivot to complete job.				
3	North wing	# 314	Stanley	Swiss	08512
	Received extension push plate.				
1	South wing	8th Ave - 14A 4A	67	Swiss	09956
	No problem found.				
4	South wing	# 400	Gate	Stanley/Swiss	03216
	No problem found.				

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 10:30
 ARRIVED HERE: 11:30
 LEFT THIS JOB: 3:00

TRUCK #: 314
 NO. OF MEN: 1
 JOB COMPLETED: YES NO

Beso
 MECHANICS

Ruehan
 CUSTOMER'S SIGNATURE

Eric Swartz
 PRINT NAME

DOOR AUTOMATION CORPORATION

DATE: 7-15-10

CUSTOMER: Bus Maintenance

PO: _____

LOCATION: NY NJ

TN: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
2	North wing	# 301	entry door		0155Z
	no problem	found			
3	North wing	# 313	entry door		0335Z
	issue with	door			
	pivot to	complete			
3	North wing	# 314	entry door		0355Z
	problem	door			
1	North wing	# 14A	door		
	no problem	found			
4	South wing	# 405	entry door		0330Z
	no problem	found			

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative tot he Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 10:30
 ARRIVED HERE: 11:30
 LEFT THIS JOB: 6:00
 MECHANICS

TRUCK #: 514
 NO. OF MEN: 1
 JOB COMPLETED: YES NO
 CUSTOMER'S SIGNATURE



PRINT NAME

PA BUS TERMINAL DOOR MAINT CHECK LIST

Sum

DATE: *03/08/14*

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	St old	/	/	/	/	/		
LOWER LEVEL SOUTH	3	St old	/	/	/	/	/		
LOWER LEVEL SOUTH	5	St old	/	/	/	/	/		
LOWER LEVEL SOUTH	7	St old	/	/	/	/	/		
LOWER LEVEL SOUTH	9	St old	/	/	/	/	/		
LOWER LEVEL SOUTH	11	St old	/	/	/	/	/		
LOWER LEVEL SOUTH	13	St old	/	/	/	/	/		
LOWER LEVEL SOUTH	15	St old	/	/	/	/	/		
LOWER LEVEL SOUTH	17	St old	/	/	/	/	/		
LOWER LEVEL SOUTH	19	St old	/	/	/	/	/		
LOWER LEVEL SOUTH	21	St old	/	/	/	/	/		
LOWER LEVEL SOUTH	23	St old	/	/	/	/	/		
LOWER LEVEL SOUTH	25	St old	/	/	/	/	/		
LOWER LEVEL SOUTH	27	St old	/	/	/	/	/		
LOWER LEVEL SOUTH	29	St old	/	/	/	/	/		
LOWER LEVEL SOUTH	31	St old	/	/	/	/	/		



PA BUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE: 03/08/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	34	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	32	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	30	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	28	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	28	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	24	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	22	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	20	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	18	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	16	St sld	/	/	/	/	/		
03545									
LOWER LEVEL NORTH	60	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	62	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	62A	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	63	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	64	St sld	/	/	/	/	/		

PA BUS TERMINAL DOOR MAINT CHECK LIST

Jvan

DATE: ~~11/27/13~~ 3/08/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	65	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	66	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	67	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	68	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	69	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	70	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	71	St sld	/	/	/	/	/	yes	Top wheels 04268
LOWER LEVEL NORTH	71A	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	72	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	73	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	74	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	75	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	75A	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	76	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	84A	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	85	St sld	/	/	/	/	/		
<i>L-L North</i>	<i>78</i>	<i>St sld</i>	/	/	/	/	/		

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUN.

DATE: 03/08/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	81	St old	/	/	/	/	/		
LOWER LEVEL NORTH	82	St old	/	/	/	/	/		
LOWER LEVEL NORTH	83	St old	/	/	/	/	/		
LOWER LEVEL NORTH	84	St old	/	/	/	/	/		
[REDACTED SECTION]									
3rd FL NORTH	301	St sw	/	/	/	/	/		
3rd FL NORTH	302	St sw	/	/	/	/	/		
3rd FL NORTH	303	St sw	/	/	/	/	/		
3rd FL NORTH	304	St sw	/	/	/	/	/		
3rd FL NORTH	305	St sw	/	/	/	/	/		
3rd FL NORTH	306	St sw	/	/	/	/	/		
3rd FL NORTH	307	St sw	/	/	/	/	/		
3rd FL NORTH	308	St sw	/	/	/	/	/		
3rd FL NORTH	309	St sw	/	/	/	/	/		

PA BUS TERMINAL DOOR MAINT CHECK LIST JCM

DATE: 03/08/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	311	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	312	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	313	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	314	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	315	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	316	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	317	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	318	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	319	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	320	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	321	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	322	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	323	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	324	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	325	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	326	St sw	✓	✓	✓	✓	✓		

PA BUS TERMINAL DOOR MAINT CHECK LIST

John

DATE: *7/03/08/19*

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St sw	/	/	/	/	/		
4th FL SOUTH	402	St sw	/	/	/	/	/		
4th FL SOUTH	403	St sw	/	/	/	/	/		
4th FL SOUTH	404	St sw	/	/	/	/	/		
4th FL SOUTH	405	St sw	/	/	/	/	/		
4th FL SOUTH	406	St sw	/	/	/	/	/		
4th FL SOUTH	407	St sw	/	/	/	/	/		
4th FL SOUTH	408	St sw	/	/	/	/	/		
4th FL SOUTH	409	St sw	/	/	/	/	/		
4th FL SOUTH	410	St sw	/	/	/	/	/		
4th FL SOUTH	411	St sw	/	/	/	/	/		
4th FL SOUTH	412	St sw	/	/	/	/	/		
4th FL SOUTH	413	St sw	/	/	/	/	/		
4th FL SOUTH	414	St sw	/	/	/	/	/		
4th FL SOUTH	415	st sw	/	/	/	/	/		
4th FL SOUTH	416	st sw	/	/	/	/	/		

PA BUS TERMINAL DOOR MAINT CHECK LIST

5/1/14

DATE: *10/3/08/14*

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	417	St sw	/	/	/	/	/		
4th FL SOUTH	418	St sw	/	/	/	/	/		
4th FL SOUTH	419	St sw	/	/	/	/	/		
4th FL SOUTH	420	St sw	/	/	/	/	/		
4th FL SOUTH	421	St sw	/	/	/	/	/		
LOWER LEV SOUTH	14	ST SLD	/	/	/	/	/		
LOWER LEV SOUTH	12	ST SLD	/	/	/	/	/		
LOWER LEV SOUTH	10	ST SLD	/	/	/	/	/		
LOWER LEV SOUTH	8	ST SLD	/	/	/	/	/		
LOWER LEV SOUTH	6	ST SLD	/	/	/	/	/		
LOWER LEV SOUTH	4	ST SLD	/	/	/	/	/		
LOWER LEV SOUTH	2	ST SLD	/	/	/	/	/		
ROAD WAY EAST	SL1A1	BESAM SLD AMD 1	/	/	/	/	/		
ROAD WAY WEST	SL1A2	BESAM SLD AMD 1	/	/	/	/	/		

DOOR AUTOMATION CORP

2/23

1800 ACCESS ROAD
 OCEANSIDE, NY 11572
 Phone (516) 678-4440 Fax (516) 887-7270

INVOICE

Date: 3/10/2014
 Invoice No: 12666

Bill to: PORT AUTHORITY BUS TERMINAL
 ATT: MAINTENANCE/BERNIE D'ALEO
 625 8TH AVE
 NEW YORK, NY 10018

Service at: PORT AUTHORITY BUS TERMINAL
 625 8TH AVENUE
 NY NY 10018

Reference: Work Order 17229
 PO Number:
 Terms:

Purchase Requisition #
~~4400486217~~
 4/24/14 CR
 @ 4/29/14

Work Date DAC Tag# Door Description Work Performed

Item	Work Date	Description	Quantity	Unit Price	Amount
Labor	2/24/2014				
Labor Subtotal					0.00
Miscellaneous	2ND FEBRUARY PM		1.00	4,370.00	4,370.00
Miscellaneous Subtotal					4,370.00

OK
 BD
 4/29/14

Subtotal:	4,370.00
Sales Tax:	0.00
Total Due:	4,370.00

DOOR AUTOMATION CORP.

DATE: 02/23/11

CUSTOMER: W. J. ...

PO: 1

LOCATION:

TN: 1415

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
04	SOUTH wing	401	Stanley	swing	
D.A.C. 03560					
330 must return with a outlet press wall switch					
04	NORTH wing	403	Stanley	swing	
D.A.C. 02148					
330 must return with a outlet					
03	NORTH wing	304	Stanley	swing	
D.A.C. 04273					
330 must return with a inlet P.W.S.					
03	NORTH wing	306	Stanley	swing	
D.A.C. 01309					
330 must return with a outlet press wall switch					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative tot he Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 9:00

TRUCK #: 300

ARRIVED HERE: 10:00

NO. OF MEN: 1

LEFT THIS JOB: 3:30

JOB COMPLETED: YES NO

MECHANICS

CUSTOMER'S SIGNATURE

PRINT NAME

PA BUS TERMINAL DOOR MAINT CHECK LIST

Sehr

DATE: *02/25/14*

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	St sld	/	/	/	/	/	no	
LOWER LEVEL SOUTH	3	St sld	/	/	/	/	/	no	
LOWER LEVEL SOUTH	5	St sld	/	/	/	/	/	no	
LOWER LEVEL SOUTH	7	St sld	/	/	/	/	/	no	
LOWER LEVEL SOUTH	9	St sld	/	/	/	/	/	no	
LOWER LEVEL SOUTH	11	St sld	/	/	/	/	/	no	
LOWER LEVEL SOUTH	13	St sld	/	/	/	/	/	no	
LOWER LEVEL SOUTH	15	St sld	/	/	/	/	/	no	
LOWER LEVEL SOUTH	17	St sld	/	/	/	/	/	no	
LOWER LEVEL SOUTH	19	St sld	/	/	/	/	/	no	
LOWER LEVEL SOUTH	21	St sld	/	/	/	/	/	no	
LOWER LEVEL SOUTH	23	St sld	/	/	/	/	/	no	
LOWER LEVEL SOUTH	25	St sld	/	/	/	/	/	no	
LOWER LEVEL SOUTH	27	St sld	/	/	/	/	/	no	
LOWER LEVEL SOUTH	29	St sld	/	/	/	/	/	no	
LOWER LEVEL SOUTH	31	St sld	/	/	/	/	/	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	34	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	32	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	30	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	28	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	26	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	24	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	22	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	20	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	18	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	16	St old	/	/	/	/	/	no	
03545									
LOWER LEVEL NORTH	60	St old	/	/	/	/	/	no	
LOWER LEVEL NORTH	62	St old	/	/	/	/	/	no	
LOWER LEVEL NORTH	62A	St old	/	/	/	/	/	no	
LOWER LEVEL NORTH	63	St old	/	/	/	/	/	no	
LOWER LEVEL NORTH	64	St old	/	/	/	/	/	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

Juan

DATE: *11/22/13*

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	85	St slid							
LOWER LEVEL NORTH	86	St slid							
LOWER LEVEL NORTH	87	St slid							
LOWER LEVEL NORTH	88	St slid							
LOWER LEVEL NORTH	89	St slid							
LOWER LEVEL NORTH	70	St slid							
LOWER LEVEL NORTH	71	St slid							
LOWER LEVEL NORTH	71A	St slid							
LOWER LEVEL NORTH	72	St slid							
LOWER LEVEL NORTH	73	St slid						<i>yes</i>	<i>control 02448</i>
LOWER LEVEL NORTH	74	St slid							
LOWER LEVEL NORTH	75	St slid							
LOWER LEVEL NORTH	75A	St slid							
LOWER LEVEL NORTH	76	St slid							
LOWER LEVEL NORTH	84A	St slid							
LOWER LEVEL NORTH	85	St slid							
<i>C-L North</i>	<i>78</i>	<i>st slid</i>							

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	81	St old							
LOWER LEVEL NORTH	82	St old							
LOWER LEVEL NORTH	83	St old							
LOWER LEVEL NORTH	84	St old							
[REDACTED SECTION]									
3rd FL NORTH	301	St sw							
3rd FL NORTH	302	St sw							
3rd FL NORTH	303	St sw							
3rd FL NORTH	304	St sw						YES inner PWS	04243
3rd FL NORTH	305	St sw							
3rd FL NORTH	306	St sw						YES outer PWS	01309
3rd FL NORTH	307	St sw							
3rd FL NORTH	308	St sw							
3rd FL NORTH	309	St sw							

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	St sw							
3rd FL NORTH	311	St sw							03563
3rd FL NORTH	312	St sw							
3rd FL NORTH	313	St sw							
3rd FL NORTH	314	St sw							
3rd FL NORTH	315	St sw							
3rd FL NORTH	316	St sw							
3rd FL NORTH	317	St sw							
3rd FL NORTH	318	St sw							
3rd FL NORTH	319	St sw							
3rd FL NORTH	320	St sw							
3rd FL NORTH	321	St sw							
3rd FL NORTH	322	St sw							
3rd FL NORTH	323	St sw							
3rd FL NORTH	324	St sw							
3rd FL NORTH	325	St sw							
3rd FL NORTH	328	St sw							

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: 7/

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St sw						205 PWS out	03560
4th FL SOUTH	402	St sw							
4th FL SOUTH	403	St sw							
4th FL SOUTH	404	St sw							
4th FL SOUTH	405	St sw							
4th FL SOUTH	406	St sw							
4th FL SOUTH	407	St sw							
4th FL SOUTH	408	St sw							
4th FL SOUTH	409	St sw							
4th FL SOUTH	410	St sw							
4th FL SOUTH	411	St sw							
4th FL SOUTH	412	St sw							
4th FL SOUTH	413	St sw							
4th FL SOUTH	414	St sw							
4th FL SOUTH	415	st sw							
4th FL SOUTH	416	st sw							

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	417	St sw							
4th FL SOUTH	418	St sw							
4th FL SOUTH	419	St sw							
4th FL SOUTH	420	St sw							
4th FL SOUTH	421	St sw							
LOWER LEV SOUTH	14	ST SLD							
LOWER LEV SOUTH	12	ST SLD							
LOWER LEV SOUTH	10	ST SLD							
LOWER LEV SOUTH	8	ST SLD							
LOWER LEV SOUTH	6	ST SLD							
LOWER LEV SOUTH	4	ST SLD							
LOWER LEV SOUTH	2	ST SLD							
ROAD WAY EAST	SL1A1	BESAM SLD AMD 1							
ROAD WAY WEST	SL1A2	BESAM SLD AMD 1							

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
OUTH WING 9th AVE	SL1R1	h sld							
OUTH WING 9th AVE	SL1R2	h sld							
OUTH WING 9th AVE	SL1R3	h revolver							
OUTH WING 9th AVE	SL1R4	h revolver							
41st STREET	S13A1	St sw							
41st STREET	S13A2	St sw							
OUTH WING 8TH AVE	S14A1A	Besam sw							
OUTH WING 8TH AVE	S14A1B	Besam sw							
OUTH WING 8TH AVE	S14A2A	Gt sw							
OUTH WING 8TH AVE	S14A2B	Gt sw							
OUTH WING 8TH AVE	S14A3A	Besam sw							
OUTH WING 8TH AVE	S14A3B	Besam sw							
OUTH WING 8TH AVE	S14A4A	Gt sw							
OUTH WING 8TH AVE	S14A4B	Gt sw							

DOOR AUTOMATION CORP

2/17

1800 ACCESS ROAD
OCEANSIDE, NY 11572
Phone (516) 678-4440 Fax (516) 887-7270

INVOICE

Date: 3/10/2014
Invoice No: 12665

Bill to: PORT AUTHORITY BUS TERMINAL
ATT: MAINTENANCE/BERNIE D'ALEO
625 8TH AVE
NEW YORK, NY 10018

Service at: PORT AUTHORITY BUS TERMINAL
625 8TH AVENUE
NY NY 10018

Reference: Work Order 16553
PO Number:
Terms:

Work Date 2/11/2014
DAC Tag#
Door Description

Work Performed

Purchase Requisition #
~~4400486276~~
4/24/14 - CR
@ 4/29/14

Item	Work Date	Description	Quantity	Unit Price	Amount
------	-----------	-------------	----------	------------	--------

Labor
2/11/2014

Labor Subtotal	0.00
----------------	------

Miscellaneous
1ST FEBRUARY PM

1.00	4,370.00	4,370.00
Miscellaneous Subtotal	4,370.00	

OK BD
4/24/14

Subtotal:	4,370.00
Sales Tax:	0.00
Total Due:	4,370.00

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE: 2/11/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	3	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	5	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	7	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	9	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	11	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	13	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	15	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	17	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	19	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	21	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	23	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	25	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	27	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	29	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	31	St sld	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

JexAn

DATE: 2/11/15

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	34	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	32	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	30	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	28	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	26	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	24	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	22	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	20	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	18	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	16	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	60	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	62	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	62A	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	63	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	64	St sld	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

SUN

DATE: 2/11/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	65	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	66	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	67	St sld							
LOWER LEVEL NORTH	68	St sld	✓	✓	✓	✓	✓	no	yes 1/4 PSI Guide
LOWER LEVEL NORTH	69	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	70	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	71	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	71A	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	72	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	73	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	74	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	75	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	75A	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	76	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	84A	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	85	St sld	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

SWAN

DATE: *2/11/14*

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	311	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	312	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	313	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	314	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	315	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	316	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	317	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	318	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	319	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	320	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	321	St sw	✓	✓	✓	✓	✓	no	yes secure ^{Arm} track
3rd FL NORTH	322	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	323	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	324	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	325	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	326	St sw	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUN

DATE: 2/11/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	402	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	403	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	404	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	405	St sw						yes N/W FIX replaced control	
4th FL SOUTH	406	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	407	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	408	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	409	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	410	St sw						yes N/W must return with	with motor for
4th FL SOUTH	411	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	412	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	413	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	414	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	415	st sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	416	st sw	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

Sum

DATE: *2/19/14*

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	417	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	418	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	419	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	420	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	421	St sw	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	14	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	12	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	10	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	8	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	6	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	4	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	2	ST SLD	✓	✓	✓	✓	✓	no	
ROAD WAY EAST	SL1A1	BESAM SLD AMD 1	✓	✓	✓	✓	✓	no	
ROAD WAY WEST	SL1A2	BESAM SLD AMD 1	✓	✓	✓	✓	✓	no	

DOOR AUTOMATION CORP.

1800 ACCESS ROAD
 OCEANSIDE, NY 11572
 Phone (516) 678-4440 Fax (516) 887-7270

INVOICE

Date: 2/17/2014
 Invoice No: 12199

Bill to: PORT AUTHORITY BUS TERMINAL
 ATT: MAINTENANCE/BERNIE D'ALEO
 625 8TH AVE
 NEW YORK, NY 10018

Service at: PORT AUTHORITY BUS TERMINAL
 625 8TH AVENUE
 NY NY 10018

Reference: Work Order 16401
 PO Number:
 Terms:

Work Date DAC Tag# Door Description Work Performed

Item	Work Date	Description	Quantity	Unit Price	Amount
Miscellaneous	2ND JANUARY PM		1.00	4,370.00	4,370.00
Miscellaneous Subtotal					4,370.00

Purchase Requisition #
~~4400482825~~
 3/14/14 CR OK
 BW
 3/6/14

ck in SAP
 Hector Equi
 3/17/14

Subtotal:	4,370.00
Sales Tax:	0.00
Total Due:	4,370.00

DOOR AUTOMATION CORP.

DATE: 01/31/14

CUSTOMER: Bus Terminal Pm

PO: _____

LOCATION: 4

TN: 16401

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
<i>Cancelled</i>					
01	South wing	940	01	Besom	Slide
DAC 01384 see TV-162505					
330 call for 330 Post already					
"					
01	South wing	940	01	Rescue	How Form
DAC 01528					
330 must return door are not working see					
<i>OK</i>					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 7:00 TRUCK #: 320
 ARRIVED HERE: 8:00 NO. OF MEN: _____
 LEFT THIS JOB: 3:00 JOB COMPLETED: YES NO

John MECHANICS CUSTOMER'S SIGNATURE PRINT NAME

DOOR AUTOMATION CORP.

DATE: 13014
 PO: _____
 TN: 11269

CUSTOMER: BUS Terminal
 LOCATION: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
					9175
lower level south gate 8 Stanley					
reset door to lower track					
due some one unknown					
cycled adjusted observed					
					316 315
					2702
lower level south gate 2 Stanley					
reset door control					
Cycled adjusted observed					
					315
OK FA 10/14					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: _____ TRUCK #: 331
 ARRIVED HERE: 300 NO. OF MEN: 1
 LEFT THIS JOB: 400 JOB COMPLETED: YES NO

MECHANICS: _____ CUSTOMER'S SIGNATURE: _____ PRINT NAME: _____

DOOR AUTOMATION CORP.

DATE: 13014

CUSTOMER: B/S Terminal

PO: _____

LOCATION: _____

TN: 11337

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
Lower level South gate 3 Stanley 3561					
Reset door control					
adjusted actuator					
cycled observed					
315 316					
Lower level South gate 13 Stanley 0575					
Required wiring and reset control					
adjusted both guide					
cycled adjusted observed					
316					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 1200 TRUCK #: 331
 ARRIVED HERE: 100 NO. OF MEN: 1
 LEFT THIS JOB: 200 JOB COMPLETED: YES NO

Ross MECHANICS CUSTOMER'S SIGNATURE PRINT NAME

PA BUS TERMINAL DOOR MAINT CHECK LIST

J. [Signature]

DATE: 01/31/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
30TH WING 8th AVE	SL1R1	h sld						YES	Call For Part 01/29/14
30TH WING 8th AVE	SL1R2	h sld	✓	✓	✓	✓	✓	NO	OFF SC-VIC
30TH WING 8th AVE	SL1R3	h revolver	✓	✓	✓	✓	✓	NO	
30TH WING 8th AVE	SL1R4	h revolver						YES	N.W. 02/28/14
[REDACTED]									
41st STREET	S13A1	St sw	✓	✓	✓	✓	✓	NO	
41st STREET	S13A2	St sw	✓	✓	✓	✓	✓	NO	
[REDACTED]									
30TH WING 8TH AVE	S14A1A	Beam sw	✓	✓	✓	✓	✓	NO	
30TH WING 8TH AVE	S14A1B	Beam sw	✓	✓	✓	✓	✓	NO	
30TH WING 8TH AVE	S14A2A	Gt sw	✓	✓	✓	✓	✓	NO	
30TH WING 8TH AVE	S14A2B	Gt sw	✓	✓	✓	✓	✓	NO	
30TH WING 8TH AVE	S14A3A	Beam sw						YES	02/9/14
30TH WING 8TH AVE	S14A3B	Beam sw						YES	01/8/14
30TH WING 8TH AVE	S14A4A	Gt sw	✓	✓	✓	✓	✓	NO	
30TH WING 8TH AVE	S14A4B	Gt sw	✓	✓	✓	✓	✓	NO	

1800 ACCESS ROAD
OCEANSIDE, NY 11572
Phone (516) 678-4440 Fax (516) 887-7270

INVOICE

Date: 1/15/2014
Invoice No: 11919

Bill to: PORT AUTHORITY BUS TERMINAL
ATT: MAINTENANCE/BERNIE D'ALEO
625 8TH AVE
NEW YORK, NY 10018

Service at: PORT AUTHORITY BUS TERMINAL
625 8TH AVENUE
NY NY 10018

Reference: Work Order 16111
PO Number:
Terms:

Work Date DAC Tag# Door Description Work Performed
1/11/2014

326 TUNED, ADJUSTED, CYCLED AND OBSERVED
329 PM PERFORMED

Item	Work Date	Description	Quantity	Unit Price	Amount
Miscellaneous	1ST JANUARY PM		1.00	4,370.00	4,370.00
				Miscellaneous Subtotal	4,370.00

OK
BN
2/21/14

Purchase Requisition #
~~4400480916~~
2/21/14 - CR
Ⓟ 3/6/14

Subtotal:	4,370.00
Sales Tax:	0.00
Total Due:	4,370.00

DOOR AUTOMATION CORP.

DATE: 1-2-14

PO: _____

TN: 15943

CUSTOMER: Bus Terminal

LOCATION: NY NY

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
1	South Building	900	# 182	Revolving	
315	Rehung	wing # 3	ON	AVOUC	Door #1
	Reinstalled	power			
	(26) Running	properly			
	Cycled	And	observed		
For Door # 3 Company follow order					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 4:30

TRUCK #: 1364

ARRIVED HERE: 5:30

NO. OF MEN: 1

LEFT THIS JOB: 7:15

JOB COMPLETED: YES NO

Bevov
MECHANICS

Richard Oaker
CUSTOMER'S SIGNATURE

Richard Oaker
PRINT NAME

PA BUS TERMINAL DOOR MAINT CHECK LIST

Juan/Charles

DATE: 01/11/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	St aid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	3	St aid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	5	St aid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	7	St aid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	9	St aid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	11	St aid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	13	St aid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	15	St aid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	17	St aid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	19	St aid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	21	St aid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	23	St aid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	25	St aid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	27	St aid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	29	St aid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	31	St aid	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

Juan/Charles

DATE: *01/11/14*

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	34	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	32	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	30	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	28	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	26	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	24	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	22	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	20	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	18	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	16	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	60	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	62	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	62A	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	63	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	64	St old	✓	✓	✓	✓	✓	no	

03545

PA BUS TERMINAL DOOR MAINT CHECK LIST

Dean / Capriles

DATE: 1/22/13 01/11/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOYS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	65	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	66	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	67	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	68	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	69	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	70	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	71	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	71A	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	72	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	73	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	74	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	75	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	75A	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	76	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	84A	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	85	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	88	St old	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

Justin / Chowles

DATE: *01/11/14*

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	81	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	82	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	83	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	84	St old	✓	✓	✓	✓	✓	no	
[REDACTED SECTION]									
3rd FL NORTH	301	St aw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	302	St aw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	303	St aw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	304	St aw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	305	St aw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	306	St aw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	307	St aw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	308	St aw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	309	St aw	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR PAINT CHECK LIST

DATE: 01/11/14
 Swr/Chorcy

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	SI SW	/	/	/	/	/		no
3rd FL NORTH	311	SI SW	/	/	/	/	/		no
3rd FL NORTH	312	SI SW	/	/	/	/	/		no
3rd FL NORTH	313	SI SW	/	/	/	/	/		no
3rd FL NORTH	314	SI SW	/	/	/	/	/		no
3rd FL NORTH	315	SI SW	/	/	/	/	/		no
3rd FL NORTH	316	SI SW	/	/	/	/	/		no
3rd FL NORTH	317	SI SW	/	/	/	/	/		no
3rd FL NORTH	318	SI SW	/	/	/	/	/		no
3rd FL NORTH	319	SI SW	/	/	/	/	/		no
3rd FL NORTH	320	SI SW	/	/	/	/	/		no
3rd FL NORTH	321	SI SW	/	/	/	/	/		no
3rd FL NORTH	322	SI SW	/	/	/	/	/		no
3rd FL NORTH	323	SI SW	/	/	/	/	/		no
3rd FL NORTH	324	SI SW	/	/	/	/	/		no
3rd FL NORTH	325	SI SW	/	/	/	/	/		no
3rd FL NORTH	326	SI SW	/	/	/	/	/		no

PA BUS TERMINAL DOOR MAINT CHECK LIST

3/27/14 Charles

DATE: 01/11/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	417	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	418	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	419	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	420	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	421	St sw	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	14	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	12	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	10	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	8	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	6	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	4	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	2	ST SLD	✓	✓	✓	✓	✓	no	
ROAD WAY EAST	SL1A1	BESAM SLD AND 1	✓	✓	✓	✓	✓	no	
ROAD WAY WEST	SL1A2	BESAM SLD AND 1	✓	✓	✓	✓	✓	no	

DOOR AUTOMATION CORP

1800 ACCESS ROAD
 OCEANSIDE, NY 11572
 Phone (516) 678-4440 Fax (516) 887-7270

INVOICE

Date: 4/15/2014
 Invoice No: 12887

Bill to: PORT AUTHORITY BUS TERMINAL
 ATT: MAINTENANCE/BERNIE D'ALEO
 625 8TH AVE
 NEW YORK, NY 10018

Service at: PORT AUTHORITY BUS TERMINAL
 625 8TH AVENUE
 NY NY 10018

Purchase Requisition #
 4400 438469
 5/22/14 - CR
 @ 5/23/14

Reference: Work Order 16957
 PO Number:
 Terms:

Work Date 3/24/2014 DAC Tag# Door Description Work Performed

1 MAN REG

Item	Work Date	Description	Quantity	Unit Price	Amount
------	-----------	-------------	----------	------------	--------

Labor

3/24/2014

Labor Subtotal 0.00

Miscellaneous

2nd MARCH PM

1.00 4,370.00 4,370.00

Miscellaneous Subtotal 4,370.00

OK 5/19/14
 BD

Subtotal:	4,370.00
Sales Tax:	0.00
Total Due:	4,370.00

DOOR AUTOMATION CORP. ②

DATE: 03/23/14

CUSTOMER: Bus Terminal Pm

PO: _____

LOCATION: _____

TN: 16437

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
04	SOUTH WING	4103		STANLEY SWING	
DAC 03890					
330 MUST RETURN WITHIN 50 SECONDS TO RESET CONTROL					
04	SOUTH WING	4106		STANLEY SWING	
DAC 03816					
330 MUST RETURN WITHIN 50 SECONDS TO RESET CONTROL					
01	SOUTH WING	9AVE	015	STANLEY SWING	
DAC 07960					
330 MUST RETURN WITHIN 50 SECONDS TO RESET CONTROL					
01	SOUTH WING	11		STANLEY SLIDE	
DAC 04647					
330 MUST RETURN WITHIN 50 SECONDS TO RESET CONTROL					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentation by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 8:00

TRUCK #: 320

ARRIVED HERE: 9:00

NO. OF MEN: _____

LEFT THIS JOB: 1:30

JOB COMPLETED: YES NO

Sum

[Signature]

[Signature]

MECHANICS

CUSTOMER'S SIGNATURE

PRINT NAME

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: 3/27/16

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	3	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	5	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	7	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	9	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	11	St old	X	/	/	/	/	yes	2012 sensor 04643
LOWER LEVEL SOUTH	13	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	15	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	17	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	19	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	21	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	23	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	25	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	27	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	29	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	31	St old	/	/	/	/	/	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: 3/23/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	34	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	32	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	30	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	28	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	26	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	24	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	22	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	20	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	18	St old	/	/	/	/	/	no	
LOWER LEVEL SOUTH	16	St old	/	/	/	/	/	no	
03545									
LOWER LEVEL NORTH	60	St old	/	/	/	/	/	no	
LOWER LEVEL NORTH	62	St old	/	/	/	/	/	no	
LOWER LEVEL NORTH	62A	St old	/	/	/	/	/	no	
LOWER LEVEL NORTH	63	St old	/	/	/	/	/	no	
LOWER LEVEL NORTH	64	St old	/	/	/	/	/	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

Dean

DATE: 3/23/14

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	65	St sld	/	/	/	/	/	no	
LOWER LEVEL NORTH	66	St sld	/	/	/	/	/	no	
LOWER LEVEL NORTH	67	St sld	/	/	/	/	/	no	
LOWER LEVEL NORTH	68	St sld	/	/	/	/	/	no	
LOWER LEVEL NORTH	69	St sld	/	/	/	/	/	no	
LOWER LEVEL NORTH	70	St sld	/	/	/	/	/	no	
LOWER LEVEL NORTH	71	St sld	/	/	/	/	/	no	
LOWER LEVEL NORTH	71A	St sld	/	/	/	/	/	no	
LOWER LEVEL NORTH	72	St sld	/	/	/	/	/	no	
LOWER LEVEL NORTH	73	St sld	/	/	/	/	/	no	
LOWER LEVEL NORTH	74	St sld	/	/	/	/	/	no	
LOWER LEVEL NORTH	75	St sld	/	/	/	/	/	no	
LOWER LEVEL NORTH	75A	St sld	/	/	/	/	/	no	
LOWER LEVEL NORTH	76	St sld	/	/	/	/	/	no	
LOWER LEVEL NORTH	84A	St sld	/	/	/	/	/	no	
LOWER LEVEL NORTH	85	St sld	/	/	/	/	/	no	
C-L North	88	St sld	/	/	/	/	/	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	81	St sid	/	/	/	/	/	no	
LOWER LEVEL NORTH	82	St sid	/	/	/	/	/	no	
LOWER LEVEL NORTH	83	St sid	/	/	/	/	/	no	
LOWER LEVEL NORTH	84	St sid	/	/	/	/	/	no	
3rd FL NORTH	301	St sw	/	/	/	/	/	no	
3rd FL NORTH	302	St sw	/	/	/	/	/	no	
3rd FL NORTH	303	St sw	/	/	/	/	/	no	
3rd FL NORTH	304	St sw	/	/	/	/	/	no	
3rd FL NORTH	305	St sw	/	/	/	/	/	no	
3rd FL NORTH	306	St sw	/	/	/	/	/	no	
3rd FL NORTH	307	St sw	/	/	/	/	/	no	
3rd FL NORTH	308	St sw	/	/	/	/	/	no	
3rd FL NORTH	309	St sw	/	/	/	/	/	no	

PA BUS TERMINAL, DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	St sw	/	/	/	/	/	no	
3rd FL NORTH	311	St sw	/	/	/	/	/	no	
3rd FL NORTH	312	St sw	/	/	/	/	/	no	
3rd FL NORTH	313	St sw	/	/	/	/	/	no	
3rd FL NORTH	314	St sw	/	/	/	/	/	no	
3rd FL NORTH	315	St sw	/	/	/	/	/	no	
3rd FL NORTH	316	St sw	/	/	/	/	/	no	
3rd FL NORTH	317	St sw	/	/	/	/	/	no	
3rd FL NORTH	318	St sw	/	/	/	/	/	no	
3rd FL NORTH	319	St sw	/	/	/	/	/	no	
3rd FL NORTH	320	St sw	/	/	/	/	/	no	
3rd FL NORTH	321	St sw	/	/	/	/	/	no	
3rd FL NORTH	322	St sw	/	/	/	/	/	no	
3rd FL NORTH	323	St sw	/	/	/	/	/	no	
3rd FL NORTH	324	St sw	/	/	/	/	/	no	
3rd FL NORTH	325	St sw	/	/	/	/	/	no	
3rd FL NORTH	326	St sw	/	/	/	/	/	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: 7/

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St sw	/	/	/	/	/	no	
4th FL SOUTH	402	St sw	/	/	/	/	/	no	
4th FL SOUTH	403	St sw	/	/	/	/	/	yes	
4th FL SOUTH	404	St sw	/	/	/	/	/	no	
4th FL SOUTH	405	St sw	/	/	/	/	/	no	
4th FL SOUTH	406	St sw	/	/	/	/	/	yes	
4th FL SOUTH	407	St sw	/	/	/	/	/	no	
4th FL SOUTH	408	St sw	/	/	/	/	/	no	
4th FL SOUTH	409	St sw	/	/	/	/	/	no	
4th FL SOUTH	410	St sw	/	/	/	/	/	no	
4th FL SOUTH	411	St sw	/	/	/	/	/	no	
4th FL SOUTH	412	St sw	/	/	/	/	/	no	
4th FL SOUTH	413	St sw	/	/	/	/	/	no	
4th FL SOUTH	414	St sw	/	/	/	/	/	no	
4th FL SOUTH	415	st sw	/	/	/	/	/	no	
4th FL SOUTH	416	st sw	/	/	/	/	/	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	417	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	418	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	419	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	420	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	421	St sw	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	14	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	12	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	10	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	8	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	6	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	4	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	2	ST SLD	✓	✓	✓	✓	✓	no	
ROAD WAY EAST	SL1A1	BESAM SLD AMD 1	✓	✓	✓	✓	✓	no	
ROAD WAY WEST	SL1A2	BESAM SLD AMD 1	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
SOUTH WING 9th AVE	SL1R1	h sld	/	/	/	/	/	no	
SOUTH WING 9th AVE	SL1R2	h sld	/	/	/	/	/	no	
SOUTH WING 9th AVE	SL1R3	h revolver	/	/	/	/	/	yes	
SOUTH WING 9th AVE	SL1R4	h revolver	/	/	/	/	/	no	
41st STREET	S13A1	St sw	/	/	/	/	/	no	
41st STREET	S13A2	St sw	/	/	/	/	/	no	
SOUTH WING 8TH AVE	S14A1A	Besam sw	/	/	/	/	/	no	
SOUTH WING 8TH AVE	S14A1B	Besam sw	/	/	/	/	/	no	
SOUTH WING 8TH AVE	S14A2A	Gt sw	/	/	/	/	/	no	
SOUTH WING 8TH AVE	S14A2B	Gt sw	/	/	/	/	/	no	
SOUTH WING 8TH AVE	S14A3A	Besam sw	/	/	/	/	/	no	
SOUTH WING 8TH AVE	S14A3B	Besam sw	/	/	/	/	/	no	
SOUTH WING 8TH AVE	S14A4A	Gt sw	/	/	/	/	/	no	
SOUTH WING 8TH AVE	S14A4B	Gt sw	/	/	/	/	/	no	

DOOR AUTOMATION

1800 ACCESS ROAD
 OCEANSIDE, NY 11572
 Phone (516) 678-4440 Fax (516) 887-7270

JICE

2/28/2014
 No: 12257 ✓

*Spoke to Angela @ Door Automation
 for core charges big double
 3/7/14*

PORT AUTHORITY BUS TERMINAL
 ATT: MAINTENANCE/BERNIE D'ALEO
 625 8TH AVE
 NEW YORK, NY 10018

*Water damage
 to sliding door*

Service at: PORT AUTHORITY BUS TERMINAL
 625 8TH AVENUE
 NY NY 10018

Reference: Work Order 16257
 PO Number:
 Terms:

Work Date	DAC Tag#	Door Description	Work Performed
24/2014		DAC 01384 SOUTHWING 9TH AVE DOOR #1	317 WATER DAMAGE 499 MUST RETURN WITH PARTS TO COMPLETE
19/2014		DAC 01384 SOUTHWING 9TH AVE DOOR #1	220 REPLACED MOTOR & GEAR BOX 241 REPLACED CONTROL 275 REPLACED CARRIER & ANTI RISER WHEELS 315 RESET- REPROGRAM CONTROL 326 TUNED, ADJUSTED, CYCLED AND OBSERVED 331 CALL COMPLETE 352 REPLACED INNER ACTIVATION SENSOR

Purchase Requisition#
~~4400488699~~
 5/29/14 ✓

*Approved on
 6/11/14*

*OK
 BK
 3/17/14*

Item	Work Date	Description	Quantity	Unit Price	Amount
Labor					
	1/24/2014				
		OVT 1 MAN	0.50	240.00	120.00
		REG 1 MAN	0.75	160.00	120.00
	2/19/2014				
		REG 1 MAN	4.00	160.00	640.00
Labor Subtotal					880.00
Miscellaneous					
- WATER DAMAGE					
- LEAK MUST BE FIXED BY PORT AUTHORITY BUS TERMINAL					
Miscellaneous Subtotal					0.00

o
ce
ns
nt
E

Oakes, Richard

From: Do-Not-Reply@weanswer.com
Sent: Sunday, August 04, 2013 3:15 PM
To: Oakes, Richard
Subject: Message: 08/04/2013 03:11 PM (12866092)

Contact: SERVICE CALL of VRH CONSTRUCTION
Date: 08/04/2013 Time: 03:08 PM By: CHYNNA CallerID: 2124358000

SERVICE CALL

MAY I HAVE YOUR NAME PLEASE? OAKES, RICHIE
MAY I HAVE YOUR PHONE NUMBER? 212-502-2244
WHAT IS THE DOOR NUMBER THAT REQUIRES SERVICE? N1BA3A AND GATE 311
WHAT IS THE PROBLEM WITH THE DOOR? 311-inter push does not work and the other
door just does not work.

THANK YOU FOR CALLING.

Dispatched

8/4/2013, 03:09 PM, 1338, Service call, 1: 18003712208PP2, gm to service

Oakes, Richard

From: Do-Not-Reply@weanswer.com
Sent: Thursday, August 08, 2013 8:36 AM
To: Oakes, Richard
Subject: Message: 08/08/2013 08:34 AM (12875171)

Contact: SERVICE CALL of VRH CONSTRUCTION
Date: 08/08/2013 Time: 08:29 AM By: THANH CallerID: 2124358000

SERVICE CALL
MAY I HAVE YOUR NAME PLEASE? RICHIE OAKES
MAY I HAVE YOUR PHONE NUMBER? 212-502-2244
WHAT IS THE DOOR NUMBER THAT REQUIRES SERVICE? north wing, outer entrance
N1B, A3A,
WHAT IS THE PROBLEM WITH THE DOOR? doors don't work, gate 302 handle fell
off, 8311push play doesn't work.
THANK YOU FOR CALLING.

Dispatched

8/8/2013, 08:32 AM, 1049, Service call, 1: 18003712208PP2, GAVE MESSAGE

Oakes, Richard

From: Do-Not-Reply@weanswer.com
Sent: Saturday, August 10, 2013 6:35 PM
To: Oakes, Richard
Subject: Message: 08/10/2013 06:34 PM (12881329)

Contact: SERVICE CALL of VRH CONSTRUCTION

Date: 08/10/2013 Time: 06:15 PM By: DENISE F. CallerID: 2124358000

SERVICE CALL

MAY I HAVE YOUR NAME PLEASE?

RICHIE OAKES

MAY I HAVE YOUR PHONE NUMBER?

212 502 2244

WHAT IS THE DOOR NUMBER THAT REQUIRES SERVICE?

gates 3, 302, 320, 313,

311, 306, N1BA3A

WHAT IS THE PROBLEM WITH THE DOOR?

SEE PERSON AT PORT AUTHORITY.

THANK YOU FOR CALLING.

Dispatched

8/10/2013, 06:22 PM, 1330, Service call, 1: 18003712208PP2, DISCONNECTED 8/10/2013, 06:23 PM, 1330, Service call, 1: 18003712208PP2, CALLER HUNG UP 8/10/2013, 06:26 PM, 1330, Service call, 1: 18003712208PP2, DISCONNECTED 8/10/2013, 06:27 PM, 1330, Service call, 1: 18003712208PP2, REACHED

Oakes, Richard

From: Do-Not-Reply@weanswer.com
Sent: Saturday, August 31, 2013 1:14 PM
To: Oakes, Richard
Subject: Message: 08/31/2013 01:13 PM (12930783)

Contact: SERVICE CALL of VRH CONSTRUCTION
Date: 08/31/2013 Time: 01:07 PM By: NICA CallerID: 2124358000

SERVICE CALL
MAY I HAVE YOUR NAME PLEASE? RICHIE OAKES
MAY I HAVE YOUR PHONE NUMBER? 212 502 2244
WHAT IS THE DOOR NUMBER THAT REQUIRES SERVICE? S WING LL GATE 6 / S WING
4 FLR GATE 412
WHAT IS THE PROBLEM WITH THE DOOR? GATE 6 DOESN'T WORK AT ALL. GATE 412 SLAMS
SHUT. PLS CALL BEFORE YOU COME.
THANK YOU FOR CALLING.

Dispatched

8/31/2013, 01:10 PM, 1005, Service call, 1: 18003712208PP2, Gave Message

Oakes, Richard

From: Do-Not-Reply@weanswer.com
Sent: Saturday, August 31, 2013 7:45 PM
To: Oakes, Richard
Subject: Message: 08/31/2013 07:45 PM (12931402)

Contact: SERVICE CALL of VRH CONSTRUCTION
Date: 08/31/2013 Time: 07:38 PM By: JOYCE CallerID: 2124358000

SERVICE CALL
MAY I HAVE YOUR NAME PLEASE? RICHIE OAKES
MAY I HAVE YOUR PHONE NUMBER? 212 502 2244
WHAT IS THE DOOR NUMBER THAT REQUIRES SERVICE? SOUTH WING 1ST FL 8TH AVE
#RS14A3A
WHAT IS THE PROBLEM WITH THE DOOR? OUTER DOOR ARM FOR THE CLOSER BROKE NEEDS
A NEW CLOSER
THANK YOU FOR CALLING.

Dispatched

8/31/2013, 07:40 PM, 1441, Service call, 1: 18003712208PP2, Delivered to: JOSEPH

Oakes, Richard

From: Do-Not-Reply@weanswer.com
Sent: Saturday, August 31, 2013 11:36 PM
To: Oakes, Richard
Subject: Message: 08/31/2013 11:36 PM (12931541)

Contact: SERVICE CALL of VRH CONSTRUCTION

Date: 08/31/2013 Time: 11:30 PM By: JOYCE CallerID: 2124358000

SERVICE CALL

MAY I HAVE YOUR NAME PLEASE? RICHIE OAKES

MAY I HAVE YOUR PHONE NUMBER? 212 502 2244

WHAT IS THE DOOR NUMBER THAT REQUIRES SERVICE? 3RD FL NORTH WING GATE 311

WHAT IS THE PROBLEM WITH THE DOOR? INNER PUSH PLATES NOT WORKING - NEEDS TO

BE REPLACED

THANK YOU FOR CALLING.

Dispatched

8/31/2013, 11:32 PM, 1441, Service call, 1: 18003712208PP2, Delivered to: JAN

Oakes, Richard

From: Do-Not-Reply@weanswer.com
Sent: Tuesday, October 15, 2013 1:56 PM
To: Oakes, Richard
Subject: Message: 10/15/2013 01:56 PM (13033279)

Contact: SERVICE CALL of VRH CONSTRUCTION
Date: 10/15/2013 Time: 01:53 PM By: TIFFANY S. CallerID: 2124358000

SERVICE CALL

MAY I HAVE YOUR NAME PLEASE? RICHIE OAKS
MAY I HAVE YOUR PHONE NUMBER? 212 502 2244
WHAT IS THE DOOR NUMBER THAT REQUIRES SERVICE? NORTH WING LOWER LEVEL
GATE 78
WHAT IS THE PROBLEM WITH THE DOOR? KEEPS FALLING OFF TRACK, ALSO ELECTRICAL
SHORTAGE.

THANK YOU FOR CALLING.

Dispatched

10/15/2013, 01:55 PM, 1302, Service call, 1: 18003712208PP2, GAVE MSG

Oakes, Richard

From: Do-Not-Reply@weanswer.com
Sent: Tuesday, October 15, 2013 7:43 PM
To: Oakes, Richard
Subject: Message: 10/15/2013 07:43 PM (13034341)

Contact: EMERGENCY of VRH CONSTRUCTION

Date: 10/15/2013 Time: 07:37 PM By: JESSICA K. CallerID: 2124358000

EMERGENCY

MAY I HAVE YOUR NAME PLEASE?

RICHIE OAKS

MAY I HAVE YOUR PHONE NUMBER?

212.502.2244

WHAT IS THE DOOR NUMBER THAT REQUIRES SERVICE?

NORTH WING LOWER LEVER

GATE 78

WHAT IS THE PROBLEM WITH THE DOOR?

it just keeps falling off the track. plus

theres no power with it. i want to get it fixed.

THANK YOU FOR CALLING.

Dispatched

10/15/2013, 07:39 PM, 1317, Emergency, 1: 18003712208PP2, gave message

Oakes, Richard

From: Do-Not-Reply@weanswer.com
Sent: Friday, November 08, 2013 3:57 PM
To: Oakes, Richard
Subject: Message: 11/08/2013 03:58 PM (13086301)

Contact: SERVICE CALL of VRH CONSTRUCTION
Date: 11/08/2013 Time: 03:50 PM By: NACHAYKA CallerID: 2124358000

SERVICE CALL

MAY I HAVE YOUR NAME PLEASE? RICHIE OAKS
MAY I HAVE YOUR PHONE NUMBER? 212-502-2257

WHAT IS THE DOOR NUMBER THAT REQUIRES SERVICE? ON FILE (There are now 7
doors down)

WHAT IS THE PROBLEM WITH THE DOOR? Do you have the parts. Another door is
down . Alt# 212502-2244 ask for the 4-0 on duty

THANK YOU FOR CALLING.

Dispatched

11/8/2013, 03:56 PM, 1054, Service call, 1: 18003712208PP2, gave message

Oakes, Richard

From: Do-Not-Reply@weanswer.com
Sent: Friday, November 15, 2013 3:40 PM
To: Oakes, Richard
Subject: Message: 11/15/2013 03:41 PM (13102199)

Contact: SERVICE CALL of VRH CONSTRUCTION

Date: 11/15/2013 Time: 03:35 PM By: CASSANDRA H. CallerID: 2124358000

SERVICE CALL

MAY I HAVE YOUR NAME PLEASE? RICHIE OAKES
MAY I HAVE YOUR PHONE NUMBER? 212 502 2244
WHAT IS THE DOOR NUMBER THAT REQUIRES SERVICE? NORTH WING 8TH AVE. INNER
ENTRANCE
WHAT IS THE PROBLEM WITH THE DOOR? COVER FELL OFF AND OTHER PARTS ARE LOOSE.
THANK YOU FOR CALLING.

Dispatched

11/15/2013, 03:38 PM, 1017, Service call, 1: 18003712208PP2, GAVE FULL MESSAGE

Oakes, Richard

From: Do-Not-Reply@weanswer.com
Sent: Friday, November 22, 2013 3:57 PM
To: Oakes, Richard
Subject: Message: 11/22/2013 03:57 PM (13117219)

Contact: SERVICE CALL of VRH CONSTRUCTION

Date: 11/22/2013 Time: 03:54 PM By: DAWN CallerID: 2124358000

SERVICE CALL

MAY I HAVE YOUR NAME PLEASE? RICH OAKES
MAY I HAVE YOUR PHONE NUMBER? 212-502-2244
WHAT IS THE DOOR NUMBER THAT REQUIRES SERVICE? 321
WHAT IS THE PROBLEM WITH THE DOOR? ONE OF THE PARTS IS MISSING. IT HAS BEEN
LIKE THIS FOR OVER 2WEEKS.

THANK YOU FOR CALLING.

Dispatched

11/22/2013, 03:55 PM, 1604, Service call, 1: 18003712208PP2, SPOKE WITH THE O/C PERSON

Oakes, Richard

From: Do-Not-Reply@weanswer.com
Sent: Saturday, November 23, 2013 4:04 PM
To: Oakes, Richard
Subject: Message: 11/23/2013 04:05 PM (13119298)

Contact: EMERGENCY of VRH CONSTRUCTION
Date: 11/23/2013 Time: 03:58 PM By: SAMANTHA JONES CallerID: 2124358000

EMERGENCY
MAY I HAVE YOUR NAME PLEASE? RICH OAKES
MAY I HAVE YOUR PHONE NUMBER? 212 502 2244
WHAT IS THE DOOR NUMBER THAT REQUIRES SERVICE? 321
WHAT IS THE PROBLEM WITH THE DOOR? THE DOOR IS OFF TRACK / STILL WAITING FOR
PARTS / PLEASE CALL BACK ASAP.
THANK YOU FOR CALLING.

Dispatched

11/23/2013, 04:00 PM, 1506, Emergency, 1: 18003712208PP2, NO ANSWER 11/23/2013, 04:05 PM,
1506, Emergency, 1: 18003712208PP2,

Oakes, Richard

From: Do-Not-Reply@weanswer.com
Sent: Monday, November 25, 2013 1:58 AM
To: Oakes, Richard
Subject: Message: 11/25/2013 01:59 AM (13121407)

Contact: SERVICE CALL of VRH CONSTRUCTION

Date: 11/25/2013 Time: 01:55 AM By: RUTH AVERY CallerID: 2124358000

SERVICE CALL

MAY I HAVE YOUR NAME PLEASE? richy oakes
MAY I HAVE YOUR PHONE NUMBER? 212-502-2244
WHAT IS THE DOOR NUMBER THAT REQUIRES SERVICE? gate 32 north wing 8th ave
inner entrance door
WHAT IS THE PROBLEM WITH THE DOOR? n1b a1b
THANK YOU FOR CALLING.

Dispatched

11/25/2013, 01:57 AM, 1326, Service call, 1: 18003712208PP2, gave to svc

Oakes, Richard

From: Do-Not-Reply@weanswer.com
Sent: Friday, December 06, 2013 3:02 PM
To: Oakes, Richard
Subject: Message: 12/06/2013 03:03 PM (13148298)

Contact: EMERGENCY of VRH CONSTRUCTION
Date: 12/06/2013 Time: 03:01 PM By: EVER CallerID: 2124358000

EMERGENCY

MAY I HAVE YOUR NAME PLEASE? RICHIE OAKES
MAY I HAVE YOUR PHONE NUMBER? 212 502 2244
WHAT IS THE DOOR NUMBER THAT REQUIRES SERVICE? MULTIPLE DOORS
WHAT IS THE PROBLEM WITH THE DOOR? I need speak w/ a supervisor. Someone
should have been here on 12/3. I am very unhappy.
THANK YOU FOR CALLING.

Dispatched

12/6/2013, 03:02 PM, 1007, Emergency, 1: 18003712208PP2, GAVE MSG

Oakes, Richard

From: Do-Not-Reply@weanswer.com
Sent: Friday, December 13, 2013 3:12 PM
To: Oakes, Richard
Subject: Message: 12/13/2013 03:14 PM (13165271)

Contact: SERVICE CALL of VRH CONSTRUCTION
Date: 12/13/2013 Time: 03:11 PM By: FRANCIS L CallerID: 2124358000

SERVICE CALL

MAY I HAVE YOUR NAME PLEASE? RICHIE OAKES
MAY I HAVE YOUR PHONE NUMBER? 212-502-2244
WHAT IS THE DOOR NUMBER THAT REQUIRES SERVICE? GATE 321 GATE 312
GATE 26
WHAT IS THE PROBLEM WITH THE DOOR? Gate 321 has been out since Nov need to
speak to a supervisor asap. 312 not opening 26 not working
THANK YOU FOR CALLING.

Dispatched

12/13/2013, 03:13 PM, 1206, Service call, 1: 18003712208PP2,

Oakes, Richard

From: Do-Not-Reply@weanswer.com
Sent: Wednesday, December 18, 2013 8:44 AM
To: Oakes, Richard
Subject: Message: 12/18/2013 08:45 AM (13175381)

Contact: SERVICE CALL of VRH CONSTRUCTION
Date: 12/18/2013 Time: 08:42 AM By: NACHAYKA CallerID: 2124358000

SERVICE CALL

MAY I HAVE YOUR NAME PLEASE? RICHIE OAKS
MAY I HAVE YOUR PHONE NUMBER? 212-502-2244
WHAT IS THE DOOR NUMBER THAT REQUIRES SERVICE? DECLINED
WHAT IS THE PROBLEM WITH THE DOOR? NEED AN AUTOMATION SUPERVISOR TO CALL ME
ASAP (NO FURTHER INFO.)

THANK YOU FOR CALLING.

Dispatched

12/18/2013, 08:43 AM, 1054, Service call, 1: 18003712208PP2, GAVE MESSAGE

Oakes, Richard

From: Do-Not-Reply@weanswer.com
Sent: Saturday, December 21, 2013 5:31 PM
To: Oakes, Richard
Subject: Message: 12/21/2013 05:33 PM (13184148)

Contact: SERVICE CALL of VRH CONSTRUCTION

Date: 12/21/2013 Time: 05:19 PM By: LISSETTE S. CallerID: 2124358000

SERVICE CALL

MAY I HAVE YOUR NAME PLEASE? RICHIE OAKS

MAY I HAVE YOUR PHONE NUMBER? 212 502 2244

WHAT IS THE DOOR NUMBER THAT REQUIRES SERVICE? Gates 81, 312, 26, South wing 8th ave s14a3b

WHAT IS THE PROBLEM WITH THE DOOR? making noise, door doesn't close, door is loose, the closer came loose & revolving door 2 out of service

THANK YOU FOR CALLING.

Dispatched

12/21/2013, 05:25 PM, 1339, Service call, 1: 18003712208PP2, GM TO MESSAGING CENTER

Oakes, Richard

From: Do-Not-Reply@weanswer.com
Sent: Saturday, December 21, 2013 7:51 PM
To: Oakes, Richard
Subject: Message: 12/21/2013 07:54 PM (13184321)

Contact: SERVICE CALL of VRH CONSTRUCTION
Date: 12/21/2013 Time: 07:51 PM By: KIZZYANN CallerID: 2124358000

SERVICE CALL
MAY I HAVE YOUR NAME PLEASE? RICHIE OAKES
MAY I HAVE YOUR PHONE NUMBER? 212.502.2244
WHAT IS THE DOOR NUMBER THAT REQUIRES SERVICE? SOUTH WING 9TH AVE
REVOLVING DOOR 1
WHAT IS THE PROBLEM WITH THE DOOR? DOOR BROKE LOOSE.
THANK YOU FOR CALLING.

Dispatched

12/21/2013, 07:52 PM, 1029, Service call, 1: 18003712208PP2, GFM

Oakes, Richard

From: Do-Not-Reply@weanswer.com
Sent: Saturday, December 21, 2013 9:06 PM
To: Oakes, Richard
Subject: Message: 12/21/2013 09:07 PM (13184389)

Contact: SERVICE CALL of VRH CONSTRUCTION
Date: 12/21/2013 Time: 09:01 PM By: TYLENE CallerID: 2124358000

SERVICE CALL

MAY I HAVE YOUR NAME PLEASE? RICHIE OAKES
MAY I HAVE YOUR PHONE NUMBER? 212.502.2244
WHAT IS THE DOOR NUMBER THAT REQUIRES SERVICE? South Wing 8th Ave, inner
exit door #: S-14-A2A
WHAT IS THE PROBLEM WITH THE DOOR? DOOR IS BROKEN; WILL NOT OPEN.
THANK YOU FOR CALLING.

Dispatched

12/21/2013, 09:04 PM, 1516, Service call, 1: 18003712208PP2, GFM TO DANIELLE @ ANS SERV

Oakes, Richard

From: Do-Not-Reply@weanswer.com
Sent: Saturday, December 28, 2013 1:12 PM
To: Oakes, Richard
Subject: Message: 12/28/2013 01:14 PM (13197115)

Contact: SERVICE CALL of VRH CONSTRUCTION
Date: 12/28/2013 Time: 01:04 PM By: QUELYN CallerID: 2124358000

SERVICE CALL

MAY I HAVE YOUR NAME PLEASE? RICHIE OAKES
MAY I HAVE YOUR PHONE NUMBER? 212 502 2244
WHAT IS THE DOOR NUMBER THAT REQUIRES SERVICE? Gates 418, 319, 320, 303,
78, 19 and 6
WHAT IS THE PROBLEM WITH THE DOOR? Various - Please ask for the 4-0 on duty
THANK YOU FOR CALLING.

Dispatched

12/28/2013, 01:07 PM, 1402, Service call, 1: 18003712208PP2, GAVE MSG

DOOR AUTOMATION CORP.

DATE: 11/10/11

CUSTOMER: Bus Terminal

PO: _____

LOCATION: _____

TN: 15679

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
LC	North wing	66		Stanley	slide
DAC 04057					
499 must return with 1/4 bottom guide					
LC	North wing	78		Stanley	slide
DAC 0347#					
499 must return with 1/4 bottom guide					
LC	North wing	79		Stanley	slide
DAC 01707					
499 must return with a MC 571 control					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 2-30 TRUCK #: 320

ARRIVED HERE: 3:30 NO. OF MEN: 1

LEFT THIS JOB: 11:15 JOB COMPLETED: YES NO

Tom

DOOR AUTOMATION CORP.

DATE: 12/24/13
 PO: _____
 TN: 15961

CUSTOMER: Bus Terminal
 LOCATION: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
					<u>0158 window</u>
					<u>01 SOUTH window 9AU Revolver Horton</u>
					<u>PH: 02528</u>
					<u>499 must repair with top</u>
					<u>100 replaced L/H operator</u>
					<u>310 made temporary repair</u>
					<u>499 must repair with door track and slider block</u>
					<u>PH: 02528</u>
					<u>PH: 02528</u>

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative tot he Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 7:30 TRUCK #: 370
 ARRIVED HERE: 8:30 NO. OF MEN: 1
 LEFT THIS JOB: 2:30 JOB COMPLETED: YES NO

J. Suber MECHANICS CUSTOMER'S SIGNATURE PRINT NAME

PA BUS TERMINAL DOOR MAINT CHECK LIST

South/Charles

DATE: 12/28/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	SI SID	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	3	SI SID	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	5	SI SID	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	7	SI SID	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	9	SI SID	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	11	SI SID	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	13	SI SID	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	15	SI SID	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	17	SI SID	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	19	SI SID	/	/	/	/	/	NO	need grease switch
LOWER LEVEL SOUTH	21	SI SID	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	23	SI SID	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	25	SI SID	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	27	SI SID	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	29	SI SID	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	31	SI SID	/	/	/	/	/	NO	

PA BUS TERMINAL DOOR MAINT CHECK LIST

John Charles

DATE: *12/28/13*

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	34	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	32	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	30	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	28	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	26	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	24	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	22	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	20	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	18	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	16	St old	✓	✓	✓	✓	✓	no	
REPAIRED									
LOWER LEVEL NORTH	60	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	62	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	62A	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	63	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	64	St old	✓	✓	✓	✓	✓	no	

03545

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUAN/Charles

DATE: ~~1/25/13~~ 12/28/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	65	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	66	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	67	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	68	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	69	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	70	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	71	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	71A	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	72	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	73	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	74	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	75	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	75A	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	76	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	84A	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	85	St slid	✓	✓	✓	✓	✓	no	
LL North	88	St slid						yes	Bottom Guide

PA BUS TERMINAL DOOR MAINT CHECK LIST

John J. Choate

DATE: *12/28/13*

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	St ew	✓	✓	✓	✓	✓	no	
3rd FL NORTH	311	St ew	✓	✓	✓	✓	✓	no	
3rd FL NORTH	312	St ew	✓	✓	✓	✓	✓	no	
3rd FL NORTH	313	St ew	✓	✓	✓	✓	✓	no	
3rd FL NORTH	314	St ew	✓	✓	✓	✓	✓	no	
3rd FL NORTH	315	St ew	✓	✓	✓	✓	✓	no	
3rd FL NORTH	316	St ew	✓	✓	✓	✓	✓	no	
3rd FL NORTH	317	St ew	✓	✓	✓	✓	✓	no	
3rd FL NORTH	318	St ew	✓	✓	✓	✓	✓	no	
3rd FL NORTH	319	St ew						yes	P.W.S
3rd FL NORTH	320	St ew						yes	P.W.S
3rd FL NORTH	321	St ew	✓	✓	✓	✓	✓	no	
3rd FL NORTH	322	St ew	✓	✓	✓	✓	✓	no	
3rd FL NORTH	323	St ew	✓	✓	✓	✓	✓	no	
3rd FL NORTH	324	St ew	✓	✓	✓	✓	✓	no	
3rd FL NORTH	325	St ew	✓	✓	✓	✓	✓	no	
3rd FL NORTH	326	St ew	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

Sum/Cher

DATE: 12/27/15

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St SW	/	/	/	/	/	no	
4th FL SOUTH	402	St SW	/	/	/	/	/	no	
4th FL SOUTH	403	St SW	/	/	/	/	/	no no	R/W discs no
4th FL SOUTH	404	St SW	/	/	/	/	/	yes	yes
4th FL SOUTH	405	St SW	/	/	/	/	/	yes	yes second comp
4th FL SOUTH	406	St SW	/	/	/	/	/	no	
4th FL SOUTH	407	St SW	/	/	/	/	/	no	
4th FL SOUTH	408	St SW	/	/	/	/	/	no	
4th FL SOUTH	409	St SW	/	/	/	/	/	no	
4th FL SOUTH	410	St SW	/	/	/	/	/	no	
4th FL SOUTH	411	St SW	/	/	/	/	/	no	
4th FL SOUTH	412	St SW	/	/	/	/	/	no	
4th FL SOUTH	413	St SW	/	/	/	/	/	no	
4th FL SOUTH	414	St SW	/	/	/	/	/	no	
4th FL SOUTH	415	St SW	/	/	/	/	/	no	
4th FL SOUTH	416	St SW	/	/	/	/	/	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

Sum/Chales

DATE: 12/25/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	417	ST SW	/	/	/	/	/	no	
4th FL SOUTH	418	ST SW	/	/	/	/	/	no	
4th FL SOUTH	419	ST SW	/	/	/	/	/	no	
4th FL SOUTH	420	ST SW	/	/	/	/	/	no	
4th FL SOUTH	421	ST SW	/	/	/	/	/	no	
LOWER LEV SOUTH	14	ST SLD	/	/	/	/	/	no	
LOWER LEV SOUTH	12	ST SLD	/	/	/	/	/	no	
LOWER LEV SOUTH	10	ST SLD	/	/	/	/	/	no	
LOWER LEV SOUTH	8	ST SLD	/	/	/	/	/	no	
LOWER LEV SOUTH	6	ST SLD	/	/	/	/	/	no	
LOWER LEV SOUTH	4	ST SLD	/	/	/	/	/	no	
LOWER LEV SOUTH	2	ST SLD	/	/	/	/	/	no	
ROAD WAY EAST	SL1A1	BEGAN SLD AND 1	/	/	/	/	/	no	
ROAD WAY WEST	SL1A2	BEGAN SLD AND 1	/	/	/	/	/	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

Seann/B. Bowler

DATE: *12/29/13*

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
SOUTH WING 9th AVE	SL1R1	h sld	✓	✓	✓	✓	✓	no	
SOUTH WING 9th AVE	SL1R2	h sld	✓	✓	✓	✓	✓	no	
SOUTH WING 9th AVE	SL1R3	h revolver	✓	✓	✓	✓	✓	no	
SOUTH WING 9th AVE	SL1R4	h revolver	✓	✓	✓	✓	✓	yes	TOP GOSHING
41st STREET	S13A1	St sw	✓	✓	✓	✓	✓	no	
41st STREET	S13A2	St sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A1A	Besam sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A1B	Besam sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A2A	Gt sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A2B	Gt sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A3A	Besam sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A3B	Besam sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A4A	Gt sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A4B	Gt sw	✓	✓	✓	✓	✓	no	

DOOR AUTOMATION CORP.

DATE: 12/27/13

CUSTOMER: BUS Terminal

PO: _____

LOCATION: _____

TN: 15860

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
01	SOUTH wing	STAN	S14A3B	besom	swing
DHC 024771					
344 RESECURE ARM TRACK					
315 RESET and REPROGRAM control					
LL	SOUTH wing	GATE 26	STANLEY	slide	
DHC 03894					
277 REPLACE BOTTOM GUIDE					
315 RESET and REPROGRAM control					
310 TACO DOOR IS WORKING OK					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 7:30 TRUCK #: 320

ARRIVED HERE: 8:30 NO. OF MEN: 1

LEFT THIS JOB: 2:30 JOB COMPLETED: YES NO

John
MECHANICS

CUSTOMER'S SIGNATURE

PRINT NAME

DOOR AUTOMATION CORP.

DATE: 12/28/13

PO: _____

TN: 15906

CUSTOMER: USC Verminol

LOCATION: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
<u>03</u>	<u>North wing</u>	<u>303</u>	<u>Stanley</u>	<u>swing</u>	
<u>DN</u>	<u>199 must return with a</u>				
	<u>press wall switch</u>				
<u>03</u>	<u>North wing</u>	<u>310</u>	<u>Stanley</u>	<u>swing</u>	
<u>DN</u>	<u>199 must return with a</u>				
	<u>press wall switch</u>				
<u>06</u>	<u>North wing</u>	<u>70</u>	<u>Stanley</u>	<u>swing</u>	
<u>DN</u>	<u>199 must return with a</u>				
	<u>bottom guide</u>				

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative tot he Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 1:00

TRUCK #: 310

ARRIVED HERE: 3:00

NO. OF MEN: 2

LEFT THIS JOB: 6:00

JOB COMPLETED: YES NO

John Schales

MECHANICS

CUSTOMER'S SIGNATURE

PRINT NAME

DOOR AUTOMATION CORPORATION

DATE: 12/22/13

CUSTOMER: Bus Terminal

PO: _____

LOCATION: _____

TN: 15906

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
04	South wing	418		Stanley swing	
DAC					
499 must return with a bottom clausure					
to be replaced					
LL	South wing	19		Stanley slider	
DAC					
499 must return with a bottom					
out switch					
01	South wing	9 Acc	01	Revolving door	
DAC					
499 must return with Top pivot					
to be completed					
OR					
TW 15861					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 1:00 TRUCK #: 320

ARRIVED HERE: 2:00 NO. OF MEN: 2

LEFT THIS JOB: 6:00 JOB COMPLETED: YES NO

Juan/Charles

MECHANICS

CUSTOMER'S SIGNATURE

PRINT NAME

DOOR AUTOMATION CORP.

DATE: 12/12/13
 PO: _____
 TN: 19951

CUSTOMER: _____
 LOCATION: Bus terminal

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
Tag # 01392					
01 South wing 8th ave SHAWA St swing					
A must return to complete repair					
A must return to complete repair					
A must return to complete repair					
Tag # 04153					
01 North wing 8th ave 02 Rear swing					
Door working need to be adjusted					
Tested door with wai of door and					
its working.					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative tot he Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: _____ TRUCK #: _____
 ARRIVED HERE: _____ NO. OF MEN: _____
 LEFT THIS JOB: _____ JOB COMPLETED: YES NO

[Signature] MECHANICS CUSTOMER'S SIGNATURE _____ PRINT NAME

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: 12/5/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL SOUTH	3	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL SOUTH	5	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL SOUTH	7	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL SOUTH	9	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL SOUTH	11	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL SOUTH	13	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL SOUTH	15	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL SOUTH	17	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL SOUTH	19	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL SOUTH	21	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL SOUTH	23	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL SOUTH	25	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL SOUTH	27	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL SOUTH	29	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL SOUTH	31	St sld	✓	✓	✓	✓	✓	N/A	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St sld	✓	✓	✓	✓	✓	n/a	
LOWER LEVEL SOUTH	34	St sld	✓	✓	✓	✓	✓	n/a	
LOWER LEVEL SOUTH	32	St sld	✓	✓	✓	✓	✓	n/a	
LOWER LEVEL SOUTH	30	St sld	✓	✓	✓	✓	✓	n/a	
LOWER LEVEL SOUTH	28	St sld	✓	✓	✓	✓	✓	n/a	
LOWER LEVEL SOUTH	26	St sld	✓	✓	✓	✓	✓	n/a	
LOWER LEVEL SOUTH	24	St sld	✓	✓	✓	✓	✓	n/a	
LOWER LEVEL SOUTH	22	St sld	✓	✓	✓	✓	✓	n/a	
LOWER LEVEL SOUTH	20	St sld	✓	✓	✓	✓	✓	n/a	
LOWER LEVEL SOUTH	18	St sld	✓	✓	✓	✓	✓	n/a	
LOWER LEVEL SOUTH	16	St sld	✓	✓	✓	✓	✓	n/a	
LOWER LEVEL NORTH	60	St sld	✓	✓	✓	✓	✓	n/a	
LOWER LEVEL NORTH	62	St sld	✓	✓	✓	✓	✓	n/a	
LOWER LEVEL NORTH	62A	St sld	✓	✓	✓	✓	✓	n/a	
LOWER LEVEL NORTH	63	St sld	✓	✓	✓	✓	✓	n/a	
LOWER LEVEL NORTH	64	St sld	✓	✓	✓	✓	✓	n/a	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	65	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL NORTH	66	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL NORTH	67	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL NORTH	68	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL NORTH	69	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL NORTH	70	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL NORTH	71	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	71A	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	72	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	73	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	74	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	75	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	75A	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	76	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	84A	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	85	St sld	✓	✓	✓	✓			see memo

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: 12/5/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	81	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL NORTH	82	St sld	✓	✓	✓	✓	✓	N/A	Made minor rep
LOWER LEVEL NORTH	83	St sld	✓	✓	✓	✓	✓	N/A	
LOWER LEVEL NORTH	84	St sld	✓	✓	✓	✓	✓	N/A	
3rd FL NORTH	301	St sw	✓	✓	✓	✓	✓	N/A	
3rd FL NORTH	302	St sw	✓	✓	✓	✓	✓	N/A	
3rd FL NORTH	303	St sw	✓	✓	✓	✓	✓	N/A	
3rd FL NORTH	304	St sw	✓	✓	✓	✓	✓	N/A	
3rd FL NORTH	305	St sw	✓	✓	✓	✓	✓	N/A	
3rd FL NORTH	306	St sw	✓	✓	✓	✓	✓	N/A	
3rd FL NORTH	307	St sw	✓	✓	✓	✓	✓	N/A	
3rd FL NORTH	308	St sw	✓	✓	✓	✓	✓	N/A	
3rd FL NORTH	309	St sw	✓	✓	✓	✓	✓	N/A	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	St sw	✓	✓	✓	✓	✓	n/a n/a	
3rd FL NORTH	311	St sw	✓	✓	✓	✓	✓	n/a	
3rd FL NORTH	312	St sw	✓	✓	✓	✓	✓	n/a	
3rd FL NORTH	313	St sw	✓	✓	✓	✓	✓	n/a	
3rd FL NORTH	314	St sw	✓	✓	✓	✓	✓	n/a	
3rd FL NORTH	315	St sw	✓	✓	✓	✓	✓	n/a	
3rd FL NORTH	316	St sw	✓	✓	✓	✓	✓	n/a	
3rd FL NORTH	317	St sw	✓	✓	✓	✓	✓	n/a	
3rd FL NORTH	318	St sw	✓	✓	✓	✓	✓	n/a	
3rd FL NORTH	319	St sw	✓	✓	✓	✓	✓	n/a	
3rd FL NORTH	320	St sw	✓	✓	✓	✓	✓	n/a	
3rd FL NORTH	321	St sw	✓	✓	✓	✓	✓	n/a	
3rd FL NORTH	322	St sw	✓	✓	✓	✓	✓	n/a	Secure Panic
3rd FL NORTH	323	St sw	✓	✓	✓	✓	✓	n/a	
3rd FL NORTH	324	St sw	✓	✓	✓	✓	✓	n/a	
3rd FL NORTH	325	St sw	✓	✓	✓	✓	✓	n/a	
3rd FL NORTH	326	St sw	✓	✓	✓	✓	✓	n/a	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St sw	✓	✓	✓	✓	✓	N/A	
4th FL SOUTH	402	St sw	✓	✓	✓	✓	✓		
4th FL SOUTH	403	St sw	✓	✓	✓	✓	✓		
4th FL SOUTH	404	St sw	✓	✓	✓	✓	✓		
4th FL SOUTH	405	St sw	✓	✓	✓	✓	✓		
4th FL SOUTH	406	St sw	✓	✓	✓	✓	✓		
4th FL SOUTH	407	St sw	✓	✓	✓	✓	✓		
4th FL SOUTH	408	St sw	✓	✓	✓	✓	✓		
4th FL SOUTH	409	St sw	✓	✓	✓	✓	✓		
4th FL SOUTH	410	St sw	✓	✓	✓	✓	✓		
4th FL SOUTH	411	St sw	✓	✓	✓	✓	✓		
4th FL SOUTH	412	St sw	✓	✓	✓	✓	✓		
4th FL SOUTH	413	St sw	✓	✓	✓	✓	✓		
4th FL SOUTH	414	St sw	✓	✓	✓	✓	✓		
4th FL SOUTH	415	st sw	✓	✓	✓	✓	✓		
4th FL SOUTH	416	st sw	✓	✓	✓	✓	✓		N/A

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	417	St sw	✓	✓	✓	✓	✓	n/a	
4th FL SOUTH	418	St sw	✓	✓	✓	✓			
4th FL SOUTH	419	St sw	✓	✓	✓	✓			
4th FL SOUTH	420	St sw	✓	✓	✓	✓			
4th FL SOUTH	421	St sw	✓	✓	✓	✓			
LOWER LEV SOUTH	14	ST SLD	✓	✓	✓	✓	✓	n/a	
LOWER LEV SOUTH	12	ST SLD	✓	✓	✓	✓	✓	n/a	
LOWER LEV SOUTH	10	ST SLD	✓	✓	✓	✓	✓	n/a	
LOWER LEV SOUTH	8	ST SLD	✓	✓	✓	✓	✓	n/a	
LOWER LEV SOUTH	6	ST SLD	✓	✓	✓	✓	✓	n/a	
LOWER LEV SOUTH	4	ST SLD	✓	✓	✓	✓	✓	n/a	
LOWER LEV SOUTH	2	ST SLD	✓	✓	✓	✓	✓	n/a	
ROAD WAY EAST	SL1A1	BESAM SLD AMD 1	✓	✓	✓	✓	✓	n/a	
ROAD WAY WEST	SL1A2	BESAM SLD AMD 1	✓	✓	✓	✓	✓	n/a	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
SOUTH WING 9th AVE	SL1R1	h sld	✓	✓	✓	✓	✓		
SOUTH WING 9th AVE	SL1R2	h sld	✓	✓	✓	✓	✓		
SOUTH WING 9th AVE	SL1R3	h revolver	✓	✓	X	X	X	need some repair	will return.
SOUTH WING 9th AVE	SL1R4	h revolver	✓	✓	✓	✓	✓		
41st STREET	S13A1	St sw	✓	✓	✓	✓	✓	N/A	
41st STREET	S13A2	St sw	✓	✓	✓	✓	✓	N/A	
SOUTH WING 8TH AVE	S14A1A	Besam sw	✓	✓	X	X	✓	need repair	will return
SOUTH WING 8TH AVE	S14A1B	Besam sw	✓	✓	✓	✓	✓		
SOUTH WING 8TH AVE	S14A2A	Gt sw	✓	✓	✓	✓	✓		
SOUTH WING 8TH AVE	S14A2B	Gt sw	X	✓	X	X	✓	need repair	will return
SOUTH WING 8TH AVE	S14A3A	Besam sw	✓	✓	✓	✓	✓		
JTH WING 8TH AVE	S14A3B	Besam sw	✓	✓	✓	✓	✓		
SOUTH WING 8TH AVE	S14A4A	Gt sw	✓	✓	✓	✓	✓		
SOUTH WING 8TH AVE	S14A4B	Gt sw	✓	✓	✓	✓	✓		

DOOR AUTOMATION CORP.

DATE: 4/24/16
 PO: _____
 TN: 12-80

*CUSTOMER: U.S. Terminal PMA
 LOCATION: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
<u>2L</u>	<u>South wing</u>	<u>30</u>	<u>Storero</u>	<u>sticker</u>	
<u>2L</u>					
	<u>499</u>	<u>must return with remote control</u>			
<u>03</u>	<u>North wing</u>	<u>308</u>	<u>Storero</u>	<u>swing</u>	
	<u>499</u>	<u>must return with a Picot wall</u>			
		<u>switch</u>			
<u>03</u>	<u>North wing</u>	<u>321</u>	<u>Storero</u>	<u>swing</u>	
<u>505</u>	<u>499</u>	<u>must return with a door track</u>			
		<u>and roller block (410272)(710206)</u>			
<u>01</u>	<u>North wing</u>	<u>N18A18</u>	<u>Person</u>	<u>Swing</u>	
	<u>499</u>	<u>must request to install a new</u>			
		<u>system</u>			

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative tot he Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 8:00 TRUCK #: 370
 ARRIVED HERE: 9:00 NO. OF MEN: 1
 LEFT THIS JOB: 3:00 JOB COMPLETED: YES NO

John MECHANICS CUSTOMER'S SIGNATURE PRINT NAME

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUN

DATE: 11/29/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	3	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	5	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	7	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	9	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	11	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	13	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	15	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	17	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	19	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	21	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	23	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	25	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	27	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	29	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	31	St old	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

D U An

DATE: 11/24/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	34	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	32	St old	✓	✓	✓	✓	✓	yes	mcsl control
LOWER LEVEL SOUTH	30	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	28	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	26	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	24	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	22	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	20	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	18	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	16	St old	✓	✓	✓	✓	✓	no	03545
[REDACTED SECTION]									
LOWER LEVEL NORTH	60	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	62	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	62A	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	63	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	64	St old	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

5/2/07

DATE: 5/2/07

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN	GLOBE	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	65	ST STD							NO
LOWER LEVEL NORTH	66	ST STD							NO
LOWER LEVEL NORTH	67	ST STD							NO
LOWER LEVEL NORTH	68	ST STD							NO
LOWER LEVEL NORTH	69	ST STD							NO
LOWER LEVEL NORTH	70	ST STD							NO
LOWER LEVEL NORTH	71	ST STD							NO
LOWER LEVEL NORTH	71A	ST STD							NO
LOWER LEVEL NORTH	72	ST STD							NO
LOWER LEVEL NORTH	73	ST STD							NO
LOWER LEVEL NORTH	74	ST STD							NO
LOWER LEVEL NORTH	75	ST STD							NO
LOWER LEVEL NORTH	75A	ST STD							NO
LOWER LEVEL NORTH	76	ST STD							NO
LOWER LEVEL NORTH	77A	ST STD							NO
LOWER LEVEL NORTH	78	ST STD							NO
LOWER LEVEL NORTH	79	ST STD							NO
LOWER LEVEL NORTH	80	ST STD							NO
LOWER LEVEL NORTH	81	ST STD							NO
LOWER LEVEL NORTH	82	ST STD							NO
LOWER LEVEL NORTH	83	ST STD							NO
LOWER LEVEL NORTH	84	ST STD							NO
LOWER LEVEL NORTH	85	ST STD							NO
LOWER LEVEL NORTH	86	ST STD							NO
LOWER LEVEL NORTH	87	ST STD							NO
LOWER LEVEL NORTH	88	ST STD							NO
LOWER LEVEL NORTH	89	ST STD							NO
LOWER LEVEL NORTH	90	ST STD							NO
LOWER LEVEL NORTH	91	ST STD							NO
LOWER LEVEL NORTH	92	ST STD							NO
LOWER LEVEL NORTH	93	ST STD							NO
LOWER LEVEL NORTH	94	ST STD							NO
LOWER LEVEL NORTH	95	ST STD							NO
LOWER LEVEL NORTH	96	ST STD							NO
LOWER LEVEL NORTH	97	ST STD							NO
LOWER LEVEL NORTH	98	ST STD							NO
LOWER LEVEL NORTH	99	ST STD							NO
LOWER LEVEL NORTH	100	ST STD							NO

7-11-07

ST

ST STD

PA BUS TERMINAL DOOR MAINT CHECK LIST

Subm

DATE: 11/29/13

REQUIRED REPAIR

COMMENTS

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	81	SI SW							no
LOWER LEVEL NORTH	82	SI SW							no
LOWER LEVEL NORTH	83	SI SW							no
LOWER LEVEL NORTH	84	SI SW							no
3RD FL NORTH	301	SI SW							no
3RD FL NORTH	302	SI SW							no
3RD FL NORTH	303	SI SW							no
3RD FL NORTH	304	SI SW							no
3RD FL NORTH	305	SI SW							no
3RD FL NORTH	306	SI SW							no
3RD FL NORTH	307	SI SW							no
3RD FL NORTH	308	SI SW							no
3RD FL NORTH	309	SI SW							no
3RD FL NORTH	310	SI SW							no
3RD FL NORTH	311	SI SW							no
3RD FL NORTH	312	SI SW							no
3RD FL NORTH	313	SI SW							no
3RD FL NORTH	314	SI SW							no
3RD FL NORTH	315	SI SW							no
3RD FL NORTH	316	SI SW							no
3RD FL NORTH	317	SI SW							no
3RD FL NORTH	318	SI SW							no
3RD FL NORTH	319	SI SW							no
3RD FL NORTH	320	SI SW							no
3RD FL NORTH	321	SI SW							no
3RD FL NORTH	322	SI SW							no
3RD FL NORTH	323	SI SW							no
3RD FL NORTH	324	SI SW							no
3RD FL NORTH	325	SI SW							no
3RD FL NORTH	326	SI SW							no
3RD FL NORTH	327	SI SW							no
3RD FL NORTH	328	SI SW							no
3RD FL NORTH	329	SI SW							no
3RD FL NORTH	330	SI SW							no
3RD FL NORTH	331	SI SW							no
3RD FL NORTH	332	SI SW							no
3RD FL NORTH	333	SI SW							no
3RD FL NORTH	334	SI SW							no
3RD FL NORTH	335	SI SW							no
3RD FL NORTH	336	SI SW							no
3RD FL NORTH	337	SI SW							no
3RD FL NORTH	338	SI SW							no
3RD FL NORTH	339	SI SW							no
3RD FL NORTH	340	SI SW							no
3RD FL NORTH	341	SI SW							no
3RD FL NORTH	342	SI SW							no
3RD FL NORTH	343	SI SW							no
3RD FL NORTH	344	SI SW							no
3RD FL NORTH	345	SI SW							no
3RD FL NORTH	346	SI SW							no
3RD FL NORTH	347	SI SW							no
3RD FL NORTH	348	SI SW							no
3RD FL NORTH	349	SI SW							no
3RD FL NORTH	350	SI SW							no
3RD FL NORTH	351	SI SW							no
3RD FL NORTH	352	SI SW							no
3RD FL NORTH	353	SI SW							no
3RD FL NORTH	354	SI SW							no
3RD FL NORTH	355	SI SW							no
3RD FL NORTH	356	SI SW							no
3RD FL NORTH	357	SI SW							no
3RD FL NORTH	358	SI SW							no
3RD FL NORTH	359	SI SW							no
3RD FL NORTH	360	SI SW							no
3RD FL NORTH	361	SI SW							no
3RD FL NORTH	362	SI SW							no
3RD FL NORTH	363	SI SW							no
3RD FL NORTH	364	SI SW							no
3RD FL NORTH	365	SI SW							no
3RD FL NORTH	366	SI SW							no
3RD FL NORTH	367	SI SW							no
3RD FL NORTH	368	SI SW							no
3RD FL NORTH	369	SI SW							no
3RD FL NORTH	370	SI SW							no
3RD FL NORTH	371	SI SW							no
3RD FL NORTH	372	SI SW							no
3RD FL NORTH	373	SI SW							no
3RD FL NORTH	374	SI SW							no
3RD FL NORTH	375	SI SW							no
3RD FL NORTH	376	SI SW							no
3RD FL NORTH	377	SI SW							no
3RD FL NORTH	378	SI SW							no
3RD FL NORTH	379	SI SW							no
3RD FL NORTH	380	SI SW							no
3RD FL NORTH	381	SI SW							no
3RD FL NORTH	382	SI SW							no
3RD FL NORTH	383	SI SW							no
3RD FL NORTH	384	SI SW							no
3RD FL NORTH	385	SI SW							no
3RD FL NORTH	386	SI SW							no
3RD FL NORTH	387	SI SW							no
3RD FL NORTH	388	SI SW							no
3RD FL NORTH	389	SI SW							no
3RD FL NORTH	390	SI SW							no
3RD FL NORTH	391	SI SW							no
3RD FL NORTH	392	SI SW							no
3RD FL NORTH	393	SI SW							no
3RD FL NORTH	394	SI SW							no
3RD FL NORTH	395	SI SW							no
3RD FL NORTH	396	SI SW							no
3RD FL NORTH	397	SI SW							no
3RD FL NORTH	398	SI SW							no
3RD FL NORTH	399	SI SW							no
3RD FL NORTH	400	SI SW							no

PIVOTS OK

62705

yes
no

PA BUS TERMINAL DOOR MAINT CHECK LIST

J. Am

DATE: 11/29/22

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	311	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	312	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	313	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	314	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	315	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	316	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	317	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	318	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	319	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	320	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	321	St sw	✓	✓	✓	✓	✓	YES 64240	W MUST REPAIR
3rd FL NORTH	322	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	323	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	324	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	325	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	326	St sw	✓	✓	✓	✓	✓	NO	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: 7/

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St ew	✓	✓	✓	✓	✓	no	
4th FL SOUTH	402	St ew	✓	✓	✓	✓	✓	no	
4th FL SOUTH	403	St ew	✓	✓	✓	✓	✓	no	
4th FL SOUTH	404	St ew	✓	✓	✓	✓	✓	no	
4th FL SOUTH	405	St ew	✓	✓	✓	✓	✓	no	
4th FL SOUTH	406	St ew	✓	✓	✓	✓	✓	no	
4th FL SOUTH	407	St ew	✓	✓	✓	✓	✓	no	
4th FL SOUTH	408	St ew	✓	✓	✓	✓	✓	no	
4th FL SOUTH	409	St ew	✓	✓	✓	✓	✓	no	
4th FL SOUTH	410	St ew	✓	✓	✓	✓	✓	no	
4th FL SOUTH	411	St ew	✓	✓	✓	✓	✓	no	
4th FL SOUTH	412	St ew	✓	✓	✓	✓	✓	no	
4th FL SOUTH	413	St ew	✓	✓	✓	✓	✓	no	
4th FL SOUTH	414	St ew	✓	✓	✓	✓	✓	no	
4th FL SOUTH	415	st ew	✓	✓	✓	✓	✓	no	
4th FL SOUTH	416	st ew	✓	✓	✓	✓	✓	no	

FA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
NORTH WING 8th ave	N1E8A1A	Buscarr sw	✓	✓	✓	✓	✓	yes 04185	Request for
NORTH WING 8th ave	N1E8A1B	Buscarr sw	✓	✓	✓	✓	✓	yes 04185	new system
NORTH WING 8th ave	N1E8A2A	Buscarr sw	✓	✓	✓	✓	✓	no	
NORTH WING 8th ave	N1E8A2B	Buscarr sw	✓	✓	✓	✓	✓	no	
NORTH WING 8th ave	N1E8A3A	Buscarr sw	✓	✓	✓	✓	✓	no	
NORTH WING 8th ave	N1E8A3B	Buscarr sw	✓	✓	✓	✓	✓	no	
NORTH WING 8th ave	N1E8A4A	Buscarr sw	✓	✓	✓	✓	✓	no	
NORTH WING 8th ave	N1E8A4B	Buscarr sw	✓	✓	✓	✓	✓	no	
[REDACTED]									
TAXI RD WAY	BT4405	Buscarr sw	✓	✓	✓	✓	✓		
TAXI RD WAY	BT4406	Buscarr sw	✓	✓	✓	✓	✓		

NEED CLOSE

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE: 11/11/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	3	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	5	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	7	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	9	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	11	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	13	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	15	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	17	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	19	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	21	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	23	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	25	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	27	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	29	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	31	St sld	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

Text

DATE: *11/11/13*

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St eld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	34	St eld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	32	St eld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	30	St eld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	28	St eld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	26	St eld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	24	St eld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	22	St eld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	20	St eld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	18	St eld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	16	St eld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	60	St eld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	62	St eld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	62A	St eld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	63	St eld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	64	St eld	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

Sun

DATE: 11/11/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	65	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	66	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	67	St sld						yes 1/4 PSI Guide	
LOWER LEVEL NORTH	68	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	69	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	70	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	71	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	71A	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	72	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	73	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	74	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	75	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	75A	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	76	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	84A	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	85	St sld	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUH

DATE: 11/11/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	81	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	82	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	83	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	84	St sld	✓	✓	✓	✓	✓	no	
1rd FL NORTH	301	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	302	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	303	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	304	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	305	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	306	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	307	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	308	St sw	✓	✓	✓	✓	✓	no	
1rd FL NORTH	309	St sw	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

Sum

DATE: *11/11/13*

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	311	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	312	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	313	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	314	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	315	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	316	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	317	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	318	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	319	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	320	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	321	St sw	✓	✓	✓	✓	✓	yes ^{Arm} secure track	
3rd FL NORTH	322	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	323	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	324	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	325	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	326	St sw	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

5/2/13

DATE: 4/11/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	402	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	403	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	404	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	405	St sw							
4th FL SOUTH	406	St sw	✓	✓	✓	✓	✓	yes n/w fix replace control	
4th FL SOUTH	407	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	408	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	409	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	410	St sw							
4th FL SOUTH	411	St sw	✓	✓	✓	✓	✓	yes n/w most return wire	with magic for
4th FL SOUTH	412	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	413	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	414	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	415	st sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	416	st sw	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

Sun

DATE: 4/2/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	417	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	418	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	419	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	420	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	421	St sw	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	14	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	12	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	10	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	8	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	6	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	4	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	2	ST SLD	✓	✓	✓	✓	✓	no	
ROAD WAY EAST	SL1A1	BESAM SLD AMD 1	✓	✓	✓	✓	✓	no	
ROAD WAY WEST	SL1A2	BESAM SLD AMD 1	✓	✓	✓	✓	✓	no	

DOOR AUTOMATION CORP.

DATE: 10/2/0

CUSTOMER: CSUS Terminal

PO: _____

LOCATION: _____

TN: 14019

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
2L	South wing	3		Standard	Swing
1999 must return with a 2/14					
03	North wing	317		Standard	Swing
1999 must return with a new inner door wall switch					
04	South wing	403		Standard	Swing
1999 must return with a new MC 571 control					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 7:00
 ARRIVED HERE: 8:00
 LEFT THIS JOB: 1:30

TRUCK #: 320
 NO. OF MEN: 1
 JOB COMPLETED: YES NO

MECHANICS: John CUSTOMER'S SIGNATURE: _____ PRINT NAME: _____

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: 10/7/13

JUN

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	3	St sld	✓	✓	✓	✓	✓	yes	03561
LOWER LEVEL SOUTH	5	St sld	✓	✓	✓	✓	✓	no	R/H Guide
LOWER LEVEL SOUTH	7	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	9	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	11	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	13	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	15	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	17	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	19	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	21	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	23	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	25	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	27	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	29	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	31	St sld	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE: 10/7/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	34	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	32	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	30	St sld	✓	✓	✓	✓	✓	no	
OWER LEVEL SOUTH	28	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	26	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	24	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	22	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	20	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	18	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	16	St sld	✓	✓	✓	✓	✓	no	
REPAIRED									
LOWER LEVEL NORTH	60	St sld							
LOWER LEVEL NORTH	62	St sld							
LOWER LEVEL NORTH	62A	St sld							
LOWER LEVEL NORTH	63	St sld							
LOWER LEVEL NORTH	64	St sld							

03545

PA BUS TERMINAL DOOR MAINT CHECK LIST

Juan

DATE: ~~10/22/13~~ 10/27/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	65	St sld							
LOWER LEVEL NORTH	66	St sld							
LOWER LEVEL NORTH	67	St sld							
LOWER LEVEL NORTH	68	St sld							
LOWER LEVEL NORTH	69	St sld							
LOWER LEVEL NORTH	70	St sld							
LOWER LEVEL NORTH	71	St sld							
LOWER LEVEL NORTH	71A	St sld							
LOWER LEVEL NORTH	72	St sld							
LOWER LEVEL NORTH	73	St sld							
LOWER LEVEL NORTH	74	St sld							
LOWER LEVEL NORTH	75	St sld							
LOWER LEVEL NORTH	75A	St sld							
LOWER LEVEL NORTH	76	St sld							
LOWER LEVEL NORTH	84A	St sld							
LOWER LEVEL NORTH	85	St sld							
1 - L North	78	St sld							

PA BUS TERMINAL DOOR MAINT CHECK LIST

S. Adams

DATE: 10/7/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	81	St sld							
LOWER LEVEL NORTH	82	St sld							
LOWER LEVEL NORTH	83	St sld							
LOWER LEVEL NORTH	84	St sld							
[REDACTED SECTION]									
3rd FL NORTH	301	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	302	St sw	✓	✓	✓	✓	✓	yes	ROUTE PW
3rd FL NORTH	303	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	304	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	305	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	306	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	307	St sw	✓	✓	✓	✓	✓	no	
4 FL NORTH	308	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	309	St sw	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE: 10/7/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	311	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	312	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	313	St sw	✓	✓	✓	✓	no		
3rd FL NORTH	314	St sw	✓	✓	✓	✓	no		
3rd FL NORTH	315	St sw	✓	✓	✓	✓	no		
3rd FL NORTH	316	St sw	✓	✓	✓	✓	no		
3rd FL NORTH	317	St sw	✓	✓	✓	✓	yes	01757 INVALID PWS	
3rd FL NORTH	318	St sw	✓	✓	✓	✓	no		
3rd FL NORTH	319	St sw	✓	✓	✓	✓	no		
3rd FL NORTH	320	St sw	✓	✓	✓	✓	no		
3rd FL NORTH	321	St sw	✓	✓	✓	✓	no		
3rd FL NORTH	322	St sw	✓	✓	✓	✓	no		
3rd FL NORTH	323	St sw	✓	✓	✓	✓	no		
3rd FL NORTH	324	St sw	✓	✓	✓	✓	no		
3rd FL NORTH	325	St sw	✓	✓	✓	✓	no		
3rd FL NORTH	326	St sw	✓	✓	✓	✓	no		

PA BUS TERMINAL DOOR MAINT CHECK LIST

JEAN

DATE: *7/10/7/13*

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	402	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	403	St sw	✓	✓	✓	✓	✓	YES	control ⁸³⁴⁹⁰
4th FL SOUTH	404	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	405	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	406	St sw	✓	✓	✓	✓	✓	N.O	
4th FL SOUTH	407	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	408	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	409	St sw	✓	✓	✓	✓	✓	YES	outer pins ⁰⁴²⁸⁰
4th FL SOUTH	410	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	411	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	412	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	413	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	414	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	415	st sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	416	st sw	✓	✓	✓	✓	✓	NO	

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUL

DATE: *10/5/13*

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	417	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	418	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	419	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	420	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	421	St sw	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	14	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	12	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	10	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	8	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	6	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	4	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	2	ST SLD	✓	✓	✓	✓	✓	no	
ROAD WAY EAST	SL1A1	BESAM SLD AMD 1	✓	✓	✓	✓	✓	no	
ROAD WAY WEST	SL1A2	BESAM SLD AMD 1	✓	✓	✓	✓	✓	no	

DOOR AUTOMATION CORP.

DATE: 10/2/20

CUSTOMER: John [unclear]

PO: 1

LOCATION: [unclear]

TN: 15112

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
66	Southwing	66	Stanley	Slide	
499 must return with a [unclear] bottom					
66	Southwing	6	Stanley	Slide	
499 must return with a [unclear] bottom					
66	Southwing	10	Stanley	Slide	
499 must return with a [unclear] bottom					
66	Southwing	38	Stanley	Slide	
499 must return with a [unclear] bottom					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative tot he Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 700

TRUCK #: 370

ARRIVED HERE: 800

NO. OF MEN: 1

LEFT THIS JOB: 1:45

JOB COMPLETED: YES NO

MECHANICS

CUSTOMER'S SIGNATURE

PRINT NAME

PA BUS TERMINAL DOOR MAINT CHECK LIST

JULY

DATE: 10/23/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	3	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	5	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	7	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	9	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	11	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	13	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	15	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	17	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	19	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	21	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	23	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	25	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	27	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	29	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	31	St old	✓	✓	✓	✓	✓	no	

PUBLIC TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	34	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	32	St old	✓	✓	✓	✓	✓	yes	Break away switch 03212
LOWER LEVEL SOUTH	30	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	28	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	26	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	24	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	22	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	20	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	18	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	16	St old	✓	✓	✓	✓	✓	no	03545
REMOVED									
LOWER LEVEL NORTH	01	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	02	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	02A	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	03	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	04	St old	✓	✓	✓	✓	✓	no	

PARADE TERMINAL DOOR MAINT CHECK LIST

Jubn

DATE: 10/23/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	66	St old	✓	✓	✓	✓	✓	no	L/A Bottom Guide 04252
LOWER LEVEL NORTH	68	St old						Yes	
LOWER LEVEL NORTH	67	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	69	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	68	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	70	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	71	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	71A	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	72	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	73	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	74	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	75	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	75A	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	76	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	84A	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	85	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH			✓	✓	✓	✓	✓	no	

PA LOS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	81	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	82	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	83	St old	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	84	St old	✓	✓	✓	✓	✓	no	
3rd FL NORTH	301	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	302	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	303	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	304	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	305	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	306	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	307	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	308	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	309	St sw	✓	✓	✓	✓	✓	no	

PALM BUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE: 10/23/13

LOCATION	DOOR #	TYPE	AGT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	Stow	✓	✓	✓	✓	✓	no	
3rd FL NORTH	311	Stow	✓	✓	✓	✓	✓	no	
3rd FL NORTH	312	Stow	✓	✓	✓	✓	✓	no	
3rd FL NORTH	313	Stow	✓	✓	✓	✓	✓	no	
3rd FL NORTH	314	Stow	✓	✓	✓	✓	✓	no	
3rd FL NORTH	315	Stow	✓	✓	✓	✓	✓	no	
3rd FL NORTH	316	Stow	✓	✓	✓	✓	✓	no	
3rd FL NORTH	317	Stow	✓	✓	✓	✓	✓	no	
3rd FL NORTH	318	Stow	✓	✓	✓	✓	✓	no	
3rd FL NORTH	319	Stow	✓	✓	✓	✓	✓	no	
3rd FL NORTH	320	Stow	✓	✓	✓	✓	✓	no	
3rd FL NORTH	321	Stow	✓	✓	✓	✓	✓	no	
3rd FL NORTH	322	Stow	✓	✓	✓	✓	✓	no	
3rd FL NORTH	323	Stow	✓	✓	✓	✓	✓	no	
3rd FL NORTH	324	Stow	✓	✓	✓	✓	✓	no	
3rd FL NORTH	325	Stow	✓	✓	✓	✓	✓	no	
3rd FL NORTH	326	Stow	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUTR

DATE: 7/10/23/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	402	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	403	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	404	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	405	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	406	St sw	✓	✓	✓	✓	✓	n.o	
4th FL SOUTH	407	St sw	✓	✓	✓	✓	✓	yes	OUTER PWS
4th FL SOUTH	408	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	409	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	410	St sw	✓	✓	✓	✓	✓	n.o	
4th FL SOUTH	411	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	412	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	413	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	414	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	415	st sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	416	st sw	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

Scan

DATE: 10/25/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	417	ST SW	/	/	/	/	/	NO	
4th FL SOUTH	418	ST SW	/	/	/	/	/	NO	
4th FL SOUTH	419	ST SW	/	/	/	/	/	NO	
4th FL SOUTH	420	ST SW	/	/	/	/	/	NO	
4th FL SOUTH	421	ST SW	/	/	/	/	/	NO	
LOWER LEV SOUTH	14	ST SLD	/	/	/	/	/	NO	
LOWER LEV SOUTH	12	ST SLD	/	/	/	/	/	NO	
LOWER LEV SOUTH	10	ST SLD	/	/	/	/	/	NO	W/A bottom Guide 0437
LOWER LEV SOUTH	8	ST SLD	/	/	/	/	/	NO	
LOWER LEV SOUTH	6	ST SLD	/	/	/	/	/	NO	Must return 0437
LOWER LEV SOUTH	4	ST SLD	/	/	/	/	/	NO	
LOWER LEV SOUTH	2	ST SLD	/	/	/	/	/	NO	
ROAD WAY EAST	31A1	BRKAM SLD	/	/	/	/	/	NO	
ROAD WAY WEST	31A2	BRKAM SLD	/	/	/	/	/	NO	

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE 10/23/15

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
SOUTH WING 9TH AVE	SL1R1	h slid	✓	✓	✓	✓	✓	no	
SOUTH WING 9TH AVE	SL1R2	h slid	✓	✓	✓	✓	✓	no	
SOUTH WING 9TH AVE	SL1R3	h revolver	✓	✓	✓	✓	✓	no	
SOUTH WING 9TH AVE	SL1R4	h revolver	✓	✓	✓	✓	✓	no	
41st STREET	S13A1	St sw	✓	✓	✓	✓	✓	no	
41st STREET	S13A2	St sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A1A	Boom sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A1B	Boom sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A2A	Cl sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A2B	Cl sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A3A	Boom sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A3B	Boom sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A4A	Cl sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A4B	Cl sw	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUN

DATE: 10/23/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
NORTH WING 8th ave	N1BA1A	Bosch sw	✓	✓	✓	✓	✓	no	
NORTH WING 8th ave	N1BA1B	Bosch sw	✓	✓	✓	✓	✓	no	
NORTH WING 8th ave	N1BA2A	Bosch sw	✓	✓	✓	✓	✓	no	
NORTH WING 8th ave	N1BA2B	Bosch sw	✓	✓	✓	✓	✓	no	
NORTH WING 8th ave	N1BA3A	Bosch sw	✓	✓	✓	✓	✓	no	
NORTH WING 8th ave	N1BA3B	Bosch sw	✓	✓	✓	✓	✓	no	
NORTH WING 8th ave	N1BA4A	Bosch sw	✓	✓	✓	✓	✓	no	
NORTH WING 8th ave	N1BA4B	Bosch sw	✓	✓	✓	✓	✓	no	
TAXI RD WAY	BT4435	Bosch sw							
TAXI RD WAY	BT4436	Bosch sw							

Handwritten note: *Handwritten: Bosch Close*

PA BUS TERMINAL DOOR MAINT CHECK LIST

2/28/15

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St sld	/	/	/	/	/	NV	
LOWER LEVEL SOUTH	34	St sld	/	/	/	/	/	NV	
LOWER LEVEL SOUTH	32	St sld	/	/	/	/	/	NV	
LOWER LEVEL SOUTH	30	St sld	/	/	/	/	/	NV	
LOWER LEVEL SOUTH	28	St sld	/	/	/	/	/	NV	
LOWER LEVEL SOUTH	26	St sld	/	/	/	/	/	NV	
LOWER LEVEL SOUTH	24	St sld	/	/	/	/	/	NV	
LOWER LEVEL SOUTH	22	St sld	/	/	/	/	/	NV	
LOWER LEVEL SOUTH	20	St sld	/	/	/	/	/	NV	
LOWER LEVEL SOUTH	18	St sld	/	/	/	/	/	NV	
LOWER LEVEL SOUTH	16	St sld	/	/	/	/	/	NV	
LOWER LEVEL NORTH	60	St sld	/	/	/	/	/	NV	
LOWER LEVEL NORTH	62	St sld	/	/	/	/	/	NV	
LOWER LEVEL NORTH	62A	St sld	/	/	/	/	/	NV	
LOWER LEVEL NORTH	63	St sld	/	/	/	/	/	NV	
LOWER LEVEL NORTH	64	St sld	/	/	/	/	/	NV	

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE: 11/22/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	65	St sld	/	/	/	/	/	NO	
LOWER LEVEL NORTH	66	St sld	/	/	/	/	/	NO	
LOWER LEVEL NORTH	67	St sld	/	/	/	/	/	NO	
LOWER LEVEL NORTH	68	St sld	/	/	/	/	/	NO	
LOWER LEVEL NORTH	69	St sld	/	/	/	/	/	NO	
LOWER LEVEL NORTH	70	St sld	/	/	/	/	/	NO	
LOWER LEVEL NORTH	71	St sld	/	/	/	/	/	YES	RP Stan Do guides 55
LOWER LEVEL NORTH	71A	St sld	/	/	/	/	/	NO	
LOWER LEVEL NORTH	72	St sld	/	/	/	/	/	NO	
LOWER LEVEL NORTH	73	St sld	/	/	/	/	/	YES	Bo guide in 51-52
LOWER LEVEL NORTH	74	St sld	/	/	/	/	/	NO	
LOWER LEVEL NORTH	75	St sld	/	/	/	/	/	NO	
LOWER LEVEL NORTH	75A	St sld	/	/	/	/	/	NO	
LOWER LEVEL NORTH	76	St sld	/	/	/	/	/	NO	
LOWER LEVEL NORTH	84A	St sld	/	/	/	/	/	NO	
LOWER LEVEL NORTH	85	St sld	/	/	/	/	/	NO	
C-L North	78	St sld	/	/	/	/	/	NO	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	81	St sld	/	/	/	/	/	NO	
LOWER LEVEL NORTH	82	St sld	/	/	/	/	/	NO	
LOWER LEVEL NORTH	83	St sld	/	/	/	/	/	NO	
LOWER LEVEL NORTH	84	St sld	/	/	/	/	/	NO	
3rd FL NORTH	301	St sw	/	/	/	/	/	NO	
3rd FL NORTH	302	St sw	/	/	/	/	/	NO	
3rd FL NORTH	303	St sw	/	/	/	/	/	NO	
3rd FL NORTH	304	St sw	/	/	/	/	/	NO	
3rd FL NORTH	305	St sw	/	/	/	/	/	NO	
3rd FL NORTH	306	St sw	/	/	/	/	/	NO	
3rd FL NORTH	307	St sw	/	/	/	/	/	NO	
3rd FL NORTH	308	St sw	/	/	/	/	/	NO	
3rd FL NORTH	309	St sw	/	/	/	/	/	NO	

PA BUS TERMINAL, DOOR MAINT CHECK LIST

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	St sw	/	/	/	/	/	NO	
3rd FL NORTH	311	St sw	/	/	/	/	/	NO	
3rd FL NORTH	312	St sw	/	/	/	/	/	NO	
3rd FL NORTH	313	St sw	/	/	/	/	/	NO	
3rd FL NORTH	314	St sw	/	/	/	/	/	NO	
3rd FL NORTH	315	St sw	/	/	/	/	/	NO	
3rd FL NORTH	316	St sw	/	/	/	/	/	NO	
3rd FL NORTH	317	St sw	/	/	/	/	/	NO	
3rd FL NORTH	318	St sw	/	/	/	/	/	NO	
3rd FL NORTH	319	St sw	/	/	/	/	/	NO	
3rd FL NORTH	320	St sw	/	/	/	/	/	NO	
3rd FL NORTH	321	St sw	/	/	/	/	/	NO	
3rd FL NORTH	322	St sw	/	/	/	/	/	NO	
3rd FL NORTH	323	St sw	/	/	/	/	/	NO	
3rd FL NORTH	324	St sw	/	/	/	/	/	NO	
3rd FL NORTH	325	St sw	/	/	/	/	/	NO	
3rd FL NORTH	326	St sw	/	/	/	/	/	NO	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: 7/

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St sw	/	/	/	/	/		
4th FL SOUTH	402	St sw	/	/	/	/	/		
4th FL SOUTH	403	St sw	/	/	/	/	/		
4th FL SOUTH	404	St sw	/	/	/	/	/		
4th FL SOUTH	405	St sw	/	/	/	/	/		
4th FL SOUTH	406	St sw	/	/	/	/	/		
4th FL SOUTH	407	St sw	/	/	/	/	/		
4th FL SOUTH	408	St sw	/	/	/	/	/		
4th FL SOUTH	409	St sw	/	/	/	/	/		
4th FL SOUTH	410	St sw	/	/	/	/	/		
4th FL SOUTH	411	St sw	/	/	/	/	/		
4th FL SOUTH	412	St sw	/	/	/	/	/		
4th FL SOUTH	413	St sw	/	/	/	/	/		
4th FL SOUTH	414	St sw	/	/	/	/	/		
4th FL SOUTH	415	st sw	/	/	/	/	/		
4th FL SOUTH	416	st sw	/	/	/	/	/		

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	417	St sw	/	/	/	/	/		
4th FL SOUTH	418	St sw	/	/	/	/	/		
4th FL SOUTH	419	St sw	/	/	/	/	/		
4th FL SOUTH	420	St sw	/	/	/	/	/		
4th FL SOUTH	421	St sw	/	/	/	/	/		
LOWER LEV SOUTH	14	ST SLD	/	/	/	/	/		
LOWER LEV SOUTH	12	ST SLD	/	/	/	/	/		
LOWER LEV SOUTH	10	ST SLD	/	/	/	/	/		
LOWER LEV SOUTH	8	ST SLD	/	/	/	/	/		
LOWER LEV SOUTH	6	ST SLD	/	/	/	/	/		
LOWER LEV SOUTH	4	ST SLD	/	/	/	/	/		
LOWER LEV SOUTH	2	ST SLD	/	/	/	/	/		
ROAD WAY EAST	SL1A1	BESAM SLD AMD 1	/	/	/	/	/		
ROAD WAY WEST	SL1A2	BESAM SLD AMD 1	/	/	/	/	/		

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
OUTH WING 9th AVE	SL1R1	h sld							
OUTH WING 9th AVE	SL1R2	h sld							
OUTH WING 9th AVE	SL1R3	h revolver							
OUTH WING 9th AVE	SL1R4	h revolver							
41st STREET	S13A1	St sw							
41st STREET	S13A2	St sw							
OUTH WING 8TH AVE	S14A1A	Besam sw							
OUTH WING 8TH AVE	S14A1B	Besam sw							
OUTH WING 8TH AVE	S14A2A	Gt sw							
OUTH WING 8TH AVE	S14A2B	Gt sw							
OUTH WING 8TH AVE	S14A3A	Besam sw							
OUTH WING 8TH AVE	S14A3B	Besam sw							
OUTH WING 8TH AVE	S14A4A	Gt sw							
OUTH WING 8TH AVE	S14A4B	Gt sw							

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
NORTH WING 8th ave	N1BA1A	Besam SW	/	/	/	/	/		
NORTH WING 8th ave	N1BA1B	Besam SW	/	/	/	/	/		
NORTH WING 8th ave	N1BA2A	Besam SW	/	/	/	/	/		Personnel door
NORTH WING 8th ave	N1BA2B	Besam SW	/	/	/	/	/		
TH WING 8th ave	N1BA3A	Besam SW	/	/	/	/	/		
NORTH WING 8th ave	N1BA3B	Besam SW	/	/	/	/	/		
NORTH WING 8th ave	N1BA4A	Besam SW	/	/	/	/	/		
NORTH WING 8th ave	N1BA4B	Besam SW	/	/	/	/	/		
TAXI RD WAY	BT4405	Besam SW	/	/	/	/	/		
TAXI RD WAY	BT4406	Besam SW	/	/	/	/	/		Close

N1BA1A Close
 N1BA1B Close

DOOR AUTOMATION CORP.

DATE: _____

PO: _____

TN: _____

CUSTOMER: Blue form, inc

LOCATION: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
<u>703 # 93561</u>					
<u>site of shuttle station</u>					
<u>no work needed</u>					
<u>ticket area on VBI</u>					
<u>down</u>					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 1000

TRUCK #: _____

ARRIVED HERE: 1115

NO. OF MEN: 2

LEFT THIS JOB: 1130

JOB COMPLETED: YES NO

Mark W. [Signature]

MECHANICS

CUSTOMER'S SIGNATURE

PRINT NAME

DOOR AUTOMATION CORP.

DATE: 7/2/77

CUSTOMER: Bus & ...

PO: _____

LOCATION: _____

TN: 104735

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
10	South Wing	415	Stanley	swing	DA
499 must operate with a micro staff					
01	South Wing	514	Stanley	swing	DA
499 must operate with a micro staff					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative tot he Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 7 06
 ARRIVED HERE: 8 00
 LEFT THIS JOB: 2:30

TRUCK #: 300
 NO. OF MEN: 1
 JOB COMPLETED: YES NO

MECHANICS _____ CUSTOMER'S SIGNATURE _____ PRINT NAME _____

DOOR AUTOMATION CORP.

DATE: 9/27/12
 PO: _____
 TN: 14995

CUSTOMER: Bar Terminal P.M.
 LOCATION: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
LL South wing		11	Stanley	Slide	
499 must return with a/b/b battery					
LL South wing		34	Stanley	Slide	
499 must return with a/b/b battery					
LL South wing		30	Stanley	Slide	
499 must return with a/b/b battery					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 7:00 TRUCK #: _____

ARRIVED HERE: 8:00 NO. OF MEN: _____

LEFT THIS JOB: 2:30 JOB COMPLETED: YES NO

MECHANICS: _____ CUSTOMER'S SIGNATURE: _____ PRINT NAME: _____

2nd PM

PA BUS TERMINAL DOOR MAINT CHECK LIST

Joan

DATE: 9/23/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	Stald	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	3	Stald	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	5	Stald	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	7	Stald	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	9	Stald	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	11	Stald	✓	✓	✓	✓	✓	yes	04647 Re/H 667 on Guide
LOWER LEVEL SOUTH	13	Stald	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	15	Stald	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	17	Stald	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	19	Stald	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	21	Stald	✓	✓	✓	✓	✓	yes	04610 Re/H 667 on Guide
LOWER LEVEL SOUTH	23	Stald	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	25	Stald	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	27	Stald	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	29	Stald	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	31	Stald	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: 9/23/13

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	SI SID	/	/	/	/	/		
LOWER LEVEL SOUTH	34	SI SID	/	/	/	/	/		02742
LOWER LEVEL SOUTH	32	SI SID	/	/	/	/	/		02742 R/H bottom Cu
LOWER LEVEL SOUTH	30	SI SID	/	/	/	/	/		02745 R/H bottom Cu
LOWER LEVEL SOUTH	28	SI SID	/	/	/	/	/		
LOWER LEVEL SOUTH	26	SI SID	/	/	/	/	/		
LOWER LEVEL SOUTH	24	SI SID	/	/	/	/	/		
LOWER LEVEL SOUTH	22	SI SID	/	/	/	/	/		
LOWER LEVEL SOUTH	20	SI SID	/	/	/	/	/		
LOWER LEVEL SOUTH	18	SI SID	/	/	/	/	/		
LOWER LEVEL SOUTH	16	SI SID	/	/	/	/	/		
LOWER LEVEL NORTH	60	SI SID	/	/	/	/	/		
LOWER LEVEL NORTH	62	SI SID	/	/	/	/	/		
LOWER LEVEL NORTH	62A	SI SID	/	/	/	/	/		
LOWER LEVEL NORTH	63	SI SID	/	/	/	/	/		
LOWER LEVEL NORTH	64	SI SID	/	/	/	/	/		

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE: ~~1/22/13~~ 9/23/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	65	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	66	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	67	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	68	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	69	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	70	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	71	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	71A	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	72	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	73	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	74	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	75	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	75A	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	76	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	84A	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	85	St sld	✓	✓	✓	✓	✓	no	
LL North	78	st sld						yes	03471 OL/H bottom GULD
	79	st sld						yes	MC 521 CONTR 02707

PA BUS TERMINAL DOOR MAINT CHECK LIST

Sean

DATE: *9/23/13*

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	81	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	82	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	83	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	84	St sld	✓	✓	✓	✓	✓	no	
[REDACTED]									
3rd FL NORTH	301	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	302	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	303	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	304	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	305	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	306	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	307	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	308	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	309	St sw	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

Seah

DATE: 9/23/13

LOCATION	DOOR #	TYPE	AGT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	311	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	312	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	313	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	314	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	315	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	316	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	317	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	318	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	319	St sw				✓		yes	outer Press wall ⁰⁴²⁰¹
3rd FL NORTH	320	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	321	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	322	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	323	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	324	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	325	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	326	St sw	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

50m

DATE: 7/23/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	402	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	403	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	404	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	405	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	406	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	407	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	408	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	409	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	410	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	411	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	412	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	413	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	414	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	415	st sw	✓	✓	✓	✓	✓	yes	O/H operator
4th FL SOUTH	416	st sw	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

FL-300m

DATE: *9/25/13*

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	417	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	418	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	419	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	420	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	421	St sw	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	14	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	12	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	10	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	8	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	6	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	4	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	2	ST SLD	✓	✓	✓	✓	✓	no	
ROAD WAY EAST	SL1A1	BESAM SLD AMD 1	✓	✓	✓	✓	✓	no	
ROAD WAY WEST	SL1A2	BESAM SLD AMD 1	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

EWAN

DATE: 9/20/03

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
DUTH WING 9th AVE	SL1R1	h slid	/	/	/	/	/	no	
DUTH WING 9th AVE	SL1R2	h slid	/	/	/	/	/	no	
DUTH WING 9th AVE	SL1R3	h revolver	/	/	/	/	/	no	
DUTH WING 9th AVE	SL1R4	h revolver	/	/	/	/	/	no	
41st STREET	S13A1	St SW	/	/	/	/	/		
41st STREET	S13A2	St SW	/	/	/	/	/		
DUTH WING 8th AVE	S14A1A	Booram SW	/	/	/	/	/	no	
DUTH WING 8th AVE	S14A1B	Booram SW	/	/	/	/	/	no	
DUTH WING 8th AVE	S14A2A	GI SW	/	/	/	/	/	no	
DUTH WING 8th AVE	S14A2B	GI SW	/	/	/	/	/	no	
DUTH WING 8th AVE	S14A3A	Booram SW	/	/	/	/	/	no	
DUTH WING 8th AVE	S14A3B	Booram SW	/	/	/	/	/	no	
DUTH WING 8th AVE	S14A4A	GI SW	/	/	/	/	/	no	SENSOR
DUTH WING 8th AVE	S14A4B	GI SW	/	/	/	/	/	no	

DOOR AUTOMATION CORP.

DATE: _____

CUSTOMER: _____

PO: _____

LOCATION: Bus Terminal

TN: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
<u>01</u>	<u>01</u>	<u>339</u>			
<u>01 9th vs. guttering of Board</u>					
<u>with</u>					
<u>to be seen (dry) control</u>					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: _____

TRUCK #: _____

ARRIVED HERE: 2:00

NO. OF MEN: 2

LEFT THIS JOB: 2:30

JOB COMPLETED: YES NO

Armando Lopez
MECHANICS

Richard Oaks
CUSTOMER'S SIGNATURE

Richard Oaks
PRINT NAME

PA BUS TERMINAL DOOR MAINT CHECK LIST

Charles

DATE: 8/24/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	St sld	✓					no	
LOWER LEVEL SOUTH	3	St sld	X	✓	✓	✓	✓	yes	inferior need a eagle sensor
LOWER LEVEL SOUTH	5	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	7	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	9	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	11	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL SOUTH	13	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL SOUTH	15	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL SOUTH	17	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL SOUTH	19	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL SOUTH	21	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL SOUTH	23	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL SOUTH	25	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL SOUTH	27	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL SOUTH	29	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL SOUTH	31	St sld	✓	✓	✓	✓	✓		

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	34	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	32	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	30	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	28	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	26	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	24	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	22	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	20	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	18	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	16	St sld	✓	✓	✓	✓	✓	no	03545
[REDACTED SECTION]									
LOWER LEVEL NORTH	60	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	62	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	62A	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	63	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	64	St sld	✓	✓	✓	✓	✓		

PA BUS TERMINAL DOOR MAINT CHECK LIST

Juan

DATE: 11/22/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	65	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	66	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	67	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	68	St sld	✓	✓	✓	✓	✓		Broken Glass
LOWER LEVEL NORTH	69	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	70	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	71	St sld	✓	✓	✓	✓	X		Need stanley R Guide RH
LOWER LEVEL NORTH	71A	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	72	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	73	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	74	St sld	✓	✓	✓	✓	✓	Fixed	was off track
LOWER LEVEL NORTH	75	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	75A	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	76	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	84A	St sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	85	St sld	✓	✓	✓	✓	✓		
CL North	88	St sld	✓	✓	✓	✓	✓		

77
79

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	81	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	82	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	83	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	84	St sld	✓	✓	✓	✓	✓	no	
[REDACTED]									
3rd FL NORTH	301	St sw	✓	✓	✓	✓	✓	yes	need starter, Travel Block
3rd FL NORTH	302	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	303	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	304	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	305	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	306	St sw	✓	✓	✓	✓	✓	no	
3rd FL NORTH	307	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	308	St sw	✓	✓	✓	✓	✓		need starter, Travel Block
3rd FL NORTH	309	St sw	✓	✓	✓	✓	✓		

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	311	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	312	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	313	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	314	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	315	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	316	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	317	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	318	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	319	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	320	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	321	St sw	✓	✓	✓	✓	✓		
1rd FL NORTH	322	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	323	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	324	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	325	St sw	✓	✓	✓	✓	✓		
3rd FL NORTH	326	St sw	✓	✓	✓	✓	✓		

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: 7/1

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	402	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	403	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	404	St sw	X	✓	X	X	✓	yes	Door stops and GV
h FL SOUTH	405	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	406	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	407	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	408	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	409	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	410	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	411	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	412	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	413	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	414	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	415	st sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	416	st sw	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL, DOOR MAINT CHECK LIST

Charles

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	417	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	418	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	419	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	420	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	421	St sw	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	14	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	12	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	10	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	8	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	6	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	4	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	2	ST SLD	✓	✓	✓	✓	✓	no	
ROAD WAY EAST	SL1A1	BESAM SLD AMD 1	✓	✓	✓	✓	✓	no	
ROAD WAY WEST	SL1A2	BESAM SLD AMD 1	✓	✓	✓	✓	✓	no	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
OUTH WING 9th AVE	SL1R1	h sld	✓	✓	✓	✓	✓	no	MISSING BENCHER COVER
OUTH WING 9th AVE	SL1R2	h sld	✓	✓	✓	✓	✓	no	
OUTH WING 9th AVE	SL1R3	h revolver	✓	✓	✓	✓	✓	no	
OUTH WING 9th AVE	SL1R4	h revolver	✓	✓	✓	✓	✓	no	
41st STREET	S13A1	St sw	✓	✓	✓	✓	✓	no	
41st STREET	S13A2	St sw	✓	✓	✓	✓	✓	no	
OUTH WING 8TH AVE	S14A1A	Besam sw	✓	✓	✓	✓	✓	no	
OUTH WING 8TH AVE	S14A1B	Besam sw	✓	✓	✓	✓	✓	no	
OUTH WING 8TH AVE	S14A2A	Record Gt sw	✓	✓	✓	✓	✓	no	
OUTH WING 8TH AVE	S14A2B	Gt sw	✓	✓	✓	✓	✓	no	
OUTH WING 8TH AVE	S14A3A	Besam sw	✓	✓	✓	✓	✓	yes	slow to react
OUTH WING 8TH AVE	S14A3B	Besam sw	✓	✓	✓	✓	✓	no	
OUTH WING 8TH AVE	S14A4A	Gt sw	✓	✓	✓	✓	✓	no	
OUTH WING 8TH AVE	S14A4B	Gt sw	✓	✓	✓	✓	✓	no	

8/3

PA BUS TERMINAL DOOR MAINT CHECK LIST

T/N 14361

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	St sld	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	3	St sld	/	YES	/	/	/	NEEDS -MICRO STAR.	
LOWER LEVEL SOUTH	5	St sld	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	7	St sld	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	9	St sld	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	11	St sld	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	13	St sld	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	15	St sld	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	17	St sld	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	19	St sld	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	21	St sld	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	23	St sld	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	25	St sld	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	27	St sld	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	29	St sld	/	/	/	/	/	NO	
LOWER LEVEL SOUTH	31	St sld	/	/	/	/	/	NO	

Jon Gahr

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St sid	/	/	/	/	/		No
LOWER LEVEL SOUTH	34	St sid	/	/	/	/	/		No
LOWER LEVEL SOUTH	32	St sid	/	/	/	/	/		No
LOWER LEVEL SOUTH	30	St sid	/	/	/	/	/		No
LOWER LEVEL SOUTH	28	St sid	/	/	/	/	/		No
LOWER LEVEL SOUTH	26	St sid	/	/	/	/	/		No
LOWER LEVEL SOUTH	24	St sid	/	/	/	/	/		No
LOWER LEVEL SOUTH	22	St sid	/	/	/	/	/		No
LOWER LEVEL SOUTH	20	St sid	/	/	/	/	/		No
LOWER LEVEL SOUTH	18	St sid	/	/	/	/	/		No
LOWER LEVEL SOUTH	16	St sid	/	/	/	/	/		No
LOWER LEVEL NORTH	60	St sid	/	/	/	/	/		No
LOWER LEVEL NORTH	62	St sid	/	/	/	/	/		No
LOWER LEVEL NORTH	62A	St sid	/	/	/	/	/		No
LOWER LEVEL NORTH	63	St sid	/	/	/	/	/		No
LOWER LEVEL NORTH	64	St sid	/	/	/	/	/		No

0354

PA BUS TERMINAL DOOR MAINT CHECK LIST

Juan

DATE: 11/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	65	St sld	/	/	/	/	/	No	
LOWER LEVEL NORTH	66	St sld	/	/	/	/	/	No	
LOWER LEVEL NORTH	67	St sld	/	/	/	/	/	No	
LOWER LEVEL NORTH	68	St sld	/	/	/	/	/	No	
LOWER LEVEL NORTH	69	St sld	/	/	/	/	/	No	
LOWER LEVEL NORTH	70	St sld	/	/	X	X	/	needs FSL R/H Guide	
LOWER LEVEL NORTH	71	St sld	/	/	/	/	/	No	
LOWER LEVEL NORTH	71A	St sld	/	/	/	/	/	No	
LOWER LEVEL NORTH	72	St sld	/	/	/	/	/	No	
LOWER LEVEL NORTH	73	St sld	/	/	/	/	/	No	
LOWER LEVEL NORTH	74	St sld	/	/	/	/	/	No	
LOWER LEVEL NORTH	75	St sld	/	/	/	/	/	No	
LOWER LEVEL NORTH	75A	St sld	/	/	/	/	/	No	
LOWER LEVEL NORTH	76	St sld	/	/	/	/	/	No	
LOWER LEVEL NORTH	84A	St sld	/	/	/	/	/	No	
LOWER LEVEL NORTH	85	St sld	/	/	/	/	/	No	
C.L North	78	St sld	/	/	/	/	/	No	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	81	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	82	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	83	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	84	St sld	/	/	/	/	/		
[REDACTED]									
3rd FL NORTH	301	St sw	/	/	/	/	/		
3rd FL NORTH	302	St sw	/	/	/	/	/		
3rd FL NORTH	303	St sw	/	/	/	/	/		
3rd FL NORTH	304	St sw	/	/	/	/	/		
3rd FL NORTH	305	St sw	/	/	/	/	/		
3rd FL NORTH	306	St sw	/	/	/	/	/	NEEDS PWS	
3rd FL NORTH	307	St sw	/	/	/	/	/		
3rd FL NORTH	308	St sw	/	/	/	/	/		
3rd FL NORTH	309	St sw	/	/	/	/	/		

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	St sw	/	/	/	/	/	No	
3rd FL NORTH	311	St sw	/	/	/	/	/	No	
3rd FL NORTH	312	St sw	/	/	/	/	/	No	
3rd FL NORTH	313	St sw	/	/	/	/	/	No	
3rd FL NORTH	314	St sw	/	/	/	/	/	No	
3rd FL NORTH	315	St sw	/	/	/	/	/	No	
3rd FL NORTH	316	St sw	/	/	/	/	/	No	
3rd FL NORTH	317	St sw	/	/	/	/	/	No	
3rd FL NORTH	318	St sw	/	/	/	/	/	No	
3rd FL NORTH	319	St sw	/	/	/	/	/	No	
3rd FL NORTH	320	St sw	/	/	/	/	/	No	
3rd FL NORTH	321	St sw	/	/	/	/	/	No	
3rd FL NORTH	322	St sw	/	/	/	/	/	No	
3rd FL NORTH	323	St sw	/	/	/	/	/	No	
3rd FL NORTH	324	St sw	/	/	/	/	/	No	
3rd FL NORTH	325	St sw	/	/	/	/	/	No	
3rd FL NORTH	326	St sw	/	/	/	/	/	No	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: 7/2

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St sw	/	/	/	/	/	No	
4th FL SOUTH	402	St sw	/	/	/	/	/	No	
4th FL SOUTH	403	St sw	/	/	/	/	/	No	
4th FL SOUTH	404	St sw	/	/	/	/	/	No	
4th FL SOUTH	405	St sw	/	/	/	/	/	No	
4th FL SOUTH	406	St sw	/	/	/	/	/	No	
4th FL SOUTH	407	St sw	/	/	/	/	/	No	
4th FL SOUTH	408	St sw	/	/	/	/	/	No	
4th FL SOUTH	409	St sw	/	/	/	/	/	No	
4th FL SOUTH	410	St sw	/	/	/	/	/	No	
4th FL SOUTH	411	St sw	/	/	/	/	/	No	
4th FL SOUTH	412	St sw	/	/	/	/	/	No	
4th FL SOUTH	413	St sw	/	/	/	/	/	No	
4th FL SOUTH	414	St sw	/	/	/	/	/	No	
4th FL SOUTH	415	st sw	/	/	/	/	/	No	
4th FL SOUTH	416	st sw	/	/	/	/	/	No	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: / /

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	417	St sw	/	/	/	/	/	NO	
4th FL SOUTH	418	St sw	/	/	/	/	/	NO	
4th FL SOUTH	419	St sw	/	/	/	/	/	NO	
4th FL SOUTH	420	St sw	/	/	/	/	/	NO	
4th FL SOUTH	421	St sw	/	/	/	/	/	NO	
LOWER LEV SOUTH	14	ST SLD	/	/	/	/	/	NO	
LOWER LEV SOUTH	12	ST SLD	/	/	/	/	/	NO	
LOWER LEV SOUTH	10	ST SLD	/	/	/	/	/	NO	
LOWER LEV SOUTH	8	ST SLD	/	/	/	/	/	NO	
LOWER LEV SOUTH	6	ST SLD	/	/	/	/	/	NO	
LOWER LEV SOUTH	4	ST SLD	/	/	/	/	/	NO	
LOWER LEV SOUTH	2	ST SLD	/	/	/	/	/	NO	
ROAD WAY EAST	SL1A1	BESAM SLD AMD 1	/	/	/	/	/	NO	
ROAD WAY WEST	SL1A2	BESAM SLD AMD 1	/	/	/	/	/	NO	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
OUTH WING 9th AVE	SL1R1	h sld	/	/	/	/	/	NO	
OUTH WING 9th AVE	SL1R2	h sld	/	/	/	/	/	NO	
OUTH WING 9th AVE	SL1R3	h revolver	/	/	/	/	/	NO	
OUTH WING 9th AVE	SL1R4	h revolver	/	/	/	/	/	NO	
41st STREET	S13A1	St sw	/	/	/	/	/	NO	
41st STREET	S13A2	St sw	/	/	/	/	/	NO	
OUTH WING 8TH AVE	S14A1A	Besam sw	/	/	/	/	/	NO	
OUTH WING 8TH AVE	S14A1B	Besam sw	/	/	/	/	/	NO	
OUTH WING 8TH AVE	S14A2A	Gt sw	/	/	/	/	/	NO	
OUTH WING 8TH AVE	S14A2B	Gt sw	/	/	/	/	/	NO	
OUTH WING 8TH AVE	S14A3A	Besam sw	/	/	/	/	/	NO	
OUTH WING 8TH AVE	S14A3B	Besam sw	/	/	/	/	/	NO	
OUTH WING 8TH AVE	S14A4A	Gt sw	/	/	/	/	/	NO	
OUTH WING 8TH AVE	S14A4B	Gt sw	/	/	/	/	/	NO	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: 7/16/13

5044

not done

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	St sid							
LOWER LEVEL SOUTH	3	St sid							
LOWER LEVEL SOUTH	5	St sid							
LOWER LEVEL SOUTH	7	St sid							
LOWER LEVEL SOUTH	9	St sid							
LOWER LEVEL SOUTH	11	St sid							
LOWER LEVEL SOUTH	13	St sid							
LOWER LEVEL SOUTH	15	St sid							
LOWER LEVEL SOUTH	17	St sid							
LOWER LEVEL SOUTH	19	St sid							
LOWER LEVEL SOUTH	21	St sid							
LOWER LEVEL SOUTH	23	St sid							
LOWER LEVEL SOUTH	25	St sid							
LOWER LEVEL SOUTH	27	St sid							
LOWER LEVEL SOUTH	29	St sid							
LOWER LEVEL SOUTH	31	St sid							

PA BUS TERMINAL DOOR MAINT CHECK LIST

5 JUL 11

DATE: 7/16/11

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	34	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	32	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	30	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	28	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	26	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	24	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	22	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	20	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	18	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	16	St sld	✓	✓	✓	✓	✓	Yes	
LOWER LEVEL NORTH	60	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	62	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	62A	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	63	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	64	St sld	✓	✓	✓	✓	✓	no	

0354

PA BUS TERMINAL DOOR MAINT CHECK LIST

Scan

DATE: 11/22/13

4/17/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	65	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	66	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	67	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	68	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	69	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	70	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	71	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	71A	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	72	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	73	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	74	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	75	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	75A	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	76	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	84A	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	85	St sid	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH			✓	✓	✓	✓	✓		

P L NORTH

84

St sid

PA BUS TERMINAL DOOR MAINT CHECK LIST

Sub

DATE: 7/16/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	81	St sld	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	82	St sld	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	83	St sld	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	84	St sld	✓	✓	✓	✓	✓	NO	
[REDACTED SECTION]									
3rd FL NORTH	301	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	302	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	303	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	304	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	305	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	306	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	307	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	308	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	309	St sw	✓	✓	✓	✓	✓	NO	

PA BUS TERMINAL DOOR MAINT CHECK LIST

7/16/13

DATE: 5/16/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	311	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	312	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	313	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	314	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	315	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	316	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	317	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	318	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	319	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	320	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	321	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	322	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	323	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	324	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	325	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	326	St sw	✓	✓	✓	✓	✓	NO	

PA BUS TERMINAL DOOR MAINT CHECK LIST

5042

DATE: 7/16/17

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	402	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	403	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	404	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	405	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	406	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	407	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	408	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	409	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	410	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	411	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	412	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	413	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	414	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	415	st sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	416	st sw	✓	✓	✓	✓	✓	NO	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: 1/11/10

DATE: 1/11/10

COMMENTS

REQUIRED REPAIR

PIVOTS

CLOSE SPEED

OPEN SPEED

SAFETY

ACT

TYPE

DOOR #

LOCATION

ST SW

417

4th FL SOUTH

ST SW

418

4th FL SOUTH

ST SW

419

4th FL SOUTH

ST SW

420

4th FL SOUTH

ST SW

421

4th FL SOUTH

ST SLD

14

LOWER LEV SOUTH

ST SLD

12

LOWER LEV SOUTH

ST SLD

10

LOWER LEV SOUTH

ST SLD

8

LOWER LEV SOUTH

ST SLD

6

LOWER LEV SOUTH

ST SLD

4

LOWER LEV SOUTH

ST SLD

2

LOWER LEV SOUTH

BESAM SLD
AMD 1

SL1A1

ROAD WAY EAST

BESAM SLD
AMD 1

SL1A2

ROAD WAY WEST

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUN

DATE: 5/11/53

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
OUTH WING 9th AVE	SL1R1	h sld						YES	
OUTH WING 9th AVE	SL1R2	h sld	✓	✓	✓	✓	✓	NO	
OUTH WING 9th AVE	SL1R3	h revolver	✓	✓	✓	✓	✓	NO	
OUTH WING 9th AVE	SL1R4	h revolver	✓	✓	✓	✓	✓	NO	
41st STREET	S13A1	St sw	✓	✓	✓	✓	✓	NO	
41st STREET	S13A2	St sw	✓	✓	✓	✓	✓	NO	
OUTH WING 8TH AVE	S14A1A	E. cam sw	✓	✓	✓	✓	✓	NO	
OUTH WING 8TH AVE	S14A1B	Besam sw	✓	✓	✓	✓	✓	NO	
OUTH WING 8TH AVE	S14A2A	Gt sw	✓	✓	✓	✓	✓	YES	02342
OUTH WING 8TH AVE	S14A2B	Gt sw	✓	✓	✓	✓	✓	NO	
OUTH WING 8TH AVE	S14A3A	Besam sw	✓	✓	✓	✓	✓	NO	
OUTH WING 8TH AVE	S14A3B	Besam sw	✓	✓	✓	✓	✓	NO	
OUTH WING 8TH AVE	S14A4A	Gt sw	✓	✓	✓	✓	✓	NO	
OUTH WING 8TH AVE	S14A4B	Gt sw	✓	✓	✓	✓	✓	NO	

DOOR AUTOMATION CORPORATION

DATE: 7/5/13

PO: _____

TN: 14025

CUSTOMER: Bus Terminal

LOCATION: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
LL	South wing	Gate 16		Stanley slide	
	DHC 03545				
	REPLACED BOTTOM R/LH FSC Guide				
LL	South wing	Gate 17		Stanley slide	
	DHC 04233				
	REPLACED bottom L/RH FSC Guide				
LL	South wing	Gate 20		Stanley slide	
	DHC 03884				
	REPLACED bottom R/LH FSC Guide				

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 7 00

TRUCK #: 320

ARRIVED HERE: 8 00

NO. OF MEN: 1

LEFT THIS JOB: 17 30

JOB COMPLETED: YES NO

Scam
MECHANICS

CUSTOMER'S SIGNATURE

PRINT NAME

DOOR AUTOMATION CORP.

DATE: 07/24/20

CUSTOMER: _____

PO: _____

LOCATION: Bus terminal

TN: 14221

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
<u>Tag # 01384</u>					
<u>at 9th ave</u>					
<u>at Bessan Blvd</u>					
<u>its checked out due to work</u>					
<u>Paul</u>					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 1000

TRUCK #: _____

ARRIVED HERE: 1100

NO. OF MEN: 2

LEFT THIS JOB: 100

JOB COMPLETED: YES NO

Markes M... ..

MECHANICS

CUSTOMER'S SIGNATURE

PRINT NAME

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	3	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	5	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	7	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	9	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	11	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	13	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	15	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	17	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	19	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	21	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	23	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	25	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	27	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	29	St sld	/	/	/	/	/		
LOWER LEVEL SOUTH	31	St sld	/	/	/	/	/		

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St sid							
LOWER LEVEL SOUTH	34	St sid							
LOWER LEVEL SOUTH	32	St sid							
LOWER LEVEL SOUTH	30	St sid							
OWER LEVEL SOUTH	28	St sid							
LOWER LEVEL SOUTH	26	St sid							
LOWER LEVEL SOUTH	24	St sid							
LOWER LEVEL SOUTH	22	St sid							
LOWER LEVEL SOUTH	20	St sid							
LOWER LEVEL SOUTH	18	St sid							
LOWER LEVEL SOUTH	16	St sid							03545
LOWER LEVEL NORTH	60	St sid							
LOWER LEVEL NORTH	62	St sid							
LOWER LEVEL NORTH	62A	St sid							
LOWER LEVEL NORTH	63	St sid							
LOWER LEVEL NORTH	64	St sid							

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE: 11/22/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	65	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	66	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	67	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	68	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	69	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	70	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	71	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	71A	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	72	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	73	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	74	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	75	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	75A	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	76	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	84A	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	85	St sld	/	/	/	/	/		
<i>CL North</i>	<i>88</i>	<i>St sld</i>	/	/	/	/	/		

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	81	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	82	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	83	St sld	/	/	/	/	/		
LOWER LEVEL NORTH	84	St sld	/	/	/	/	/		
3rd FL NORTH	301	St sw	/	/	/	/	/		
3rd FL NORTH	302	St sw	/	/	/	/	/		
3rd FL NORTH	303	St sw	/	/	/	/	/		
3rd FL NORTH	304	St sw	/	/	/	/	/		
3rd FL NORTH	305	St sw	/	/	/	/	/		
3rd FL NORTH	306	St sw	/	/	/	/	/		
3rd FL NORTH	307	St sw	/	/	/	/	/		
3rd FL NORTH	308	St sw	/	/	/	/	/		
3rd FL NORTH	309	St sw	/	/	/	/	/		

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	St sw	/	/	/	/	/		
3rd FL NORTH	311	St sw	/	/	/	/	/		
3rd FL NORTH	312	St sw	/	/	/	/	/		
3rd FL NORTH	313	St sw	/	/	/	/	/		
3rd FL NORTH	314	St sw	/	/	/	/	/		
3rd FL NORTH	315	St sw	/	/	/	/	/		
3rd FL NORTH	316	St sw	/	/	/	/	/		
3rd FL NORTH	317	St sw	/	/	/	/	/		
3rd FL NORTH	318	St sw	/	/	/	/	/		
3rd FL NORTH	319	St sw	/	/	/	/	/		
3rd FL NORTH	320	St sw	/	/	/	/	/		
3rd FL NORTH	321	St sw	/	/	/	/	/		
3rd FL NORTH	322	St sw	/	/	/	/	/		
3rd FL NORTH	323	St sw	/	/	/	/	/		
3rd FL NORTH	324	St sw	/	/	/	/	/		
3rd FL NORTH	325	St sw	/	/	/	/	/		
3rd FL NORTH	326	St sw	/	/	/	/	/		

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: 7/1

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St sw	/	/	/	/	/		
4th FL SOUTH	402	St sw	/	/	/	/	/		
4th FL SOUTH	403	St sw	/	/	/	/	/		
4th FL SOUTH	404	St sw	/	/	/	/	/		
4th FL SOUTH	405	St sw	/	/	/	/	/		
4th FL SOUTH	406	St sw	/	/	/	/	/		
4th FL SOUTH	407	St sw	/	/	/	/	/		
4th FL SOUTH	408	St sw	/	/	/	/	/		
4th FL SOUTH	409	St sw	/	/	/	/	/		
4th FL SOUTH	410	St sw	/	/	/	/	/		
4th FL SOUTH	411	St sw	/	/	/	/	/		
4th FL SOUTH	412	St sw	/	/	/	/	/		
4th FL SOUTH	413	St sw	/	/	/	/	/		
4th FL SOUTH	414	St sw	/	/	/	/	/		
4th FL SOUTH	415	st sw	/	/	/	/	/		
4th FL SOUTH	416	st sw	/	/	/	/	/		

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE:

LOCATION	DOOR #	TYPE	AGT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	417	SI SW							
4th FL SOUTH	418	SI SW							
4th FL SOUTH	419	SI SW							
4th FL SOUTH	420	SI SW							
4th FL SOUTH	421	SI SW							
LOWER LEV SOUTH	14	ST SLD							
LOWER LEV SOUTH	12	ST SLD							
LOWER LEV SOUTH	10	ST SLD							
LOWER LEV SOUTH	8	ST SLD							
LOWER LEV SOUTH	6	ST SLD							
LOWER LEV SOUTH	4	ST SLD							
LOWER LEV SOUTH	2	ST SLD							
ROAD WAY EAST	SL1A1	BESAM SLD							
ROAD WAY WEST	SL1A2	BESAM SLD							

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE:

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
OUTH WING 9th AVE	SL1R1	h sid							
OUTH WING 9th AVE	SL1R2	h sid							
OUTH WING 9th AVE	SL1R3	h revolver							
OUTH WING 9th AVE	SL1R4	h revolver							
41st STREET	SL1A1	SL SW							
41st STREET	SL1A2	SL SW							
OUTH WING 8th AVE	S14A1A	Bosam SW							
OUTH WING 8th AVE	S14A1B	Bosam SW							
OUTH WING 8th AVE	S14A2A	GI SW							
OUTH WING 8th AVE	S14A2B	GI SW							
OUTH WING 8th AVE	S14A3A	Bosam SW							
OUTH WING 8th AVE	S14A3B	Bosam SW							
OUTH WING 8th AVE	S14A4A	GI SW							
OUTH WING 8th AVE	S14A4B	GI SW							

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
NORTH WING 8th ave	N1BA1A	Besam sw							
NORTH WING 8th ave	N1BA1B	Besam sw							
NORTH WING 8th ave	N1BA2A	Besam sw							
NORTH WING 8th ave	N1BA2B	Besam sw							
NORTH WING 8th ave	N1BA3A	Besam sw							
NORTH WING 8th ave	N1BA3B	Besam sw							
NORTH WING 8th ave	N1BA4A	Besam sw							
NORTH WING 8th ave	N1BA4B	Besam sw							
TAXI RD WAY	BT4405	Besam sw							
TAXI RD WAY	BT4406	Besam sw							

AREA CLOSE

DOOR AUTOMATION CORP.

DATE: 6/8/13

CUSTOMER: Bus Terminal

PMO

PO: _____

LOCATION: _____

TN: _____

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
DL	North wing	75A		Stanley slider	
DAC 04265					
499 must return with a new bottom guide to completed					
LL	North wing	84A		Stanley slider	
DAC 03551					
499 must return with a new stand guard to completed					
LL	North wing	79		Stanley slider	
DAC 02707					
499 must return with a new MCS21 to completed					
LL	North wing	319		Stanley swing	
DAC 01200					
499 must return with a new bottom press w/ol supply					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 8:00 TRUCK #: 300
 ARRIVED HERE: 9:00 NO. OF MEN: 1
 LEFT THIS JOB: 3:30 JOB COMPLETED: YES NO

MECHANICS: John CUSTOMER'S SIGNATURE: _____ PRINT NAME: _____

DOOR AUTOMATION CORP.

DATE: 6/27/13

CUSTOMER: Buff Terminal Pin (2)

PO: _____

LOCATION: _____

TN: 13964

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
03	NORTH wing	323		Stanley swing	
DAC 04241					
499 must return with a new slider block					
04	south wing	420		Stanley swing	
DAC 03436					
499 must return with a new slider block					
01	south wing	8 Ave	314A2A	Recess Swing	
DAC 02342					
330 must return to lift door is too low to allow 8th floor					
01	north wing	2400	N16A4A	GT Swing	
DAC 21726					
499 must return to replaced L.P. Rikon Picot					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: _____ TRUCK #: 300

ARRIVED HERE: _____ NO. OF MEN: 2

LEFT THIS JOB: _____ JOB COMPLETED: YES NO

SUNY licensed
MECHANICS

(Signature)
CUSTOMER'S SIGNATURE

Emily King
PRINT NAME

DOOR AUTOMATION CORP.

DATE: 6/27/13

CUSTOMER: WCS Terminal WM

PO: _____

LOCATION: _____

TN: 13964

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
					<u>01 LL South wing 11 Stanley slider</u>
					<u>DAC 04047</u>
					<u>499 must return with a R/H FSL bottom Guide</u>
					<u>LL South wing 17 Stanley slider</u>
					<u>DAC 04237</u>
					<u>499 must return with a L/H FSL bottom Guide</u>
					<u>LL South wing 26 Stanley slider</u>
					<u>DAC 03884</u>
					<u>499 must return with a L/H FSL bottom Guide</u>
					<u>LL South wing 16 Stanley swing</u>
					<u>DAC 04115</u>
					<u>499 must return with a FSL Guide</u>

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: _____ TRUCK #: _____

ARRIVED HERE: _____ NO. OF MEN: _____

LEFT THIS JOB: _____ JOB COMPLETED: YES NO

Juan Alonso
MECHANICS

CUSTOMER'S SIGNATURE

EMM Erazand
PRINT NAME

PA BUS TERMINAL DOOR MAINT CHECKLIST

DATE: 6/27/13
 Juan Alonzo

ADD Name

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	St. Std	✓	✓	✓	✓	✓		no
LOWER LEVEL SOUTH	3	St. Std	✓	✓	✓	✓	✓		no
LOWER LEVEL SOUTH	5	St. Std	✓	✓	✓	✓	✓		no
LOWER LEVEL SOUTH	7	St. Std	✓	✓	✓	✓	✓		no
LOWER LEVEL SOUTH	8	St. Std	✓	✓	✓	✓	✓		no
LOWER LEVEL SOUTH	11	St. Std	✓	✓	✓	✓	✓		no yes Overt w/H FSL Guide
LOWER LEVEL SOUTH	13	St. Std	✓	✓	✓	✓	✓		no
LOWER LEVEL SOUTH	15	St. Std	✓	✓	✓	✓	✓		no
LOWER LEVEL SOUTH	17	St. Std							no yes w/H FSL Guide 04233
LOWER LEVEL SOUTH	19	St. Std	✓	✓	✓	✓	✓		no
LOWER LEVEL SOUTH	21	St. Std	✓	✓	✓	✓	✓		no
LOWER LEVEL SOUTH	23	St. Std	✓	✓	✓	✓	✓		no
LOWER LEVEL SOUTH	25	St. Std	✓	✓	✓	✓	✓		no
LOWER LEVEL SOUTH	27	St. Std	✓	✓	✓	✓	✓		no
LOWER LEVEL SOUTH	29	St. Std	✓	✓	✓	✓	✓		no
LOWER LEVEL SOUTH	31	St. Std	✓	✓	✓	✓	✓		no

PA BUS TERMINAL DOOR MAINT CHECK LIST

John / 10020

DATE: 6-2-12

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPND	CLOSE SPND	PNOTS	REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	34	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	32	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	30	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	28	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	26	St old	✓	✓	✓	✓	✓	NO	yes
LOWER LEVEL SOUTH	24	St old	✓	✓	✓	✓	✓	NO	need 4/A FSL Guide
LOWER LEVEL SOUTH	22	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	20	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	18	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	16	St old	✓	✓	✓	✓	✓	NO	need 4/A FSL Guide 03545
LOWER LEVEL NORTH	00	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	02	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	02A	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	03	St old	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	04	St old	✓	✓	✓	✓	✓	NO	

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: 6-27-13

John Alonzo

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REPAIR	COMMENTS
LOWER LEVEL NORTH	81	SI sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	82	SI sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	83	SI sld	✓	✓	✓	✓	✓		
LOWER LEVEL NORTH	84	SI sld	✓	✓	✓	✓	✓		
[REDACTED]									
3rd FL NORTH	301	SI s/w	✓	✓	✓	✓	✓		
3rd FL NORTH	302	SI s/w	✓	✓	✓	✓	✓		
3rd FL NORTH	303	SI s/w	✓	✓	✓	✓	✓		
3rd FL NORTH	304	SI s/w	✓	✓	✓	✓	✓		
3rd FL NORTH	305	SI s/w	✓	✓	✓	✓	✓		
3rd FL NORTH	306	SI s/w	✓	✓	✓	✓	✓		
3rd FL NORTH	307	SI s/w	✓	✓	✓	✓	✓		
3rd FL NORTH	308	SI s/w	✓	✓	✓	✓	✓		
3rd FL NORTH	309	SI s/w	✓	✓	✓	✓	✓		

PA BUS TERMINAL DOOR MAINT CHECKLIST

DATE: 6-27-13
 JRM / Aburzel

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PNOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	SI SW	✓	✓	✓	✓	✓	N/D	
3rd FL NORTH	311	SI SW	✓	✓	✓	✓	✓	N/D	
3rd FL NORTH	312	SI SW	✓	✓	✓	✓	✓	N/D	
3rd FL NORTH	313	SI SW	✓	✓	✓	✓	✓	N/D	
3rd FL NORTH	314	SI SW	✓	✓	✓	✓	✓	N/D	
3rd FL NORTH	315	SI SW	✓	✓	✓	✓	✓	N/D	
3rd FL NORTH	316	SI SW	✓	✓	✓	✓	✓	N/D	
3rd FL NORTH	317	SI SW	✓	✓	✓	✓	✓	N/D	
3rd FL NORTH	318	SI SW	✓	✓	✓	✓	✓	N/D	
3rd FL NORTH	319	SI SW	✓	✓	✓	✓	✓	N/D	
3rd FL NORTH	320	SI SW	✓	✓	✓	✓	✓	N/D	
3rd FL NORTH	321	SI SW	✓	✓	✓	✓	✓	N/D	
3rd FL NORTH	322	SI SW	✓	✓	✓	✓	✓	N/D	
3rd FL NORTH	323	SI SW	✓	✓	✓	✓	✓	N/D	
3rd FL NORTH	324	SI SW	✓	✓	✓	✓	✓	N/D	
3rd FL NORTH	325	SI SW	✓	✓	✓	✓	✓	N/D	
3rd FL NORTH	326	SI SW	✓	✓	✓	✓	✓	N/D	

Sliding block
04241

PA BUS TERMINAL DOOR MAINT CHECK SHEET

DATE: 7/1

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REPAIR NEEDED	COMMENTS
4th FL SOUTH	401	SI SW	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	402	SI SW	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	403	SI SW	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	404	SI SW	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	405	SI SW	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	406	SI SW	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	407	SI SW	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	408	SI SW	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	409	SI SW	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	410	SI SW	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	411	SI SW	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	412	SI SW	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	413	SI SW	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	414	SI SW	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	415	SI SW	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	416	SI SW	✓	✓	✓	✓	✓	NO	

PA BUS TERMINAL DOOR MAINT CHECKLIST

Alan So / *[Signature]*

DATE: 5/27/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REPAIR	COMMENTS
4th FL SOUTH	417	SI SW	✓	✓	✓	✓	✓		
4th FL SOUTH	418	SI SW	✓	✓	✓	✓	✓		
4th FL SOUTH	419	SI SW	✓	✓	✓	✓	✓		
4th FL SOUTH	420	SI SW							
4th FL SOUTH	421	SI SW	✓	✓	✓	✓	✓		
LOWER LEV SOUTH	14	ST SLD	✓	✓	✓	✓	✓		
LOWER LEV SOUTH	12	ST SLD	✓	✓	✓	✓	✓		
LOWER LEV SOUTH	10	ST SLD	✓	✓	✓	✓	✓		
LOWER LEV SOUTH	8	ST SLD	✓	✓	✓	✓	✓		
LOWER LEV SOUTH	6	ST SLD	✓	✓	✓	✓	✓		
LOWER LEV SOUTH	4	ST SLD	✓	✓	✓	✓	✓		
LOWER LEV SOUTH	2	ST SLD	✓	✓	✓	✓	✓		
ROAD WAY EAST	SL1A1	BESAM SLD AND 1	✓	✓	✓	✓	✓		
ROAD WAY WEST	SL1A2	BESAM SLD AND 1	✓	✓	✓	✓	✓		

03436
slide block

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: 6/29/13

5:42 AM

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REPAIRS	COMMENTS
4th FL SOUTH	417	ST SW	✓	✓	✓	✓	✓		
4th FL SOUTH	418	ST SW	✓	✓	✓	✓	✓		
4th FL SOUTH	419	ST SW	✓	✓	✓	✓	✓		
4th FL SOUTH	420	ST SW	✓	✓	✓	✓	✓		
4th FL SOUTH	421	ST SW	✓	✓	✓	✓	✓		
LOWER LEV SOUTH	14	ST SLD	✓	✓	✓	✓	✓		
LOWER LEV SOUTH	12	ST SLD	✓	✓	✓	✓	✓		
LOWER LEV SOUTH	10	ST SLD	✓	✓	✓	✓	✓		
LOWER LEV SOUTH	8	ST SLD	✓	✓	✓	✓	✓		
LOWER LEV SOUTH	6	ST SLD	✓	✓	✓	✓	✓		
LOWER LEV SOUTH	4	ST SLD	✓	✓	✓	✓	✓		
LOWER LEV SOUTH	2	ST SLD	✓	✓	✓	✓	✓		
ROAD WAY EAST	SL1A1	BEAM SLD AND 1	✓	✓	✓	✓	✓		
ROAD WAY WEST	SL1A2	BEAM SLD AND 1	✓	✓	✓	✓	✓		

PACIFIC TERMINAL DOOR MAINT CHECK LIST

JUN 9

DATE: 6/9/03

LOCATION	DOOR #	TYPE	ACT	ALARM	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
DUTH WING 9th AVE	SL1R1	h aid	✓	✓	✓	✓	✓	NO	
DUTH WING 9th AVE	SL1R2	h aid	✓	✓	✓	✓	✓	NO	
DUTH WING 9th AVE	SL1R3	h revolver	✓	✓	✓	✓	✓	NO	
DUTH WING 9th AVE	SL1R4	h revolver	✓	✓	✓	✓	✓	NO	
41st STREET	S13A1	St sw							
41st STREET	S13A2	St sw							
DUTH WING 8TH AVE	S14A1A	Beam sw	✓	✓	✓	✓	✓	NO	
DUTH WING 8TH AVE	S14A1B	Beam sw	✓	✓	✓	✓	✓	NO	
DUTH WING 8TH AVE	S14A2A	Gt sw	✓	✓	✓	✓	✓	NO	
DUTH WING 8TH AVE	S14A2B	Gt sw	✓	✓	✓	✓	✓	NO	
DUTH WING 8TH AVE	S14A3A	Beam sw	✓	✓	✓	✓	✓	NO	
DUTH WING 8TH AVE	S14A3B	Beam sw	✓	✓	✓	✓	✓	NO	
DUTH WING 8TH AVE	S14A4A	Gt sw	✓	✓	✓	✓	✓	NO	
DUTH WING 8TH AVE	S14A4B	Gt sw	✓	✓	✓	✓	✓	NO	

PA BUS TERMINAL POOR MAINT CHECK SHEET

DATE: _____

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PNOTS	REPAIR	COMMENTS
NORTH WING 8th ave	N1B41A	Basem sw	✓	✓	✓	✓	✓	210	
NORTH WING 8th ave	N1B41B	Basem sw	✓	✓	✓	✓	✓	210	
NORTH WING 8th ave	N1B42A	Basem sw	✓	✓	✓	✓	✓	210	
NORTH WING 8th ave	N1B42B	Basem sw	✓	✓	✓	✓	✓	210	
NORTH WING 8th ave	N1B43A	Basem sw	✓	✓	✓	✓	✓	210	
NORTH WING 8th ave	N1B43B	Basem sw	✓	✓	✓	✓	✓	210	
NORTH WING 8th ave	N1B44A	Basem sw	✓	✓	✓	✓	✓	210	
NORTH WING 8th ave	N1B44B	Basem sw	✓	✓	✓	✓	✓	210	
TAXI RID WAY	BT4405	Basem sw							
TAXI RID WAY	BT4406	Basem sw							

AORF
Close

FACILITY TERMINAL DOOR MAINT CHECK LIST

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
DUTH WING 9th AVE	SL1R1	h sid							
DUTH WING 9th AVE	SL1R2	h sid							
DUTH WING 9th AVE	SL1R3	h revolver							
DUTH WING 9th AVE	SL1R4	h revolver							
41st STREET	S13A1	St sw							
41st STREET	S13A2	St sw							
DUTH WING 8TH AVE	S14A1A	Besam sw	✓	✓	✓	✓	✓	no	
DUTH WING 8TH AVE	S14A1B	Besam sw	✓	✓	✓	✓	✓	no	
DUTH WING 8TH AVE	S14A2A	Gt sw	✓	✓	✓	✓	✓	yes	Door is low need Manual Tech #2342
DUTH WING 8TH AVE	S14A2B	Gt sw	✓	✓	✓	✓	✓	no	
DUTH WING 8TH AVE	S14A3A	Besam sw	✓	✓	✓	✓	✓	no	
DUTH WING 8TH AVE	S14A3B	Besam sw	✓	✓	✓	✓	✓	no	
DUTH WING 8TH AVE	S14A4A	Gt sw	✓	✓	✓	✓	✓	no	
DUTH WING 8TH AVE	S14A4B	Gt sw	✓	✓	✓	✓	✓	no	

PERIODIC TERMINAL DOOR MAINT CHECK LIST

5/8/13

LOCATION	DOOR #	TYPE	ACT	ADJUST	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	St std	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	3	St std	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	5	St std	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	7	St std	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	9	St std	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	11	St std	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	13	St std	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	15	St std	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	17	St std	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	19	St std	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	21	St std	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	23	St std	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	25	St std	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	27	St std	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	29	St std	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	31	St std	✓	✓	✓	✓	✓	NO	

P-30 OVERHEAD DOOR MAINT CHECK LIST

DATE: 6/8/13

LOCATION	DOOR #	TYPE	ACT	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St sid	/	/	/	/	NO	
LOWER LEVEL SOUTH	34	St sid	/	/	/	/	NO	
LOWER LEVEL SOUTH	32	St sid	/	/	/	/	NO	
LOWER LEVEL SOUTH	30	St sid	/	/	/	/	NO	
LOWER LEVEL SOUTH	28	St sid	/	/	/	/	NO	
LOWER LEVEL SOUTH	26	St sid	/	/	/	/	NO	
LOWER LEVEL SOUTH	24	St sid	/	/	/	/	NO	
LOWER LEVEL SOUTH	22	St sid	/	/	/	/	NO	
LOWER LEVEL SOUTH	20	St sid	/	/	/	/	NO	
LOWER LEVEL SOUTH	18	St sid	/	/	/	/	NO	
LOWER LEVEL SOUTH	16	St sid	/	/	/	/	NO	
LOWER LEVEL NORTH	60	St sid	/	/	/	/	NO	
LOWER LEVEL NORTH	62	St sid	/	/	/	/	NO	
LOWER LEVEL NORTH	62A	St sid	/	/	/	/	NO	
LOWER LEVEL NORTH	63	St sid	/	/	/	/	NO	
LOWER LEVEL NORTH	64	St sid	/	/	/	/	NO	

03545

PARTIAL TERMINAL DOOR MAINT CHECK LIST

Dean

11/23/73

LOCATION	DOOR #	TYPE	ACT	SECURITY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	65	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	66	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	67	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	68	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	69	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	70	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	71	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	71A	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	72	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	73	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	74	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	75	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	75A	St ald	✓	✓	✓	✓	✓	NO	04565 6.5 Ton Guide
LOWER LEVEL NORTH	76	St ald	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	84A	St ald	✓	✓	✓	✓	✓	NO	03581 ST and Craned
LOWER LEVEL NORTH	85	St ald	✓	✓	✓	✓	✓	NO	
Lower North	88	St ald	✓	✓	✓	✓	✓	NO	
Lower North	89	St ald	✓	✓	✓	✓	✓	NO	
								yes	02707 control

RESIDENTIAL DOOR MAINT CHECK LIST

J. L. M.

6/8/13

LOCATION	DOOR #	TYPE	ACT	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	81	St sid	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	82	St sid	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	83	St sid	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	84	St sid	✓	✓	✓	✓	NO	
[REDACTED]								
3rd FL NORTH	301	St sw	✓	✓	✓	✓	NO	
3rd FL NORTH	302	St sw	✓	✓	✓	✓	NO	
3rd FL NORTH	303	St sw	✓	✓	✓	✓	NO	
3rd FL NORTH	304	St sw	✓	✓	✓	✓	NO	
3rd FL NORTH	305	St sw	✓	✓	✓	✓	NO	
3rd FL NORTH	306	St sw	✓	✓	✓	✓	NO	
3rd FL NORTH	307	St sw	✓	✓	✓	✓	NO	
3rd FL NORTH	308	St sw	✓	✓	✓	✓	NO	
3rd FL NORTH	309	St sw	✓	✓	✓	✓	NO	

PLUMBING TERMINAL, DOOR MAINT CHECK LIST

LOCATION	DOOR #	TYPE	ACT	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	St SW	✓	✓	✓	✓	NO	
3rd FL NORTH	311	St SW	✓	✓	✓	✓	NO	
3rd FL NORTH	312	St SW	✓	✓	✓	✓	NO	
3rd FL NORTH	313	St SW	✓	✓	✓	✓	NO	
3rd FL NORTH	314	St SW	✓	✓	✓	✓	NO	
3rd FL NORTH	315	St SW	✓	✓	✓	✓	NO	
3rd FL NORTH	316	St SW	✓	✓	✓	✓	NO	
3rd FL NORTH	317	St SW	✓	✓	✓	✓	NO	
3rd FL NORTH	318	St SW	✓	✓	✓	✓	NO	
3rd FL NORTH	319	St SW	✓	✓	✓	✓	YES	04261 OUTER FWS
3rd FL NORTH	320	St SW	✓	✓	✓	✓	NO	
3rd FL NORTH	321	St SW	✓	✓	✓	✓	YES	04240 APR Track
3rd FL NORTH	322	St SW	✓	✓	✓	✓	NO	
3rd FL NORTH	323	St SW	✓	✓	✓	✓	NO	
3rd FL NORTH	324	St SW	✓	✓	✓	✓	NO	
3rd FL NORTH	325	St SW	✓	✓	✓	✓	NO	
3rd FL NORTH	326	St SW	✓	✓	✓	✓	NO	

PARIS TERMINAL DOOR MAINT CHECK LIST

DATE: 5/11/13

Subm

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	3	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	5	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	7	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	9	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	11	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	13	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	15	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	17	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	19	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	21	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	23	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	25	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	27	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	29	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	31	St sid	✓	✓	✓	✓	✓	NO	

DATE: 5/11/13
 OPERATIONAL DOOR MAINT CHECK LIST

Jim

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	34	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	32	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	30	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	28	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	28	St sid	✓	✓	✓	✓	✓	NO	yes
LOWER LEVEL SOUTH	24	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	22	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	20	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	18	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL SOUTH	16	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	60	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	62	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	62A	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	63	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	64	St sid	✓	✓	✓	✓	✓	NO	

4th Floor Cotton Gums
 63884

03545

PASS BUS TERMINAL DOOR MAINT CHECK LIST

504m

DATE: 11/23/13 5:11/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PNOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	65	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	66	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	67	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	68	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	69	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	70	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	71	St sid	✓	✓	✓	✓	✓	YES	Top wheel 04/26/13
LOWER LEVEL NORTH	71A	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	72	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	73	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	74	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	75	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	75A	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	76	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	84A	St sid	✓	✓	✓	✓	✓	NO	
LOWER LEVEL NORTH	85	St sid	✓	✓	✓	✓	✓	NO	
A-1 NORTH		85	St sid	✓	✓	✓	✓	NO	

PLUMBING GENERAL DOOR MAINT CHECK LIST

Butler

DATE: 5/11/13

COMMENTS	REQUIRED REPAIR	PIVOTS	CLOSE SPEED	OPEN SPEED	SAFETY	ACT	TYPE	DOOR #	LOCATION
							St sid	81	LOWER LEVEL NORTH
							St sid	82	LOWER LEVEL NORTH
							St sid	83	LOWER LEVEL NORTH
							St sid	84	LOWER LEVEL NORTH
							St SW	301	3rd FL NORTH
							St SW	302	3rd FL NORTH
							St SW	303	3rd FL NORTH
							St SW	304	3rd FL NORTH
							St SW	305	3rd FL NORTH
							St SW	306	3rd FL NORTH
							St SW	307	3rd FL NORTH
							St SW	308	3rd FL NORTH
							St SW	309	3rd FL NORTH

RAILROAD TERMINAL DOOR MAINT CHECK LIST

DATE: 5/11/13

Sum

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	SI SW	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	311	SI SW	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	312	SI SW	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	313	SI SW	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	314	SI SW	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	315	SI SW	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	316	SI SW	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	317	SI SW	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	318	SI SW	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	319	SI SW	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	320	SI SW	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	321	SI SW	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	322	SI SW	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	323	SI SW	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	324	SI SW	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	325	SI SW	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	326	SI SW	✓	✓	✓	✓	✓	NO	

order per 5 04157

PA BUS TERMINAL DOOR MAINT CHECK LIST

DATE: 10/11/18

JKR

LOCATION	DOOR #	TYPE	ACT	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St SW	✓	✓	✓	✓	NO	
4th FL SOUTH	402	St SW	✓	✓	✓	✓	NO	
4th FL SOUTH	403	St SW	✓	✓	✓	✓	NO	
4th FL SOUTH	404	St SW	✓	✓	✓	✓	NO	
4th FL SOUTH	405	St SW	✓	✓	✓	✓	NO	
4th FL SOUTH	406	St SW	✓	✓	✓	✓	NO	
4th FL SOUTH	407	St SW	✓	✓	✓	✓	NO	
4th FL SOUTH	408	St SW	✓	✓	✓	✓	NO	
4th FL SOUTH	409	St SW	✓	✓	✓	✓	NO	
4th FL SOUTH	410	St SW	✓	✓	✓	✓	NO	
4th FL SOUTH	411	St SW	✓	✓	✓	✓	NO	
4th FL SOUTH	412	St SW	✓	✓	✓	✓	NO	
4th FL SOUTH	413	St SW	✓	✓	✓	✓	NO	
4th FL SOUTH	414	St SW	✓	✓	✓	✓	NO	
4th FL SOUTH	415	St SW	✓	✓	✓	✓	NO	
4th FL SOUTH	416	St SW	✓	✓	✓	✓	NO	

PAEBOSS PERIODICAL DOOR MAINT CHECK LIST

LOCATION	DOOR #	TYPE	ACT	SECURITY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	417	SI SW	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	418	SI SW	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	419	SI SW	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	420	SI SW	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	421	SI SW	✓	✓	✓	✓	✓	NO	
LOWER LEV SOUTH	14	ST SLD	✓	✓	✓	✓	✓	NO	
LOWER LEV SOUTH	12	ST SLD	✓	✓	✓	✓	✓	NO	
LOWER LEV SOUTH	10	ST SLD	✓	✓	✓	✓	✓	NO	
LOWER LEV SOUTH	8	ST SLD	✓	✓	✓	✓	✓	NO	
LOWER LEV SOUTH	6	ST SLD	✓	✓	✓	✓	✓	NO	
LOWER LEV SOUTH	4	ST SLD	✓	✓	✓	✓	✓	NO	
LOWER LEV SOUTH	2	ST SLD	✓	✓	✓	✓	✓	NO	
ROAD WAY EAST	SL1A1	BESAM SLD AMD 1	✓	✓	✓	✓	✓	NO	
ROAD WAY WEST	SL1A2	BESAM SLD AMD 1	✓	✓	✓	✓	✓	NO	

PA 805 TERMINAL DOOR MAINT CHECK LIST

LOCATION	DOOR #	TYPE	ACT	EASYS	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
DUTH WING 9th AVE	SL1R1	h std	✓	✓	✓	✓	✓	no	
DUTH WING 9th AVE	SL1R2	h std	✓	✓	✓	✓	✓	no	
DUTH WING 9th AVE	SL1R3	h revolver	✓	✓	✓	✓	✓	no	
DUTH WING 9th AVE	SL1R4	h revolver	✓	✓	✓	✓	✓	no	
41st STREET	S13A1	St sw	✓	✓	✓	✓	✓	no	
41st STREET	S13A2	St sw	✓	✓	✓	✓	✓	no	
DUTH WING 8TH AVE	S14A1A	Besam sw	✓	✓	✓	✓	✓	no	
DUTH WING 8TH AVE	S14A1B	Besam sw	✓	✓	✓	✓	✓	no	
DUTH WING 8TH AVE	S14A2A	Gt sw	✓	✓	✓	✓	✓	no	
DUTH WING 8TH AVE	S14A2B	Gt sw	✓	✓	✓	✓	✓	no	
DUTH WING 8TH AVE	S14A3A	Besam sw	✓	✓	✓	✓	✓	no	
DUTH WING 8TH AVE	S14A3B	Besam sw	✓	✓	✓	✓	✓	no	
DUTH WING 8TH AVE	S14A4A	Gt sw	✓	✓	✓	✓	✓	no	
DUTH WING 8TH AVE	S14A4B	Gt sw	✓	✓	✓	✓	✓	no	

DOOR AUTOMATION CORP.

DATE: 6/2/13

CUSTOMER: Bus Terminal

PO: _____

LOCATION: _____

TN: 13358

13358

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
OB	North wing	316	Stanley	swing	
DAC 04238					
394 Replaced outer Press wall switch					
315 Reset and ReProgram control					
316 TACO Door is working OK					
LL	North wing	31	Stanley	slide	
DAC 04915					
275 Replaced Turn Top wheels					
315 Reset and ReProgram control					
316 TACO Door is working OK					
LL	South wing	28	Stanley	slide	
DAC 03884					
277 Replaced R/H FS Guide					
315 Reset and ReProgram control					
326 TACO Door is working OK					
331 COM completed					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 11:30

TRUCK #: 520

ARRIVED HERE: 12:30

NO. OF MEN: 1

LEFT THIS JOB: 3:00

JOB COMPLETED: YES NO

JCA

MECHANICS

CUSTOMER'S SIGNATURE

PRINT NAME

DOOR AUTOMATION CORP.

DATE: 5/15/13

CUSTOMER: BOS Terminal PM ②

PO: _____

LOCATION: _____

TN: 13861

FLOOR	DEPARTMENT	ROOM	DOOR	TYPE	OPERATOR
JOB DESCRIPTION					
03	North wing	Gate 301	Stanley	Swing	
DAC 01352					
499 must return with door arm track to complete					
03	North wing	Gate 319	Stanley	Swing	
DAC 01352					
499 must return with outer press wall switch to complete					
03	North wing	Gate 311	Stanley	Swing	
DAC 03502					
315 reset and reprogram control					
316 & 317 door is working OK					
319 PM performed					

In consideration of the work performed by Door Automation Corp. pursuant to the "Job Description" set forth above ("Job"), Customer agrees to pay upon presentment by Door Automation Corp., any and all invoices relative to the Job.

Door automation Corp. will assume responsibility for damages or injury while working at the site of the Job, but only if resulting from negligence on the part of Door Automation Corp. or its employees or agents. Customer agrees to hold Door Automation Corp. harmless from all other claims or consequential damages. This document is not intended to, nor does it, supercede the terms and conditions of any Maintenance Agreement into which Door automation Corp. and Customer have entered pertaining to the Job.

PLEASE REVIEW DAILY SAFETY CHECK INSTRUCTIONS ON THE REVERSE SIDE OF THIS PAGE

LEFT PREV. JOB: 7100 TRUCK #: 320
 ARRIVED HERE: 8100 NO. OF MEN: 1
 LEFT THIS JOB: 2130 JOB COMPLETED: YES NO

Juan MECHANICS _____ CUSTOMER'S SIGNATURE _____ PRINT NAME

REPAIRS 7/13/13

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE: 5/15/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	1	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	3	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	5	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	7	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	9	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	11	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	13	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	15	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	17	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	19	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	21	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	23	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	25	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	27	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	29	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	31	St slid	✓	✓	✓	✓	✓	no	

Page: 1/9

RECEIVED 06/11/2012 09:10

From: 516-887-7270

JUN 11 2012 09:41

PAEUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE: 5/19/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL SOUTH	33	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	34	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	32	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	30	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	28	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	26	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	24	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	22	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	20	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	18	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL SOUTH	16	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	60	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	62	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	62A	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	63	St slid	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	64	St slid	✓	✓	✓	✓	✓	no	

RECEIVED 06/11/2012 09:10
 From: 516-887-7270
 JUN-11-2012 09:42
 Page: 2/9

PA BUS TERMINAL DOOR MAINT CHECK LIST

5/11/13

DATE: 5/15/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	65	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	66	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	67	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	68	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	69	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	70	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	71	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	71A	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	72	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	73	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	74	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	75	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	75A	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	76	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	84A	St sld	✓	✓	✓	✓	✓	no	
LOWER LEVEL NORTH	85	St sld	✓	✓	✓	✓	✓	no	

RECEIVED 06/11/2012 09:10 Page: 3/9

From: 516-887-7270

JUN-11-2012 09:43

PA BUS TERMINAL DOOR MAINT CHECK LIST

John

DATE: 6/15/12

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
LOWER LEVEL NORTH	81	St sid	/	/	/	/	/	NO	
LOWER LEVEL NORTH	82	St sid	/	/	/	/	/	NO	
LOWER LEVEL NORTH	83	St sid	/	/	/	/	/	NO	
LOWER LEVEL NORTH	84	St sid	/	/	/	/	/	NO	
3rd FL NORTH	301	St SW	/	/	/	/	/	Ann Track 205	01352
3rd FL NORTH	302	St SW	/	/	/	/	/	NO	
3rd FL NORTH	303	St SW	/	/	/	/	/	NO	
3rd FL NORTH	304	St SW	/	/	/	/	/	NO	
3rd FL NORTH	305	St SW	/	/	/	/	/	NO	
3rd FL NORTH	306	St SW	/	/	/	/	/	NO	
3rd FL NORTH	307	St SW	/	/	/	/	/	NO	
3rd FL NORTH	308	St SW	/	/	/	/	/	NO	
3rd FL NORTH	309	St SW	/	/	/	/	/	NO	

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE: 5/15/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
3rd FL NORTH	310	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	311	St sw	✓	✓	✓	✓	✓	YES STAIN OPEN	03562
3rd FL NORTH	312	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	313	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	314	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	315	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	316	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	317	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	318	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	319	St sw	✓	✓	✓	✓	✓	YES OUTER PWS	04201
3rd FL NORTH	320	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	321	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	322	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	323	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	324	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	325	St sw	✓	✓	✓	✓	✓	NO	
3rd FL NORTH	326	St sw	✓	✓	✓	✓	✓	NO	

RECEIVED 06/11/2012 09:10
 Page: 5/9
 JUN-11-2012 09:44 From: 516-887-7270

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE: 6/13/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	401	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	402	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	403	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	404	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	405	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	406	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	407	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	408	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	409	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	410	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	411	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	412	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	413	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	414	St sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	415	st sw	✓	✓	✓	✓	✓	NO	
4th FL SOUTH	416	st sw	✓	✓	✓	✓	✓	NO	

Page: 6 of 9

RECEIVED 06/11/2012 09:10

From: 516-887-7270

JUN-11-2012 09:44

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUAN

DATE: 5/15/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
4th FL SOUTH	417	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	418	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	419	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	420	St sw	✓	✓	✓	✓	✓	no	
4th FL SOUTH	421	St sw	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	14	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	12	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	10	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	8	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	6	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	4	ST SLD	✓	✓	✓	✓	✓	no	
LOWER LEV SOUTH	2	ST SLD	✓	✓	✓	✓	✓	no	
ROAD WAY EAST	SL1A1	BESAM SLD AMD 1	✓	✓	✓	✓	✓	no	
ROAD WAY WEST	SL1A2	BESAM SLD AMD 1	✓	✓	✓	✓	✓	no	

RECEIVED 06/11/2012 09:10
 From: 516-887-7270
 JUN-11-2012 09:45
 Page: 7/9

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUN

DATE: 5/15/13

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
SOUTH WING 9th AVE	SL1R1	h sld	✓	✓	✓	✓	✓	no	
SOUTH WING 9th AVE	SL1R2	h sld	✓	✓	✓	✓	✓	no	
SOUTH WING 9th AVE	SL1R3	h revolver	✓	✓	✓	✓	✓	no	
SOUTH WING 9th AVE	SL1R4	h revolver	✓	✓	✓	✓	✓	no	
41st STREET	S13A1	St sw	✓	✓	✓	✓	✓	no	
41st STREET	S13A2	St sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A1A	Besam sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A1B	Besam sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A2A	Gt sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A2B	Gt sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A3A	Besam sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A3B	Besam sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A4A	Gt sw	✓	✓	✓	✓	✓	no	
SOUTH WING 8TH AVE	S14A4B	Gt sw	✓	✓	✓	✓	✓	no	

Page: 8/9

RECEIVED 06/11/2012 09:10

From: 516-887-7270

JUN-11-2012 09:45

PA BUS TERMINAL DOOR MAINT CHECK LIST

JUN 10

DATE: 5/15/12

LOCATION	DOOR #	TYPE	ACT	SAFETY	OPEN SPEED	CLOSE SPEED	PIVOTS	REQUIRED REPAIR	COMMENTS
NORTH WING 8th ave	N1BA1A	Besam sw	✓	✓	✓	✓	✓	no	
NORTH WING 8th ave	N1BA1B	Besam sw	✓	✓	✓	✓	✓	no	
NORTH WING 8th ave	N1BA2A	Besam sw	✓	✓	✓	✓	✓	no	
NORTH WING 8th ave	N1BA2B	Besam sw	✓	✓	✓	✓	✓	no	
NORTH WING 8th ave	N1BA3A	Besam sw	✓	✓	✓	✓	✓	no	
NORTH WING 8th ave	N1BA3B	Besam sw	✓	✓	✓	✓	✓	no	
NORTH WING 8th ave	N1BA4A	Besam sw	✓	✓	✓	✓	✓	no	
NORTH WING 8th ave	N1BA4B	Besam sw	✓	✓	✓	✓	✓	no	
TAXI RD WAY	BT4405	Besam sw	Area Close						
TAXI RD WAY	BT4406	Besam sw							

RECEIVED 06/11/2012 09:10 Page: 9/9

JUN-11-2012 09:46 From: 516-887-7270